

The following is a list of the days when PJM likely would have triggered the proposed RT Operating Reserve Requirement during 2013 and through July 2014.

This determination is based on PJM operators having scheduled additional resources in excess of a half a percent of the peak load (based on the economic mins of the additionally scheduled units), consistent with the trigger included in the RT Operating Reserve proposal.

The alert column indicates any hot weather (HWA), cold weather (CWA) or Emergency alerts that were in place for each day listed.

Day	Approx. Peak Load (MW)	Threshold (MW) (Half Percent of Peak Load)	Alert
1/21/2013	115400	580	CWA
1/22/2013	129000	650	CWA
1/23/2013	125200	630	CWA
1/24/2013	126500	630	CWA
11/23/2013	100800	500	
12/12/2013	126200	630	
12/13/2013	120600	600	
1/2/2014	123100	620	CWA
1/3/2014	129200	650	CWA
1/4/2014	117100	590	
1/5/2014	109900	550	
1/6/2014	132800	660	CWA
1/7/2014	142700	710	CWA
1/8/2014	135900	680	CWA
1/9/2014	122400	610	
1/20/2014	111200	560	
1/21/2014	131500	660	CWA
1/22/2014	137700	690	CWA
1/23/2014	137200	690	CWA
1/24/2014	140300	700	CWA
1/25/2014	120700	600	
1/26/2014	115700	580	
1/27/2014	129600	650	CWA
1/28/2014	139700	700	CWA
1/29/2014	135700	680	CWA
3/3/2014	127400	640	
3/4/2014	126300	630	
3/12/2014	102800	510	
3/13/2014	117600	590	