

# Subregional RTEP Committee – Western Duquesne Light Supplemental Projects

May 17, 2024

# Solutions

Stakeholders must submit any comments within 10 days of this meeting in order to provide time necessary to consider these comments prior to the next phase of the M-3 process

**Need Number:** DLC-2024-002

**Process Stage:** Needs Meeting – 3/15/2024  
Solutions Meeting – 5/17/2024

**Supplemental Project Driver(s):**

- Customer Service
- Equipment Material Condition, Performance, and Risk

**Specific Assumptions Reference:**


Slides 6 and 9 of the DLC 2024 Local Planning Assumptions.

**Problem Statement:**

Duquesne Light’s Distribution Planning team has determined that Dravosburg Substation has limited capacity to serve new distribution load due to the size of the station’s existing distribution transformers.

Duquesne Light’s Asset Management team has determined that the Dravosburg #1 and #2 138-69 kV autotransformers have increased failure probability due to:

- Equipment Age (#1 138-69 kV autotransformer age: 64 years, #2 138-69 kV autotransformer age: 44 years)
- Obsolescence (Spare parts are not readily available)



# DLCO Transmission Zone M-3 Process West Mifflin, PA

**Need Number:** DLC-2024-002

**Process Stage:** Solution Meeting – 5/17/2024

**Previously Presented:** Needs Meeting – 3/15/2024

**Proposed Solution:**

Eliminate the 69 kV voltage level from Dravosburg Substation by replacing the two aged 138-69 kV autotransformers and the station’s existing 69-23 kV transformers with two new 138-23 kV transformers. This elimination will require an extension of the 138 kV bus, the addition of 3 new 138 kV breakers, and the removal of the 69 kV bus and associated breakers.

**Estimated Cost:** \$8.5 M

**Ancillary Benefits:**



The proposed solution removes the last 69-23 kV transformers from the DLC system.

**Alternatives Considered:**

- Maintain existing condition** – Maintaining the existing condition of the equipment does not address the increased failure risk of the aged transformers and does not address Dravosburg Substation’s limited capacity to serve new distribution load . Estimated Cost: N/A

**Projected In-Service:** 1<sup>st</sup> Transformer June 2025, 2<sup>nd</sup> transformer December 2027

**Project Status:** Planning



Legend	
138 kV	
69 kV	
23 kV	
New	

# Appendix

# High Level M-3 Meeting Schedule

Assumptions	Activity	Timing
	Posting of TO Assumptions Meeting information	20 days before Assumptions Meeting
	Stakeholder comments	10 days after Assumptions Meeting
Needs	Activity	Timing
	TOs and Stakeholders Post Needs Meeting slides	10 days before Needs Meeting
	Stakeholder comments	10 days after Needs Meeting
Solutions	Activity	Timing
	TOs and Stakeholders Post Solutions Meeting slides	10 days before Solutions Meeting
	Stakeholder comments	10 days after Solutions Meeting
Submission of Supplemental Projects & Local Plan	Activity	Timing
	Do No Harm (DNH) analysis for selected solution	Prior to posting selected solution
	Post selected solution(s)	Following completion of DNH analysis
	Stakeholder comments	10 days prior to Local Plan Submission for integration into RTEP
	Local Plan submitted to PJM for integration into RTEP	Following review and consideration of comments received after posting of selected solutions

## Revision History

5/7/2024– V1 – Original version posted to pjm.com