

The background of the slide is a photograph of several high-voltage transmission towers (pylons) stretching across the frame. The towers are silhouetted against a bright blue sky filled with scattered white clouds. The perspective is from a low angle, looking up at the towers, which recede into the distance. The overall color palette is dominated by blues and whites, with a slight desaturation effect.

Transmission Expansion Advisory Committee Market Efficiency Update

November 11, 2014

Market Efficiency Long Term Proposal Window



2014 RTEP Long Term Proposal Window: Market Efficiency

- Identify enhancements or expansion that could relieve PJM transmission constraints stemming from the 2014 Market Efficiency Analysis for which no reliability based project has already been identified.
- Perform and compare market simulations with and without proposed enhancements or expansions to evaluate if the Benefit/Cost Ratio is at least 1.25 using the criteria as defined in Schedule 6, Section 1.5.7 of the PJM Operating Agreement and PJM Manual 14B, Attachment E.
- Perform high level reliability analysis of proposed Market Efficiency enhancements or expansions to ensure the proposed enhancement or expansion does not create any reliability issues.

- Stakeholder feedback received on initial base congestion results
 - PJM incorporated appropriate changes
- Updated PROMOD case files and necessary documents provided at following link
 - Includes descriptions of changes from original posted case files

<http://pjm.com/planning/rtep-development/market-efficiency.aspx>
- PJM identified recommended facilities for which proposals may be submitted
 - Recommended facilities provided in 2014 Market Efficiency Congestion Results file at following link:
<http://pjm.com/planning/rtep-development/market-efficiency.aspx>
 - PJM to identify if any facilities may have potential low cost or simple solutions
- Additional feedback since window opened will result in new base congestion, recommended facilities, and updated PROMOD files

- Market Efficiency Criteria for facilities recommended for proposals:
 - Annual simulated congestion frequency of at least 25 hours in 2019 and 2022 study years.
 - Lower voltage facilities: Minimum of \$1 million congestion in 2019 and 2022 study years.
 - Regional facilities: Minimum of \$10 million congestion in 2019 and 2022 study years.
 - Facilities below these thresholds are not anticipated to pass the Benefit/Cost Criteria because of the expected cost of an upgrade. Congestion for 2025 study year is considered more speculative and therefore will be monitored in future analysis.
- RPM Criteria:
 - PJM will accept proposals to address the following corridor for which has had consistent capacity import limitations and thermal overloads.
 - Roseland-Cedar Grove-Clifton 230 kV corridor

Supplemental Projects

- Several submitted supplemental projects may fix Market Efficiency congestion
- Supplemental projects may be re-designated if pass B/C and still in Engineering/Design phase
 - Projects must be submitted during proposal window
- Supplemental projects will be added to base case if in construction phase

Long Term Proposal Window

- Update base congestion results and list of recommended facilities (November)
- Add notes for potential low cost upgrades, if any (November)
- Develop ARR mapping file (December)
- Create B/C user spreadsheet (December)
- **Proposal window will NOT be extended**

Market Efficiency Facilities Recommended for Long term Proposal Window



Market Efficiency Facilities: Regional

Constraint: AP SOUTH Interface I/o Black Oak-Bedington

- Area: Reactive Interface
- Congestion:
 - 2019: \$112.4 million
 - 2022: \$130.5 million

Constraint: AEP-DOM Interface I/o Black Oak-Bedington

- Area: Reactive Interface
- Congestion:
 - 2019: \$22.6 million
 - 2022: \$34.5 million

Constraint:


Miami Fort to Willey 138 kV Line

➤ Area: DEOK

➤ Congestion:


2019: \$22.7 million

2022: \$35.8 million




Constraint:
Worcester to Ocean Pines 69 kV Line

- Area: DPL
- Congestion:
 - 2019: \$23.7 million
 - 2022: \$26.8 million
- Potential Upgrade:
 - S0837: Rebuild the Worcester - Ocean City 69 kV circuit '6724'



Constraint:
Safe Harbor to Graceton 230 kV Line

- Area: PPL-BGE
- Congestion:
 - 2019: \$28 million
 - 2022: \$21.1 million
- Congestion will be impacted by below upgrade:
 - B0497: Install a second Conastone - Graceton 230 kV circuit and replace Conastone 230 kV breaker 2323/2302 will impact congestion
 - Upgrade will be added to base case and results will be updated



Constraint:


Brunner Island to Yorkana 230 kV Line

➤ Area: METED-PPL

➤ Congestion:


2019: \$28.2 million

2022: \$29 million




Constraint: Frackville to Siegfried 230 kV Line

- Area: PPL
- Congestion:
 - 2019: \$13 million
 - 2022: \$14.5 million
- Congestion may be impacted by below upgrade that is under construction
 - S0148: New substation at Sunbury may eliminate the contingency causing congestion
 - Upgrade will be added to base case and results will be updated



Constraint:
Crescent 345 kV Transformer


- Area: DUQ
- Congestion:
 - 2019: \$8.9 million
 - 2022: \$30.7 million
- Congestion will be impacted by below upgrade:
 - Operate with the Crescent 345/138 kV #3 autotransformer in-service by replacing 8 over dutied 138 kV breakers at Crescent, 3 138 kV breakers at Beaver Valley, install #1 section 345 kV breaker for 331 circuit at Crescent
 - Upgrade will be added to base case and results will be updated



Constraint:

Dravosburg to West Mifflin 138 kV Line


- Area: DUQ
- Congestion:
 - 2019: \$4 million
 - 2022: \$5.9 million



Market Efficiency Facilities: DUQ


Constraint:
Woodville to 15USAP 138 kV Line

- Area: DUQ
- Congestion:
 - 2019: \$1.8 million
 - 2022: \$4.7 million




Constraint:
Taneytown to Carroll 138 kV Line

- Area: APS
- Congestion:
 - 2019: \$24.6 million
 - 2022: \$13.6 million



Constraint:
Cordova to Nelson 345 kV Line

- **Area:** ComEd
- **Congestion:**
 - 2019: \$9.7 million
 - 2022: \$12.4 million
- **Potential Upgrade:**
 - S0704: Reconductor 0.4 miles of 345 kV line
 - 15503 from Cordova to Nelson and replace breaker leads at Nelson




Market Efficiency Facilities: ComEd

Constraint:

Lorreto to Wilton CTR 345 kV Line


- Area: ComEd
- Congestion:
 - 2019: \$2.8 million
 - 2022: \$8 million



Constraint:


Fieldale to Thornton 138 kV Line

- Area: AEP
- Congestion:
 - 2019: \$2.1 million
 - 2022: \$8.5 million
- Notes:
 - Circuit from Fieldale-Thornton-Franklin would need to be upgraded




Constraint:
Charlottesville to Proffit DP 230 kV Line

- Area: DOM
- Congestion:
 - 2019: \$1.4 million
 - 2022: \$2.9 million




Constraint:
Sub 56 (Davenport) to East Calamus 161 kV Line

- Area: M2M
- Congestion:
 - 2019: \$3.5 million
 - 2022: \$19.3 million



Constraint:
Bunsonville to Eugene 345 kV Line


- Area: M2M
- Congestion:
 - 2019: \$4.6 million
 - 2022: \$12.9 million
- AMEREN and AEP upgrade in 2015 anticipated to remove this congestion
- Upgrade will be added to base case and results will be updated



Constraint:

Racine to Pleasant Prairie 345 kV Line


- Area: M2M
- Congestion:
 - 2019: \$1.6 million
 - 2022: \$3.2 million
- ATC uprating line expected in February 2015
- Upgrade will be added to base case and results will be updated



Constraint:

Roseland-Cedar Grove-Clifton 230 kV corridor

- Area: PSEG
- Capacity import limitations and thermal overloads at the CETL for following modeled LDAs
 - PS
 - PS North



- Study of approved RTEP projects for accelerations and modifications
 - Compare congestion for near term vs. future topology
 - Estimate economic impact of accelerating planned upgrades
- No previously approved RTEP projects subject to B/C acceleration analysis
 - Approved projects with impact are either already under construction or can't be advanced
- Investigating if ISD of Crescent transformer can be advanced
 - Operate with the Crescent 345/138 kV #3 autotransformer in-service by replacing 8 over dutied 138 kV breakers at Crescent, 3 138 kV breakers at Beaver Valley, install #1 section 345 kV breaker for 331 circuit at Crescent
 - Listed as Market Efficiency congested facility

Questions?

Email: RTEP@pjm.com