



Market Efficiency Update

Transmission Expansion Advisory Committee
February 8, 2018

- Conclusion of 2017 Acceleration Analysis (2nd read)
- Conclusion of Market Efficiency Re-evaluation Efforts (2014/15 Window)
- 2016/17 RTEP Window Update
- 2018/19 RTEP Window Cycle

Conclusion of 2017 Acceleration Analysis

- PJM completed the acceleration analysis
 - 2018 (AS-IS) and 2022 (RTEP) set of economic input assumptions used to study impacts of approved RTEP reliability upgrades
 - Compared the board approved reliability upgrades with the congestion reductions between the AS-IS and the RTEP Base cases
 - Estimated economic impact of accelerating RTEP reliability upgrades
- RTEP B2766 was selected for acceleration from 2021 to 2020
 - Upgrade substation equipment at Conastone and Peach Bottom 500 kV stations to increase facility Normal/Emergency rating to 2826/3525 MVA. (b2766.1 - b2766.2)
 - Estimated annual congestion savings: \$4.4 million
 - Acceleration cost: 0\$

Conclusion of Market Efficiency Re-evaluation Efforts (2014/15 RTEP Window)

- PJM presented at the September 2017 TEAC the results of the reevaluation process:
 - Applied to market efficiency projects approved during the 2014/15 RTEP Window
 - Analysis performed individually, one project at a time
 - All projects analyzed passed the B/C ratio threshold of 1.25
- PJM re-evaluated project 2014/15_1-9A, AP-South, (b2743.1-8, b2752.1-7), with the most recent Market Efficiency base case update (posted on 1/9/2018)
 - The updated B/C ratio is 1.32
- Updated B/C Ratios Re-evaluation table included in Appendix B



2016/2017 Long Term Window – BGE Group

- Reran all submitted proposals with the posted Final Update Base Case
 - Included Crane generator retirement along with corresponding reliability upgrade.
 - Updated the load forecast to reflect the 2018 PJM Load Forecast.
- Results similar to those previously presented at November 2017 TEAC
 - Conclusions remain unchanged
 - A number of proposals did not pass the B/C ratio threshold.
 - Some proposals did not fully address the congestion driver or introduced new significant congestion.
 - Updated B/C ratios included in Appendix A.
- Due to the significant decrease in the posted congestion drivers, upgrades are the most cost-effective solutions. (see next slide)



BGE Posted Congestion Drivers

- Congestion drivers decreased 65% compared to the start of the RTEP Window

BGE Congestion Drivers (posted November 2016)

Facility Name	AREA	2017 Market Congestion (\$ Millions)	2021 Market Congestion (\$ Millions)	2024 Market Congestion (\$ Millions)	2027 Market Congestion (\$ Millions)	Average 2021, 2024 (\$ Millions)
GRACETON TO CONASTON 230kV	BGE	\$ 51.80	\$ 58.26	\$ 72.10	\$ 68.88	\$ 65.18
BAGLEY TO GRACETON 230kV	BGE	\$ 23.59	\$ 33.01	\$ 49.55	\$ 59.57	\$ 41.28
Total Target Congestion Driver		\$ 75.39	\$ 91.27	\$ 121.65	\$ 128.45	\$ 106.46

BGE Congestion Drivers Latest Base Case (posted January 2018)

Facility Name	AREA	2017 Market Congestion (\$ Millions)	2021 Market Congestion (\$ Millions)	2024 Market Congestion (\$ Millions)	2027 Market Congestion (\$ Millions)	Average 2021, 2024 (\$ Millions)
GRACETON TO CONASTON 230kV	BGE	\$ 19.80	\$ 13.55	\$ 23.50	\$ 17.33	\$ 18.52
BAGLEY TO GRACETON 230kV	BGE	\$ 36.88	\$ 12.87	\$ 24.17	\$ 16.94	\$ 18.52
Total Target Congestion Driver		\$ 56.69	\$ 26.42	\$ 47.67	\$ 34.28	\$ 37.05

Decrease \$ (69.41) -65%

- B/C ratio of 8.16
 - Highest among proposals submitted for the BGE constraints.
- Fully addresses target congestion driver
 - Conastone – Graceton – Bagley 230 kV
- Addresses downstream congestion expected to be relieved on the 230 kV & 115 kV system
 - Bagley – Raphael 230 kV; Raphael – Northeast 230 kV
 - Glenarm – Windy Edge 115 kV
- Remaining shifted congestion is within acceptable levels
 - Congestion shifts < \$1million/year (average 2021, 2024)

- Completed 5E Sensitivity Analysis
 - 5E Passes all PROMOD sensitivity scenarios

Base Case Name	In Service	Cost	B/C Ratio
5E Base Case	2021	\$ 25.40	8.16
5E Sensitivity - Low Gas Forecast	2021	\$ 25.40	17.45
5E Sensitivity - High Gas Forecast	2021	\$ 25.40	2.42
5E Sensitivity - Low Load Forecast	2021	\$ 25.40	6.95
5E Sensitivity - High Load Forecast	2021	\$ 25.40	8.40
5E Sensitivity - No FSA Units	2021	\$ 25.40	4.82

- Reliability Analysis has been completed and no reliability violation identified as a result of the 5E Market Efficiency proposal
- Cost/Constructability Analysis in-progress
 - Constructability review to be completed by the end of February (see next slide)

- PJM and BGE had discussions to understand the existing conditions and proposed project scope
- PJM is conducting full constructability review, which is expected to be completed by the end of February
- Project component constructability assessment
 - Graceton – Bagley – Raphael Rd 230 kV
 - Scope: Install bundled conductor along 20 mile double circuit 230 kV corridor
 - Rebuild completed in Feb 2017 was designed to support the second conductor
 - All hardware and insulators will be re-used

- Project component constructability assessment (con't)
 - Raphael Road – Northeast 230 kV line
 - Scope: Reconductor the 4 mile double 230kV circuit corridor
 - Equipment approximately 30 years old
 - Existing insulators and hardware to be replaced
 - Minor tower loading change with new conductor limits rebuild risk

 - Conastone – Graceton 230 kV line
 - Scope: Reconductor the 9 mile double 230kV circuit corridor
 - Existing insulators and hardware to be replaced
 - Proposed project cost included scope to rebuild 5 structures and reinforce remaining structures where required

Project ID: 201617_1-5E

Proposed by: BGE

Proposed Solution:

Reconductor the Conastone to Graceton 230kV lines. Upgrade substation equipment at Conastone. Add bundled conductors to the Graceton-Bagley-Raphael Road 230kV double circuit lines. Reconductor the Raphael Road to Northeast 230 kV double circuit lines. Upgrade substation equipment at Windy Edge substation.

kV Level: 115/230 kV

In-Service Cost (\$M): \$25.40


In-Service Date: 2021

Target Zone: BGE

ME Constraints:


CONASTONE - GRACETON - BAGLEY 230 kV

Notes: **To be recommended for approval at the next Board meeting.**



- Pending constructability review, PJM will be recommending BGE's proposal 5E for approval at the April Board meeting.
- PJM will complete PPL Group analysis with 5E included in the base case
- PJM will present the final conclusions for the 2016/17 RTEP Window at the March TEAC

2018/2019 Long Term Window





Step	Timeline
Develop Assumptions	February – May 2018
Build Base Case	June – July 2018
Identify Congestion Drivers	August – September 2018
Post Base Case and Congestion Drivers	October 2018
Proposal Window	November 2018 - February 2019
Analysis of Proposed Solutions	March - November 2019
Final TEAC Review and Board Approval	November - December 2019

Appendix A

BGE Group Updated Results




Proposal	5A	5B	5C	5D	5E
In-Service cost (\$M)	\$ 5.97	\$ 14.20	\$ 20.30	\$ 20.40	\$ 25.40
In-service Year	2020	2021	2021	2021	2021
B/C Ratio	11.99	6.38	8.15	8.16	8.16
Fully Solves Target Congestion	No	No	Yes	Yes	Yes
Creates other BGE/PECO Congestion	No	Yes	Yes	Yes	See Slide 10

Map







Proposal	6F	6G	6L	6M
In-Service cost (\$M)	\$ 49.20	\$ 56.00	\$ 41.70	\$ 65.49
In-service Year	2021	2021	2021	2021
B/C Ratio	4.05	3.67	5.23	3.28
Fully Solves Target Congestion	Yes	Yes	Yes	Yes
Creates other BGE/PECO Congestion	Yes	Yes	Yes	Yes

Map






Proposal	7H	7I	7J	7K
In-Service cost (\$M)	\$ 35.60	\$ 59.80	\$ 68.10	\$ 191.40
In-service Year	2021	2021	2022	2022
B/C Ratio	5.57	3.90	3.56	1.10
Fully Solves Target Congestion	No	No	Yes	Yes
Creates other BGE/PECO Congestion	Yes	Yes	Yes	Yes

Map







Proposal	10C	10D	10E
In-Service cost (\$M)	\$ 44.40	\$ 93.50	\$ 105.70
In-service Year	2021	2021	2021
B/C Ratio	2.50	1.22	0.48
Fully Solves Target Congestion	No	No	Yes
Creates other BGE/PECO Congestion	Yes	Yes	Yes

Map





Proposal	13A	13B	13C	13D
In-Service cost (\$M)	\$ 457.80	\$ 107.49	\$ 169.27	\$ 182.99
In-service Year	2024	2022	2022	2022
B/C Ratio	0.54	2.06	1.31	1.16
Fully Solves Target Congestion	Yes	No	No	No
Creates other BGE/PECO Congestion	No	Yes	Yes	Yes

Map




Proposal	13E	13F	13G
In-Service cost (\$M)	\$ 179.22	\$ 483.21	\$ 192.07
In-service Year	2022	2024	2022
B/C Ratio	1.23	0.58	0.86
Fully Solves Target Congestion	No	Yes	No
Creates other BGE/PECO Congestion	No	No	No

Map




Proposal	14A
In-Service cost (\$M)	\$ 114.80
In-service Year	2023
B/C Ratio	1.17
Fully Solves Target Congestion	Yes
Creates other BGE/PECO Congestion	Yes

Map







Proposal	15A	15B
In-Service cost (\$M)	\$ 138.50	\$ 178.30
In-service Year	2022	2022
B/C Ratio	1.75	1.91
Fully Solves Target Congestion	Yes	Yes
Creates other BGE/PECO Congestion	Yes	No

Map



Proposal	16A	16B	16C	16D	16E
In-Service cost (\$M)	\$ 70.50	\$ 92.20	\$ 87.20	\$ 105.10	\$ 109.30
In-service Year	2021	2021	2021	2021	2021
B/C Ratio	3.03	2.34	1.77	1.82	2.67
Fully Solves Target Congestion	No	No	No	No	No
Creates other BGE/PECO Congestion	Yes	Yes	Yes	No	No



Map



Northeast Transmission Development (6 proposals)

Proposal	18A	18B	18C
In-Service cost (\$M)	\$ 126.20	\$ 132.80	\$ 149.90
In-service Year	2021	2021	2021
B/C Ratio	2.23	2.26	1.83
Fully Solves Target Congestion	Yes	Yes	Yes
Creates other BGE/PECO Congestion	No	No	No




Map



Northeast Transmission Development (continue)


Proposal	18D	18E	18F
In-Service cost (\$M)	\$ 166.00	\$ 152.90	\$ 95.30
In-service Year	2021	2021	2021
B/C Ratio	1.70	1.95	2.18
Fully Solves Target Congestion	Yes	Yes	No
Creates Other BGE Congestion	No	No	Yes

Map



Proposal	20A	20B	20C	20D	20E
In-Service cost (\$M)	\$ 73.60	\$ 63.00	\$ 135.80	\$ 75.90	\$ 132.20
In-service Year	2021	2021	2021	2021	2021
B/C Ratio	3.14	1.59	1.41	1.52	2.90
Fully Solves Target Congestion	Yes	Yes	No	No	No
Creates other BGE/PECO Congestion	Yes	Yes	Yes	Yes	Yes

Map



Proposal	20F	20G	20H	20I
In-Service cost (\$M)	\$ 126.00	\$ 151.50	\$ 107.50	\$ 165.70
In-service Year	2021	2021	2021	2021
B/C Ratio	0.65	1.30	3.51	2.71
Fully Solves Target Congestion	No	No	Yes	Yes
Creates Other BGE Congestion	Yes	Yes	Yes	Yes
Map				

Appendix B

BC Ratios Reevaluation Market Efficiency Projects (2014/15 RTEP Window)



Reevaluation Results (updated 02/2018)

PJM Window Project ID	Baseline#	Type	Area	Constraint	Cost (\$mill)	In-Service Date	B/C 2014/15 Window	BC Reevaluation 2017
201415_1-2A	b2690	Upgrade	PPL/BGE	Safe Harbor to Graceton 230 kV	\$ 1.10	2019	14.4	1.72
201415_1-2B	b2691	Upgrade	ME/PPL	Brunner Island to Yorkana 230 kV	\$ 3.10	2019	22.2	2.84
201415_1-4I	b2697.1-2	Upgrade	AEP	Fieldale to Thornton 138 kV	\$ 0.75	2019	101.2	9.47
201415_1-4J	b2698	Upgrade	AEP	Jacksons Ferry to Cloverdale 765 KV	\$ 0.50	2019	62	46.18
201415_1-9A	b2743.1-8, b2752.1-7	Greenfield	APS/BGE	AP-South	\$340.60	2020	2.48	1.32*
201415_1-10B	b2693	Upgrade	COMED	Wayne to South Elgin 138 kV	\$ 0.10	2019	6.4	25.03
201415_1-10J	b2692.1-2	Upgrade	COMED	Cordova to Nelson 345 kV	\$ 24.60	2019	1.9	1.59
201415_1-10D	b2728	Upgrade	COMED	Loretto-Wilton 345 kV (RPM)	\$ 11.50	2017	64.5	In-service
201415_1-11H	b2694	Upgrade	PECO	Peach Bottom 500 kV	\$ 9.70	2019	3	5.70
201415_1-12A	b2689.1-2	Upgrade	DUQ	Dravosburg to West Mifflin 138 kV	\$ 11.18	2018	2	2.63
201415_1-13E	b2695	Upgrade	DPL	Worcester to Ocean Pines (I) 69 kV	\$ 2.40	2019	65.3	10.14
201415_1-18G	b2688.1-3	Upgrade	APS	Taneytown to Carroll 138 kV	\$ 5.20	2019	90.1	8.50
201415_1-18I	b2696	Upgrade	APS/ATSI	Krendale to Shanor Manor 138 kV	\$ 0.60	2019	123.4	78.88
Optimal Caps	b2729	Upgrade	DOM	AP-South	\$ 8.98	2019	15.4	2.16

Note: * B/C ratio calculated based on the Market Efficiency Base Case posted on 1/9/2018

- Revision History
 - V1 – 2/5/2018 – Original Version Posted to PJM.com