



# Impact of Station Service Rates on Start-Up Cost Calculations

Tom Hauske  
Cost Development Sub-Committee  
September 28, 2023

- For units without a soak process (combustion turbines, reciprocating engines), Start-Up Cost include costs from PJM notification to first breaker close and from last breaker open to shutdown (Status Quo).
- For units with a soak process (steam, combined cycle, nuclear) Start-Up Cost include costs from PJM notification to dispatchable output and from last breaker open to shutdown.




# M15 Section 2.4.1 Start-Up Cost Equation

$$\begin{aligned} \text{Start - upCost } (\$/\text{Start}) = & \\ & [\text{StartFuel (MMBtu}/(\text{Start})) * \text{TotalFuelRelatedCost } (\$/\text{MMBtu}) * \text{PerformanceFactor}] \\ & + [\text{StationService (MWh)} * \text{StationServiceRate } (\$/\text{MWh})] + \text{StartMaintenanceAdder } (\$/\text{Start}) \cdot \end{aligned}$$

Where


$$\begin{aligned} \text{TotalFuelRelatedCosts} = & \\ & \text{FuelCosts} + \text{SO}_2 \text{ AllowanceCost} + \text{CO}_2 \text{ AllowanceCost} + \text{NO}_x \text{ AllowanceCost} + \text{MaintenanceAdder} + \text{OperatingCostAdder} \end{aligned}$$



\* Duration limited to unit specific start and soak time or M15 defaults

- Start-Up Costs were calculated for a Steam Unit and a Combined Cycle Unit using both a 12 Month Station Service Average and a 3 Month Station Service Average
- PJM is demonstrating this calculation to show the impact of a change in the Station Service Rate on the Start-Up calculation. It does not indicate that PJM favors a 3 Month Average over a 12 Month Average

- 100 MW Steam Unit
- Fuel Cost = \$4/mmBtu
- Performance Factor = 1.02
- Allowance Cost = \$0.10/mmBtu
- Maintenance Adder = \$0.25/mmBtu
- Operating Cost Adder = \$0.05/mmBtu
- Station Service Rate = \$55.84/MWh (12 Month Average)
- Unit Specific Start Time = 8 Hour
- Unit Specific Soak Time = 3 Hour



- Total Fuel Related Cost = \$4/mmBtu + \$0.10/mmBtu + \$0.25/mmBtu + \$0.05/mmBtu = \$4.40/mmBtu
- Start Fuel = (50mmBtu/hr \* 3 hr) + (75mmBtu/hr \* 2 hr) + (150mmBtu/hr \* 2 hr) + (150mmBtu/hr \* 2 hr) + (1200mmBtu/hr \* 1 hr) + (0mmBtu/hr \* 1 hr) = 2,100mmBtu
- Station Service = (10 MWh \* 1 hr) + (10MWh \* 3 hr) + (10MWh \* 2 hr) - (10MWh \* 2 hr) - (10MWh \* 2 hr) - (100MWh \* 1 hr) + (4MWh \* 1 hr) = -76 MWh



# Steam Unit Start-Up Example - 12 Month Average

*Start – upCost (\$/Start) =*

$$\begin{aligned} & [StartFuel (MMBtu/(Start)) * TotalFuelRelatedCost (\$/MMBtu) * PerformanceFactor] \\ & + [StationService (MWh) * StationServiceRate (\$/MWh)] + StartMaintenanceAdder (\$/Start) \cdot \end{aligned}$$

- Start-Up Cost = (2,100mmBtu \* \$4.40/mmBtu \* 1.02)  
+ (-76 MWh \* \$55.84/MWh)  
+ \$0/Start  
= \$5,180.96/Start

- 100 MW Steam Unit
- Fuel Cost = \$4/mmBtu
- Performance Factor = 1.02
- Allowance Cost = \$0.10/mmBtu
- Maintenance Adder = \$0.25/mmBtu
- Operating Cost Adder = \$0.05/mmBtu
- Station Service Rate = **\$24.04/MWh** (2023 Q3 3 Month Average)
- Unit Specific Start Time = 8 Hour
- Unit Specific Soak Time = 3 Hour

# Steam Unit Start-Up Example – 3 Month Average

*Start – upCost (\$/Start) =*

$$\begin{aligned} & [StartFuel (MMBtu/(Start)) * TotalFuelRelatedCost (\$/MMBtu) * PerformanceFactor] \\ & + [StationService (MWh) * StationServiceRate (\$/MWh)] + StartMaintenanceAdder (\$/Start) \cdot \end{aligned}$$


- Start-Up Cost = (2,100mmBtu \* \$4.40/mmBtu \* 1.02)  
+ (-76 MWh \* **\$24.04/MWh**)  
+ \$0/Start  
= \$7,597.76/Start



## Combined Cycle Unit Start-Up Example – 12 Month Average

- 2 X1 Combined Cycle
- (2) 100 MW CTs
- 100 MW ST
- Fuel Cost = \$4.00
- Performance Factor = 1.20
- Allowance Cost = \$0.10/mmBtu
- Maintenance Adder = \$2000/CT/Start
- Station Service Rate = \$55.84/MWh (12 Month Average)
- Unit Specific Start Time = 0.5 Hour
- Unit Specific Soak Time = 4.5 Hours

# Combined Cycle Unit Start-Up Example



- Total Fuel Related Cost = \$4/mmBtu + \$0.10/mmBtu  
= \$4.10/mmBtu
- Start Fuel = (50mmBtu/hr \* 0.5 hr) + (120mmBtu/hr \* 1 hr) +  
(120mmBtu/hr \* 1 hr) + (170mmBtu/hr \* 0.5 hr) + (240mmBtu/hr \*  
1 hr) + (1700mmBtu/hr \* 1 hr) + (0mmBtu/hr \* 1 hr)  
= 2,290mmBtu
- Station Service = (5 MWh \* 0.5 hr) - (10MWh \* 1 hr) - (10MWh \*  
1 hr) - (15MWh \* 0.5 hr) - (25MWh \* 2 hr) - (225MWh \* 1 hr) +  
(4MWh \* 1 hr) = -271 MWh



# Combined Cycle Unit Start-Up Example – 12 Month Average

*Start – upCost (\$/Start) =*

$$\begin{aligned} & [StartFuel (MMBtu/(Start)) * TotalFuelRelatedCost (\$/MMBtu) * PerformanceFactor] \\ & + [StationService (MWh) * StationServiceRate (\$/MWh)] + StartMaintenanceAdder (\$/Start) \cdot \end{aligned}$$

- Start-Up Cost = (2,290mmBtu \* \$4.10/mmBtu \* 1.02)  
+ (-271 MWh \* \$55.84/MWh)  
+ (\$2000/Start \* 2 Starts)  
= \$-1,555.86/Start

Since Start-Up Cost cannot be less than zero  
= \$0/Start



## Combined Cycle Unit Start-Up Example – 3 Month Average

- 2 X1 Combined Cycle
- (2) 100 MW CTs
- 100 MW ST
- Fuel Cost = \$4.00
- Performance Factor = 1.20
- Allowance Cost = \$0.10/mmBtu
- Maintenance Adder = \$2000/CT/Start
- Station Service Rate = **\$24.04/MWh** (2023 Q3 3 Month Average)
- Unit Specific Start Time = 0.5 Hour
- Unit Specific Soak Time = 4.5 Hours





# Combined Cycle Unit Start-Up Example – 3 Month Average

*Start – upCost (\$/Start) =*

$$\begin{aligned} & [StartFuel (MMBtu/(Start)) * TotalFuelRelatedCost (\$/MMBtu) * PerformanceFactor] \\ & + [StationService (MWh) * StationServiceRate (\$/MWh)] + StartMaintenanceAdder (\$/Start) \cdot \end{aligned}$$

- Start-Up Cost = (2,290mmBtu \* \$4.10/mmBtu \* 1.02)  
+ (-271 MWh \* **\$24.04/MWh**)  
+ (\$2000/Start \* 2 Starts)  
= \$7,061.94/Start

CDS Chair :  
Nicole Scott ,  
[Nicole.Scott@pjm.com](mailto:Nicole.Scott@pjm.com)

CDS Secretary:  
Heather Reiter,  
[Heather.Reiter@pjm.com](mailto:Heather.Reiter@pjm.com)

Presenter/SME:  
Thomas Hauske,  
[Thomas.Hauske@pjm.com](mailto:Thomas.Hauske@pjm.com)



### Member Hotline

(610) 666 – 8980

(866) 400 – 8980

[custsvc@pjm.com](mailto:custsvc@pjm.com)