



PJM Summer Emergency Procedure Drill - Load Management

June 11, 2020

DRS

- Conducted on June 2 from 0700 to 1430
- Emergency Procedures and All Calls systems tested
 - DR Hub is not used in the drills as there is no way to distinguish between Drill and Real LM Events
- Simulated implementation of all Emergency Procedures

- Great CSP All Call acknowledgement rate
 - All CSPs with LM registrations acknowledged LM calls
 - Most of them on the first call attempt
 - This is important as acknowledgment on first call attempt avoids redials, minimizing the time to get the message out
- Some old entries on the All Call list need to be removed

- DR Hub electronic (web service) notification is PJM's primary means to deliver dispatch instructions for Load Management DR
 - CSPs should always follow instructions received from DR Hub
- Emergency Procedures website and All Call are secondary means of communication

CSPs Should Always Follow Electronic Notification Instructions