



# Duquesne Light Company 2024 Large Load Adjustment

October 2024 Load Analysis Subcommittee Meeting

# Large Load Adjustment Methodology

---

- Customers seeking to interconnect new loads or increase their loading submit a request for service to Duquesne Light.
- Duquesne Light analyzes requests for new service and develops estimates to interconnect the customer.
- Duquesne Light updates its load forecast upon commitment from the customer to proceed with the interconnection project.
- Duquesne Light submits a load adjustment to PJM for any loads that may not be captured as part of PJM's load forecasting efforts.

# Requested Adjustment

---

- Duquesne Light is requesting a 20 MW load increase for years 2026-2035.
  - The load increase is for a construction project that is expected to last approximately ten years.
  - The load is forecasted to be a constant 20 MW.



***— DUQUESNE LIGHT CO. —***