					Pag	ge 1 of 1
	Formula Rate - Non-Levelized	SFC Summary			For the 12 months ended 12/	31/2022
Lin	e (1)	(2)	(3)	(4)	(5)	
No	)					
					Total	
	1 Net Revenue Requirement with incentive projects - MP	Attachment H-11A, Page 1, Line 8, Col. 5			\$58,404,835	
	2 Net Revenue Requirement with incentive projects - PE	Attachment H-11A, Page 1, Line 8, Col. 5			\$51,499,963	
	3 Net Revenue Requirement with incentive projects - WPP	Attachment H-11A, Page 1, Line 8, Col. 5			\$51,102,052	
	4 TOTAL NET REVENUE REQUIREMENT				\$161,006,850	
	DU VAOD					
	DIVISOR				Total	
	5 1 Coincident Peak (CP) (MW)			(Note A)	8,865.0	
	6 Average 12 CPs (MW)			(Note B)	7,567.9	
			Total			
	7 Annual Rate (\$/MW/Yr)	(line 4 / line 5)	18,162.00			
			Peak Rate		Off-Peak Rate	
			Total		Total	
	8 Point-to-Point Rate (\$/MW/Year)	(line 4 / line 6)	21,274.97		21,274.97	
	9 Point-to-Point Rate (\$/MW/Month)	(line 8/12)	1,772.91		1,772.91	
	10 Point-to-Point Rate (\$/MW/Week)	(line 8/52)	409.13		409.13	
	11 Point-to-Point Rate (\$/MW/Day)	(line 10/5; line 10/7)	81.83		58.45	
	12 Point-to-Point Rate (\$/MWh)	(line 8/4,160; line 8/8,760)	5.11		2.43	

Attachment H-11A Summary

Notes

A As provided by PJM and in effect at the time of the annual rate calculations pursuant to Section 34.1 of the PJM OATT. Includes CP for the AP Zone.

B Peak as would be reported on page 401, column d of Form 1 at the time of the zonal peak for the twelve-month period ending October 31 of the calendar year used to calculate rates. The projection year will utilize the most recent preceding 12-month period at the time of the filing.

Attachment H-11A, Attachment 1 - Summary Page 1 of 1 For the 12 months ended 12/31/2022

## Schedule 1A Rate Calculation Summary

	Total
1 Transmission expenses included in OATT Ancillary Services (Attachment H-11A, Page 4, Line 7)	2,521,042
2 <u>Revenue Credits for Sched 1A - Note A</u> Attachment 1, Line 2	0
3 Net Schedule 1A Expenses (Line 1 - Line 2) Attachment 1, Line 3	\$ 2,521,042.00
4 Annual MWh in AP Zone - Note B Attachment 1, Line 4	53,609,653
5 Schedule 1A rate \$/MWh (Line 3/ Line 4) Attachment 1, Line 5	\$ 0.0470

Note:

A Revenues received pursuant to PJM Schedule 1A revenue allocation procedures for transmission service outside of AP Zone during the year used to calculate rates under Attachment H-11A

B Load expressed in MWh consistent with load used for billing under Schedule 1A for the AP Zone. Data from RTO settlement systems for the calendar year prior to the rate year.

## Transmission Enhancement Charge (TEC) Summary

	(1)	(2)	(3)
Line No.	Project Name	RTEP Project Number	Net Revenue Requirement with True-up
	·		
			(Note A)
1a	Replace Fort Martin 500 kV breaker 'FL-1'	b0577	\$39,161
14	Terminate the Powell Mountain and Goff Run lines into the new Chloe substation and perform any associated relay upgrades or modifications required at Powell Mountain and Goff run to	0011	φου, ι ο ι
1b	accommodate new substation	b2609.5	\$319,289
1c	Reconductor Doubs - Dickerson and Doubs - Aqueduct - Dickerson 230 kV to 1200MVA	b0238	\$533,171
1d	Convert Doubs - Monocacy 138kV facilities to 230kV operation - Phase 2 of b0322	b0373	\$346,406
1e	Terminal Equipment upgrade at Doubs substation	b1507.2	\$18,750
1f	Mt Storm - Doubs transmission line rebuild in Maryland - Total line mileage for APS is 2.71 miles Reconductor 14.3 miles of 556 ACSR with 795 ACSR from Old Chapel to Millville 138 kV and upgrade line risers at Old Chapel 138 kV and Millville 138 kV and replace 1200 A wave trap at	b1507.3	\$2,381,444
1g	Milville 138 kV Carroll Substation: Replace the Germantown 138 kV wave trap, upgrade the bus conductor and	b1835	\$1,908
1h	adjust CT ratios.	b2688.3	\$79,374
1i	Replace Meadow Brook 138kV breaker	b0347.17-b0347.32	\$191,361
1j	Replace the two Ringgold 230/138 kV transformers, substation, and reconductor	b2743.6, b2743.6.1, b2743.7	\$485,754
1k	Replace Ringgold Substation 138 kV breakers '138 BUS TIE' and 'RCM0' with 40 kA breakers Install a steel pole at the crossing of the Elrama to Woodville 138 kV line and the Peters to	b2743.8	\$55,836
11	Bethel Park 138 kV line	b1022.11	\$56,977
1m	Add static capacitors at South Fayette 138 kV	b1022.5	\$70,028
	Reconductor the Charleroi –Allenport 138KV Line with 954 ACSR Conductor, Replace Breaker		• • • • • • •
1n	Risers at Charleroi and Allenport Upgrade terminal equipment at Yukon to increase rating on Yukon to Charleroi #2 138 kV line	b2965	\$1,413,347
10	(New Yukon to Route 51 #4 138 kV line)	b3011.2	\$95,633
1р	Upgrade terminal equipment at Yukon to increase rating on Yukon to Route 51 #3 138 kV line Replace four Yukon 500/138 kV transformers with three transformers with higher rating and	b3011.5	\$128,333
1q	reconfigure 500 kV bus	b3006	\$13,972,519

Net Revenue Requirement with True-up is sourced from Attachment 11, Col. 15. PJM to bill each project utilizing the respective Net revenue requirement with true-up on Col. 3

Attachment H-11A, Attachment 16 - Summary Page 1 of 1 For the 12 months ended 12/31/2022

## **Abandoned Plant Summary**

(1) (2)	(3)
---------	-----

Line			
No.	Project Name (A)	<b>RTEP Project Number</b>	<b>Revenue Requirement (A)</b>
1.00			
1.01			
1.02			
1.03			
1.04			
1.05			
1.06			
1.07			
1.08			
1.09			
1.10			

## Note A

(A) Revenue Requirement is sourced from Attachment 16 Col. R. PJM to bill each project utilizing the respective Revenue Requirement reflected on Col. 3