

# Upgrades for Deans 6000 MW Injection

## General Information

Proposing entity name	NEETMH
Does the entity who is submitting this proposal intend to be the Designated Entity for this proposed project?	Yes
Company proposal ID	1A-D60
PJM Proposal ID	651
Project title	Upgrades for Deans 6000 MW Injection
Project description	Upgrades for Deans 6000 MW Injection
Email	Johnbinh.Vu@nexteraenergy.com
Project in-service date	10/2025
Tie-line impact	Yes
Interregional project	No
Is the proposer offering a binding cap on capital costs?	No
Additional benefits	

## Project Components

1. Reconductor existing Deans - Brunswick 230 kV OH line
2. Reconductor existing Windsor - Clarksville 230 kV OH line
3. Reconductor existing Gilbert - Springfield 230 kV OH line
4. Reconductor existing Pierson Avenue H - Metuchen 230 kV OH line
5. Increase Deans 500/230 Transformer (ID '3') ratings
6. Put Smithburg 500/230 kV Spare Transformer (ID '1') in service

- 7. Add 1x Phase Shifting Transformer (PST) at Aldene 230kV substation
- 8. Increase existing Linden Bergen\_4 - Bergen\_R 138 kV bus section ratings

**Transmission Line Upgrade Component**

Component title	Reconductor existing Deans - Brunswick 230 kV OH line
Project description	Reconductor existing Deans - Brunswick 230 kV OH line
Impacted transmission line	Deans - Brunswick 230 kV
Point A	Deans
Point B	Brunswick
Point C	
Terrain description	Expect to utilize existing easements/utility owned property, no expansion anticipated

**Existing Line Physical Characteristics**

Operating voltage	230
Conductor size and type	Same as existing
Hardware plan description	Utilize existing line hardware to extent practicable
Tower line characteristics	Utilize existing towers to extent practicable

**Proposed Line Characteristics**

	<b>Designed</b>	<b>Operating</b>
Voltage (kV)	230.000000	230.000000
	<b>Normal ratings</b>	<b>Emergency ratings</b>
Summer (MVA)	1322.000000	1600.000000
Winter (MVA)	1385.000000	1668.000000

Conductor size and type	2156 kcmil Bluebird ACSS/TW HS:1C
Shield wire size and type	Utilize existing shield wire to extent practicable
Rebuild line length	3.6 miles
Rebuild portion description	Proposing to reconductor the entire line (or necessary portion) to achieve the specified rating
Right of way	Use of existing ROW, no expansion anticipated
Construction responsibility	PSEG
Benefits/Comments	Resolves reliability issues identified per PJM's Gen. Deliv. Process

**Component Cost Details - In Current Year \$**

Engineering & design	Confidential competitive information
Permitting / routing / siting	Confidential competitive information
ROW / land acquisition	Confidential competitive information
Materials & equipment	Confidential competitive information
Construction & commissioning	Confidential competitive information
Construction management	Confidential competitive information
Overheads & miscellaneous costs	Confidential competitive information
Contingency	Confidential competitive information
Total component cost	\$4,680,000.00
Component cost (in-service year)	\$5,070,000.00

**Transmission Line Upgrade Component**

Component title	Reconductor existing Windsor - Clarksville 230 kV OH line
Project description	Reconductor existing Windsor - Clarksville 230 kV OH line
Impacted transmission line	Windsor to Clarksville Bus Section 1 230 kV line

Point A	Windsor
Point B	Clarksville Bus Section 1
Point C	
Terrain description	Expect to utilize existing easements/utility owned property, no expansion anticipated

**Existing Line Physical Characteristics**

Operating voltage	230
Conductor size and type	Same as existing
Hardware plan description	Utilize existing line hardware to extent practicable
Tower line characteristics	Utilize existing towers to extent practicable

**Proposed Line Characteristics**

	<b>Designed</b>	<b>Operating</b>
Voltage (kV)	230.000000	230.000000
	<b>Normal ratings</b>	<b>Emergency ratings</b>
Summer (MVA)	812.000000	975.000000
Winter (MVA)	852.000000	1020.000000
Conductor size and type	1033.5 kcmil Snowbird ACSS: 1C Bundle	
Shield wire size and type	Utilize existing shield wire to extent practicable	
Rebuild line length	7.75 miles	
Rebuild portion description	Proposing to reconductor the entire line (or necessary portion) to achieve the specified rating	
Right of way	Use of existing ROW, no expansion anticipated	
Construction responsibility	JCPL	

Benefits/Comments

Resolves reliability issues identified per PJM's Gen. Deliv. Process

**Component Cost Details - In Current Year \$**

Engineering & design

Confidential competitive information

Permitting / routing / siting

Confidential competitive information

ROW / land acquisition

Confidential competitive information

Materials & equipment

Confidential competitive information

Construction & commissioning

Confidential competitive information

Construction management

Confidential competitive information

Overheads & miscellaneous costs

Confidential competitive information

Contingency

Confidential competitive information

Total component cost

\$10,090,000.00

Component cost (in-service year)

\$10,910,000.00

**Transmission Line Upgrade Component**

Component title

Reconductor existing Gilbert - Springfield 230 kV OH line

Project description

Reconductor existing Gilbert - Springfield 230 kV OH line

Impacted transmission line

Gilbert to Springfield 230 kV line

Point A

Gilbert

Point B

Springfield

Point C

Terrain description

Expect to utilize existing easements/utility owned property, no expansion anticipated

**Existing Line Physical Characteristics**

Operating voltage

230

Conductor size and type	Same as existing
Hardware plan description	Utilize existing line hardware to extent practicable
Tower line characteristics	Utilize existing towers to extent practicable

**Proposed Line Characteristics**

	<b>Designed</b>	<b>Operating</b>
Voltage (kV)	230.000000	230.000000
	<b>Normal ratings</b>	<b>Emergency ratings</b>
Summer (MVA)	799.000000	963.000000
Winter (MVA)	837.000000	1008.000000
Conductor size and type	1033.5 kcmil Curlew ACSS HS: 1C Bundle	
Shield wire size and type	Utilize existing shield wire to extent practicable	
Rebuild line length	11.95 miles	
Rebuild portion description	Proposing to reconductor the entire line (or necessary portion) to achieve the specified rating	
Right of way	Use of existing ROW, no expansion anticipated	
Construction responsibility	JCPL	
Benefits/Comments	Resolves reliability issues identified per PJM's Gen. Deliv. Process	

**Component Cost Details - In Current Year \$**

Engineering & design	Confidential competitive information
Permitting / routing / siting	Confidential competitive information
ROW / land acquisition	Confidential competitive information
Materials & equipment	Confidential competitive information

Construction & commissioning	Confidential competitive information
Construction management	Confidential competitive information
Overheads & miscellaneous costs	Confidential competitive information
Contingency	Confidential competitive information
Total component cost	\$15,530,000.00
Component cost (in-service year)	\$16,810,000.00

**Transmission Line Upgrade Component**

Component title	Reconductor existing Pierson Avenue H - Metuchen 230 kV OH line
Project description	Reconductor existing Pierson Avenue H - Metuchen 230 kV OH line
Impacted transmission line	Pierson Avenue H to Metuchen 230 kV line
Point A	Pierson Avenue H
Point B	Metuchen
Point C	
Terrain description	Expect to utilize existing easements/utility owned property, no expansion anticipated

**Existing Line Physical Characteristics**

Operating voltage	230
Conductor size and type	Same as existing
Hardware plan description	Utilize existing line hardware to extent practicable
Tower line characteristics	Utilize existing towers to extent practicable

**Proposed Line Characteristics**

	<b>Designed</b>	<b>Operating</b>
Voltage (kV)	230.000000	230.000000

	<b>Normal ratings</b>	<b>Emergency ratings</b>
Summer (MVA)	937.000000	1123.000000
Winter (MVA)	982.000000	1173.000000
Conductor size and type	1272 kcmil Bittern ACSS HS: 1C Bundle	
Shield wire size and type	Utilize existing shield wire to extent practicable	
Rebuild line length	0.35 miles	
Rebuild portion description	Proposing to reconductor the entire line (or necessary portion) to achieve the specified rating	
Right of way	Use of existing ROW, no expansion anticipated	
Construction responsibility	PSEG	
Benefits/Comments	Resolves reliability issues identified per PJM's Gen. Deliv. Process	
<b>Component Cost Details - In Current Year \$</b>		
Engineering & design	Confidential competitive information	
Permitting / routing / siting	Confidential competitive information	
ROW / land acquisition	Confidential competitive information	
Materials & equipment	Confidential competitive information	
Construction & commissioning	Confidential competitive information	
Construction management	Confidential competitive information	
Overheads & miscellaneous costs	Confidential competitive information	
Contingency	Confidential competitive information	
Total component cost	\$1,000,000.00	
Component cost (in-service year)	\$1,080,000.00	



## Substation Upgrade Component

Component title	Increase Deans 500/230 Transformer (ID '3') ratings
Project description	Increase Deans 500/230 Transformer (ID '3')
Substation name	Deans 500/230 kV
Substation zone	PSEG
Substation upgrade scope	Increase Deans 500/230 Transformer (ID '3') to following ratings : Summer Normal :987 MVA Summer Emergency : 1370 MVA

## Transformer Information

	Name	Capacity (MVA)	
Transformer	Increase Deans 500/230 Transformer (ID '3') ratings	987	
	<b>High Side</b>	<b>Low Side</b>	<b>Tertiary</b>
Voltage (kV)	500	230	
New equipment description	AC Substation : Transformer		
Substation assumptions	Transformer upgrade is feasible		
Real-estate description	No expansion of substation fence anticipated		
Construction responsibility	PSEG		
Benefits/Comments	Resolves reliability issues identified per PJM's Gen. Deliv. Process		
<b>Component Cost Details - In Current Year \$</b>			
Engineering & design	Confidential competitive information		
Permitting / routing / siting	Confidential competitive information		
ROW / land acquisition	Confidential competitive information		
Materials & equipment	Confidential competitive information		

Construction & commissioning	Confidential competitive information
Construction management	Confidential competitive information
Overheads & miscellaneous costs	Confidential competitive information
Contingency	Confidential competitive information
Total component cost	\$8,360,000.00
Component cost (in-service year)	\$9,060,000.00

### Substation Upgrade Component

Component title	Put Smithburg 500/230 kV Spare Transformer (ID '1') in service
Project description	Put Smithburg 500/230 kV Spare Transformer (ID '1') in service
Substation name	Smithburg 500/230 kV
Substation zone	JCPL
Substation upgrade scope	Put Smithburg 500/230 kV Spare Transformer (ID '1') in service

### Transformer Information

	Capacity (MVA)			
	Name	High Side	Low Side	Tertiary
Transformer	Put Smithburg 500/230 kV Spare Transformer (ID '1') in service			
Voltage (kV)		500	230	
New equipment description	AC Substation : Transformer			
Substation assumptions	Transformer upgrade is feasible			
Real-estate description	No expansion of substation fence anticipated			
Construction responsibility	JCPL			

Benefits/Comments

Resolves reliability issues identified per PJM's Gen. Deliv. Process

**Component Cost Details - In Current Year \$**

Engineering & design

Confidential competitive information

Permitting / routing / siting

Confidential competitive information

ROW / land acquisition

Confidential competitive information

Materials & equipment

Confidential competitive information

Construction & commissioning

Confidential competitive information

Construction management

Confidential competitive information

Overheads & miscellaneous costs

Confidential competitive information

Contingency

Confidential competitive information

Total component cost

\$11,510,000.00

Component cost (in-service year)

\$12,450,000.00

**Substation Upgrade Component**

Component title

Add 1x Phase Shifting Transformer (PST) at Aldene 230kV substation

Project description

Add 1x Phase Shifting Transformer (PST) at Aldene substation in series with Aldene-Springfield Road 230 kV Bus Section 2

Substation name

Aldene 230 kV

Substation zone

PSEG

Substation upgrade scope

Add 1x Phase Shifting Transformers at Aldene substation in series with Aldene-Springfield Road 230 kV Bus Section 2

**Transformer Information**

**Name**

**Capacity (MVA)**

Transformer	Aldene 230 kV PST	766	
	<b>High Side</b>	<b>Low Side</b>	<b>Tertiary</b>
Voltage (kV)	230	230	
New equipment description	AC Substation : Phase Shifter		
Substation assumptions	Use available space in substation to add phase shifting transformer		
Real-estate description	No expansion of substation fence anticipated		
Construction responsibility	PSEG		
Benefits/Comments	Resolves reliability issues identified per PJM's Gen. Deliv. Process		
<b>Component Cost Details - In Current Year \$</b>			
Engineering & design	Confidential competitive information		
Permitting / routing / siting	Confidential competitive information		
ROW / land acquisition	Confidential competitive information		
Materials & equipment	Confidential competitive information		
Construction & commissioning	Confidential competitive information		
Construction management	Confidential competitive information		
Overheads & miscellaneous costs	Confidential competitive information		
Contingency	Confidential competitive information		
Total component cost	\$2,500,000.00		
Component cost (in-service year)	\$2,710,000.00		
<b>Substation Upgrade Component</b>			
Component title	Increase existing Linden Bergen_4 - Bergen_R 138 kV bus section ratings		

Project description	Increase existing Linden Bergen_4 - Bergen_R 138 kV bus sections
Substation name	Bergen 138 kV
Substation zone	PSEG
Substation upgrade scope	Upgrade the bus section or the line to obtain the desired rating

**Transformer Information**

Transformer	Increase existing Linden Bergen_4 - Bergen_R 138 kV bus section ratings		
	<b>Name</b>	<b>Capacity (MVA)</b>	
		<b>High Side</b>	<b>Low Side</b>
			<b>Tertiary</b>
Voltage (kV)	138	138	
New equipment description	AC Substation : Busbar		
Substation assumptions	Upgrade of bus section and desired line is feasible		
Real-estate description	No expansion of substation fence anticipated		
Construction responsibility	PSEG		
Benefits/Comments	Resolves reliability issues identified per PJM's Gen. Deliv. Process		

**Component Cost Details - In Current Year \$**

Engineering & design	Confidential competitive information
Permitting / routing / siting	Confidential competitive information
ROW / land acquisition	Confidential competitive information
Materials & equipment	Confidential competitive information
Construction & commissioning	Confidential competitive information
Construction management	Confidential competitive information

Overheads & miscellaneous costs

Confidential competitive information

Contingency

Confidential competitive information

Total component cost

\$3,000,000.00

Component cost (in-service year)

\$3,250,000.00

## **Congestion Drivers**

None

## **Existing Flowgates**

None

## **New Flowgates**

None

## **Financial Information**

Capital spend start date

12/2022

Construction start date

12/2022

Project Duration (In Months)

34

## **Additional Comments**

None