Line #2141 Lakeview to Carolina 230 kV Rebuild

General Information

Proposing entity name

Does the entity who is submitting this proposal intend to be the Designated Entity for this proposed project?

Company proposal ID

PJM Proposal ID

Project title

Project description

Email

Project in-service date

Tie-line impact

Interregional project

Is the proposer offering a binding cap on capital costs?

Additional benefits

Project Components

- 1. Line #2141 (Lakeview to Carolina)
- 2. Lakeview Substation
- 3. Carolina Substation

Transmission Line Upgrade Component

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

414

Line #2141 Lakeview to Carolina 230 kV Rebuild

This proposal increases the ampacity of Line 2141 between Lakeview and Carolina to a summer rating of 1047 MVA by reconductoring the line. This project partially overlaps with Supplemental project DOM-2021-0025 presented during the 06/08/2021 TEAC meeting.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

06/2026

No

No

No

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Component title

Line #2141 (Lakeview to Carolina)

Project description

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Impacted transmission line

Line #2141 - Lakeview to Carolina

Point A

Lakeview

Point B

Carolina

Point C

Terrain description

Starting at Lakeview Substation located in Halifax County and just southeast of Roanoke Rapids Lake, the terrain of the existing right-of-way (ROW) varies in slope and is maintained open space. The adjacent properties to the north are forested and to the south are predominately residential. The span between 2141/61 and 2141/62 aerially crosses an unnamed pond/lake. The terrain remains gently rolling and open as it heads east toward Carolina Substation.

Existing Line Physical Characteristics

Operating voltage

Conductor size and type

Hardware plan description

Tower line characteristics

230

Designed

795 ACSR (45/7) 90 Deg C MOT, and 1033.5 ACSR (45/7) 90 Deg C MOT

Operating

All line hardware will be replaced.

The existing structures were installed in 1967. Repairs to the structures are not needed; however, some structures will be modified as described in the "Rebuild portion description" below.

Proposed Line Characteristics

Voltage (kV) 230.000000 230.000000

> **Normal ratings Emergency ratings**

Summer (MVA) 1047.000000 1047.000000

Winter (MVA) 1160.000000 1160.000000

2-636 ACSR (24/7) 150 Deg C Conductor size and type

Shield wire size and type

Rebuild line length

Rebuild portion description

Right of way

Construction responsibility

Benefits/Comments

Component Cost Details - In Current Year \$

Engineering & design

Permitting / routing / siting

N/A

1.37

FACILITIES TO BE REMOVED: 1. Remove (1) span (approximately 0.1 miles) of 3 phase 1033 ACSR 45/7 - "Ortolan" conductor from Lakeview Substation (Structure 2141/1) to Structure 2141/2. 2. Remove approximately 1.3 miles of 3 phase 795 ACSR 45/7 - "Tern" conductor from Structure 2141/2 to Carolina Substation (Structure 2141/13). 3. Remove insulator hardware from Structure 2141/1 to Structure 2141/13 associated with the phase conductor being removed. This will consist of removing approximately: a. (12) suspension insulator assemblies a. (14) idler suspension assemblies b. (2) suspension training insulator assemblies c. (48) dead-end insulator assemblies FACILITIES TO BE INSTALLED: 1. Modify (5) existing T0415003 dead end towers to accommodate proposed conductor; modifications included in this estimate are for the installation of dead-end conductor assemblies and replacement of failing angle members. a. Tower modifications will need to be completed on Structure 2141/2 (4V Tower + 15' Leg Extension), 2141/5 (4V Tower + 10' Leg Extension), 2141/7 (4V Tower + 15' Leg Extension), and 2141/9 (4V Tower + 15' Leg Extension), b. Install thirty (30) DE Insulator Assemblies, c. Install fourteen (14) idler suspension assemblies. 2. Modify (4) existing T0412019 suspension towers to accommodate proposed conductor; modifications included in this estimate are for the installation of suspension conductor assemblies. a. Install twelve (12) suspension insulator assemblies. 3. Modify (2) existing backbone structures to accommodate proposed conductor; modifications included in this estimate are for the installation of suspension conductor assemblies. a. Three (3) dead-end insulator crossing assemblies on structure 2141/1. b. Six (6) dead-end insulator crossing assemblies on structure 2141/12. 4. Modify (1) existing monopole structure to accommodate proposed conductor; modifications included in this estimate are for the installation of dead-end conductor assemblies. a. Install three (3) dead-end insulator assemblies. b. Install three (3) dead-end insulator crossing assemblies. c. Install three (3) suspension training insulator assemblies. 5. Modify (1) existing switch tower to accommodate proposed conductor; modifications included in this estimate are for the installation of dead conductor assemblies. a. Install three (3) dead-end insulator assemblies. 6. Install approximately 1.4 miles of bundled 3-phase 636 ACSR 24/7 "Rook" from existing Carolina Substation (Structure 2141/13).

No new ROW is needed.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

ROW / land acquisition

Materials & equipment

Construction & commissioning

Construction management

Overheads & miscellaneous costs

Contingency

Total component cost

Component cost (in-service year)

Substation Upgrade Component

Component title

Project description

Substation name

Substation zone

Substation upgrade scope

Transformer Information

None

New equipment description

Substation assumptions

Real-estate description

Construction responsibility

Benefits/Comments

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

\$802,912.00

\$859,919.00

Lakeview Substation

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Lakeview

362

Purchase and install: 1. Install riser conductors. 2. Two (2) 230 kV, 3000A Center Break Switches. 3. Connectors on both ends of the risers along with spacers. 4. Miscellaneous conductors, connectors, insulators, and grounding materials as per engineering standards.

Two (2) 230 kV, 3000A Center Break Switches

No relay material will be needed for this portion of the project.

Lakeview substation will not need to be expanded for this project.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

2021-W1-414 4

Component Cost Details - In Current Year \$

Engineering & design

Permitting / routing / siting

ROW / land acquisition

Materials & equipment

Construction & commissioning

Construction management

Overheads & miscellaneous costs

Contingency

Total component cost

Component cost (in-service year)

Substation Upgrade Component

Component title

Project description

Substation name

Substation zone

Substation upgrade scope

Transformer Information

None

New equipment description

Substation assumptions

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

\$253,931.00

\$271,959.00

Carolina Substation

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Carolina Substation

362

Purchase and install: 1. Install riser conductors. 2. Connectors on both ends of the risers along with spacers. 3. Miscellaneous conductors, connectors, insulators, and grounding materials as per engineering standards.

No new substation equipment will be installed for this project.

No relay material will be needed for this portion of the project.

2021-W1-414 5

Real-estate description

Construction responsibility

Benefits/Comments

Component Cost Details - In Current Year \$

Engineering & design

Permitting / routing / siting

ROW / land acquisition

Materials & equipment

Construction & commissioning

Construction management

Overheads & miscellaneous costs

Contingency

Total component cost

Component cost (in-service year)

Congestion Drivers

None

Existing Flowgates

Carolina substation will not need to be expanded for this project.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

\$127,840.00

\$136,917.00

FG#	From Bus No.	From Bus Name	To Bus No.	To Bus Name	СКТ	Voltage	TO Zone	Analysis type	Status
GD-S19	314583	6LAKEVEW	314561	6CAROLNA	1	230	345	Summer Gen Deliv	Included

New Flowgates

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Financial Information

Capital spend start date 06/2025

Construction start date 01/2026

Project Duration (In Months) 12

Additional Comments

Contact info: for Technical: ETAreaPlanning@dominionenergy.com; for Fees/Financial: Dane.Jonas@dominionenergy.com

2021-W1-414 7