

Data Center Reinforcement Proposal #2

General Information

Proposing entity name	Company specific
Does the entity who is submitting this proposal intend to be the Designated Entity for this proposed project?	Yes
Company proposal ID	2022-W3-23
PJM Proposal ID	23
Project title	Data Center Reinforcement Proposal #2
Project description	<p>This proposal incorporates construction of multiple transmission lines and substation expansions to provide a robust, expandable transmission solution to address the 2022 Open Window 3 violations. This proposal will also ensure the PJM transmission system can safely and reliably accommodate future load growth. NOTE: The proposing entity has worked closely with other PJM TOs in developing a transmission solution and this proposal should be reviewed in conjunction with proposal 2022-W3-129 and proposal 2023-W3-660. Subsequent to execution of the DEA for one or more of these projects, the proposing entity may file application with the FERC for award of the CWIP and abandonment transmission rate incentives that are typical for projects of this size.</p>
Email	Company specific
Project in-service date	06/2030
Tie-line impact	Yes
Interregional project	No
Is the proposer offering a binding cap on capital costs?	No
Additional benefits	<p>The proposed solution is a robust and expandable solution. The proposal will place new transmission facilities in proximity to existing transmission infrastructure which will provide opportunities to improve the reliability and resilience of the transmission system as the transmission system changes. Historic reliability and congestion issues on the transmission system such as the Black Oak-Bedington interface and the AP South interface could be addressed with smaller additions or expansions to the transmission facilities proposed in this submittal.</p>

Project Components

1. Doubs Substation - Install 500 kV Breaker
2. Doubs Substation - Expand 500 kV Switchyard
3. Meadow Brook Substation - Expand 500 kV Switchyard
4. Fort Martin Substation - Install 500 kV Breaker
5. Pruntytown Substation - Expand 500 kV Switchyard
6. Bedington Substation - Rebuild & Install 600 MVAR STATCOM
7. Fort Martin - Doubs 500 kV #1 Line
8. Meadow Brook - Doubs 500 kV Line
9. Meadow Brook - Pruntytown 500 kV Line
10. Black Oak Substation - Install Redundant Relaying
11. Reid Substation - Install Redundant Relaying
12. Pruntytown - Install Redundant Relaying
13. Junction - Install Redundant Relaying
14. Doubs 500 kV - Overduty Breaker Replacements
15. Pruntytown - Rebuild 138 kV Switchyard Due to Over Duty Breakers
16. Doubs - Goose Creek 500 kV Rebuild
17. Doubs - Aspen 500 kV Line
18. Rebuild the Germantown - Carroll 138 kV Line to 230 kV double circuit construction
19. Taneytown Substation terminal upgrade
20. Carroll 230 kV Substation Expansion
21. Rebuild the Germantown - Lincoln 115 kV Line for 230 kV double circuit construction
22. Rebuild the Hunterstown- Lincoln 115 kV Line for 230 kV double circuit construction
23. Construct New 230 kV Hunterstown - Carroll Line (MAIT section)
24. Rebuild the Germantown - Carroll 138 kV Line for 230 kV double circuit construction (MAIT)
25. Revise Relay Settings at Germantown Substation
26. Install new 230 kV line terminal at Hunterstown Substation
27. Revise Relay Settings at Lincoln Substation

- 28. Install DTT relaying at Straban Substation
- 29. Network Upgrades at Carroll Substation
- 30. Construct New 230 kV Hunterstown - Carroll Line (APS-PE section)
- 31. Fort Martin Substation - Expand 500 kV
- 32. Fort Martin - Doubs 500 kV #2 Line

Substation Upgrade Component

Component title	Doubs Substation - Install 500 kV Breaker
Project description	Install one 500 kV Breaker, relaying, and associated equipment at Doubs Substation.
Substation name	Doubs (235105)
Substation zone	APS (Area 201, Zone 1203)
Substation upgrade scope	- Install foundation, conduit, and grounding for new equipment. - Install (1) 500 kV circuit breaker. - Install (2) 500 kV GOAB disconnect switches. - Install (1) 500 kV MOAB disconnect switch. - Install (3) 500 kV CVTs. - Install (3) 500 kV surge arresters. - Install (1) lot of steel structures, cables, and grounding for new equipment. - Install (1) line relay panel. - Install (1) breaker control panel. - Install (1) lot of control cables. - Relay Revisions at Doubs Substation.

Transformer Information

None	
New equipment description	The new 500 kV breaker, terminal equipment, and relaying will be rated at 5000 A or higher.
Substation assumptions	- It is assumed that the control house has adequate space. - It is assumed that the existing substation bay can be utilized without expanding Doubs Substation and without rebuilding and bus work.
Real-estate description	Land acquisition and substation fence expansion are not required.
Construction responsibility	Company specific
Benefits/Comments	This 500 kV breaker installation will allow two new lines to be terminated at Doubs substation without expanding the fence of Doubs Substation. Doubs Substation is an important interface with the Dominion Zone, so additional power flow through Doubs Substation is a reliability benefit to the EHV system.

Component Cost Details - In Current Year \$

Engineering & design	This information is considered confidential and proprietary
Permitting / routing / siting	This information is considered confidential and proprietary
ROW / land acquisition	This information is considered confidential and proprietary
Materials & equipment	This information is considered confidential and proprietary
Construction & commissioning	This information is considered confidential and proprietary
Construction management	This information is considered confidential and proprietary
Overheads & miscellaneous costs	This information is considered confidential and proprietary
Contingency	This information is considered confidential and proprietary
Total component cost	\$4,719,889.00
Component cost (in-service year)	\$5,426,954.00

Substation Upgrade Component

Component title	Doubs Substation - Expand 500 kV Switchyard
Project description	Expand the Doubs 500 kV substation by constructing an additional three-breaker, 500 kV string to accommodate the termination of two additional 500 kV lines. This will require the 500 kV Buses A & B to be extended, a fence expansion, and relay installations. No land acquisition is required. This upgrade will be required if Component 7 (Fort Martin - Doubs 500 kV Line) is constructed.
Substation name	Doubs (235105)
Substation zone	APS (Area 201, Zone 1203)
Substation upgrade scope	- Install foundation, conduit, trench, and grounding for new equipment. - Install fencing, stoning, and ground grid for substation expansion. - Install (3) 500 kV, 5000 A circuit breakers. - Install (6) 500 kV CVTs. - Install (6) 500 kV surge arresters. - Install (6) 500 kV, 5000 A GOAB disconnect switches. - Install (2) 500 kV, 5000 A MOAB disconnect switches. - Install (2) 500 kV H-frames. - Install (2) breaker control panels. - Install (2) line relay panels. - Install (1) bus diff panel. - Wetland mitigation.

Transformer Information

None	
New equipment description	All new equipment to be rated at 5000 A or higher.
Substation assumptions	- There is adequate space in the existing control house for the new panels. - Land does not need to be purchased. Expansion is on existing substation property. - Conductor shall be installed in triple cable jumper.
Real-estate description	Doubs 500 kV substation will require a fence expansion, but no property acquisition is required. There are forested wetlands to the west, where the expansion is currently proposed. The expansion will require wetland mitigation such as stream enclosure or relocation. The terrain is hilly.
Construction responsibility	Company specific
Benefits/Comments	This 500 kV substation expansion will allow an additional two 500 kV lines to be terminated at Doubs Substation. Doubs Substation is an interface with the Dominion territory, so this substation is critical for power transfer to the Dominion Zone.

Component Cost Details - In Current Year \$

Engineering & design	This information is considered confidential and proprietary
Permitting / routing / siting	This information is considered confidential and proprietary
ROW / land acquisition	This information is considered confidential and proprietary
Materials & equipment	This information is considered confidential and proprietary
Construction & commissioning	This information is considered confidential and proprietary
Construction management	This information is considered confidential and proprietary
Overheads & miscellaneous costs	This information is considered confidential and proprietary
Contingency	This information is considered confidential and proprietary
Total component cost	\$14,436,447.00
Component cost (in-service year)	\$16,594,016.00

Substation Upgrade Component

Component title	Meadow Brook Substation - Expand 500 kV Switchyard
Project description	Expand the Meadow Brook 500 kV substation by extending the 500 kV bus and adding a new line terminal to accommodate the termination of a new 500 kV line. This upgrade will be required if one or more new 500 kV lines terminate at Meadow Brook Substation.
Substation name	Meadow Brook (235110)
Substation zone	APS (Area 201, Zone 1203)
Substation upgrade scope	- Install grounding, conduit & foundations for substation expansion. - Install new cable trench, and tie into existing trench. - (1) A-frame dead-ends - (2) 500 kV breakers - (4) 500 kV breaker disconnect switches - (1) 500 kV line disconnect switch - (1) set of 500 kV arresters - (1) sets of 500 kV CVT's - Expand the Meadow Brook Substation fence - (2) Breaker control panels - (1) Line relaying panel - (1) Bus Differential - Revise relay settings at Meadow Brook Substation

Transformer Information

None	
New equipment description	All new equipment to be rated at 5000 A or higher.
Substation assumptions	- There is adequate space in the existing control house for the new panels. - Land does not need to be purchased. Expansion is on existing substation property. - Bus protection will be installed for future line position - Existing SCADA transport at Meadow Brook Substation is sufficient for additional SCADA telemetry.
Real-estate description	Meadow Brook 500 kV Substation will require a fence expansion, but no property acquisition is required. No wetlands or environmental risks were identified at this time.
Construction responsibility	Company specific
Benefits/Comments	This 500 kV substation expansion will allow an additional 500 kV line to be terminated at Meadow Brook Substation. Meadow Brook Substation is an interface with the Dominion zone, so this substation is critical for power transfer into and out of the Dominion Zone.

Component Cost Details - In Current Year \$

Engineering & design	This information is considered confidential and proprietary
Permitting / routing / siting	This information is considered confidential and proprietary

ROW / land acquisition	This information is considered confidential and proprietary
Materials & equipment	This information is considered confidential and proprietary
Construction & commissioning	This information is considered confidential and proprietary
Construction management	This information is considered confidential and proprietary
Overheads & miscellaneous costs	This information is considered confidential and proprietary
Contingency	This information is considered confidential and proprietary
Total component cost	\$16,547,994.00
Component cost (in-service year)	\$19,197,920.00

Substation Upgrade Component

Component title	Fort Martin Substation - Install 500 kV Breaker
Project description	Install one 500 kV Breaker, relaying, and associated equipment at Fort Martin Substation. This upgrade will be required if one or more new 500 kV Lines terminate at Fort Martin Substation (Component 7: Fort Martin - Doubs 500 kV Line).
Substation name	Fort Martin (235106)
Substation zone	APS (Area 201, Zone 1201)
Substation upgrade scope	- Install foundation, conduit, and grounding for new equipment. - Install conduit for fiber. - Install (1) 500 kV circuit breaker. - Install (2) 500 kV GOAB disconnect switches. - Install (1) 500 kV MOAB disconnect switch. - Install (3) 500 kV CVTs. - Install (3) 500 kV surge arresters. - Install (1) 500 kV H-frame. - Install (1) lot of steel structures, cables, rigid bus, and grounding for new equipment. - Install (1) line relay panel. - Install (1) lot of control cables.

Transformer Information

None	
New equipment description	New equipment to be rated at 5000 A or higher.
Substation assumptions	It is assumed that the existing substation bay can be utilized without expanding Fort Martin Substation.

Real-estate description	Land acquisition and substation fence expansion are not required.
Construction responsibility	Company specific
Benefits/Comments	This 500 kV breaker installation will allow a new line to be terminated at Fort Martin Substation without expanding the fence. Fort Martin Substation provides a strong source for transferring power from the west to the east.

Component Cost Details - In Current Year \$

Engineering & design	This information is considered confidential and proprietary
Permitting / routing / siting	This information is considered confidential and proprietary
ROW / land acquisition	This information is considered confidential and proprietary
Materials & equipment	This information is considered confidential and proprietary
Construction & commissioning	This information is considered confidential and proprietary
Construction management	This information is considered confidential and proprietary
Overheads & miscellaneous costs	This information is considered confidential and proprietary
Contingency	This information is considered confidential and proprietary
Total component cost	\$6,013,770.00
Component cost (in-service year)	\$6,924,500.00

Substation Upgrade Component

Component title	Pruntytown Substation - Expand 500 kV Switchyard
Project description	Expand the Pruntytown 500 kV substation by installing a new three-breaker cross bus with three 500 kV breakers to accommodate the termination of a new 500 kV line. This upgrade will be required for a new 500 kV line terminal at Pruntytown Substation (Component 9: Pruntytown - Meadow Brook 500 kV Line).
Substation name	Pruntytown (235112)
Substation zone	APS (Area 201, Zone 1201)

Substation upgrade scope

At Pruntytown Substation: - Install grounding, conduit & foundations for substation expansion. - Install new cable trench, and tie into existing trench. - (5) H-frame deadends - (4) 500 kV breakers - (8) 500 kV breaker disconnect switches - (4) 500 kV line disconnect switches - (4) sets of 500 kV arresters - (6) sets of 500 kV CVT's - Fence expansion - Install (2) breaker control panels. - Install (5) line relaying panels. - Install (1) bus protection panel. - Install (2) 3-pole dead-end structures and (0.2) miles of new conductor for the Mount Storm-Pruntytown 500 kV Line re-termination.

Transformer Information

None

New equipment description

All new equipment to be rated 5000 A or higher.

Substation assumptions

Pruntytown Substation Assumptions: - Existing poles for future dead-end locations are still able to be utilized. - There is adequate space in the existing control house for the new panels. - Transformer protection will not be updated. - Expansion would require wetland mitigation such as stream enclosure or relocation - The new conductor will match the existing conductor. - Assumed no E&S measures to be installed by ROW Clearing Contractor. - No time-of-year clearing restrictions. - No site restoration activities performed by clearing contractor. - No maintenance efforts will be absorbed by the project. - All construction work areas are located within the ROW. - Some clearing may be required. - Permit conditions, Real Estate Provisions for Property Owners, finalized line route, information on access road needs and schedules, restoration requirements requested of vegetation management, ability to work without schedule conflicts with other vendors, access road design outside of the ROW, all rights and permits will be in-hand upon mobilization. - A rights and restrictions review by Real Estate will be required. - Georeferenced ROW extents will be required to be provided to engineering. - Road Bonds are required.

Real-estate description

Pruntytown 500 kV Substation will require a fence expansion, but no property acquisition is required. The expansion will require wetland mitigation such as stream enclosure or relocation. The terrain is hilly. Real estate dollars have been included for: - Internal support including document review, project planning meetings, subcontractor oversight. - External support for easement digitization and other GIS support, general project support, and acquisition of 1 access road and 1 yard.

Construction responsibility

Company specific

Benefits/Comments

Pruntytown Substation is an interface with the Dominion Zone and is also a strong source for network power flow to the east.

Component Cost Details - In Current Year \$

Engineering & design

This information is considered confidential and proprietary

Permitting / routing / siting

This information is considered confidential and proprietary

ROW / land acquisition	This information is considered confidential and proprietary
Materials & equipment	This information is considered confidential and proprietary
Construction & commissioning	This information is considered confidential and proprietary
Construction management	This information is considered confidential and proprietary
Overheads & miscellaneous costs	This information is considered confidential and proprietary
Contingency	This information is considered confidential and proprietary
Total component cost	\$28,211,763.00
Component cost (in-service year)	\$32,210,363.00

Substation Upgrade Component

Component title	Bedington Substation - Rebuild & Install 600 MVAR STATCOM
Project description	Rebuild Bedington 500 kV Substation to a 12-breaker, breaker-and-a-half configuration and install a 600 MVAR STATCOM. This includes the relocation and re-termination of the Doubs - Black Oak & Doubs - Bedington 500 kV lines.
Substation name	Bedington (235101)
Substation zone	APS (Area 201, Zone 1203)
Substation upgrade scope	- Demolish and remove existing 500 kV equipment, including but not limited to: (2) wave traps, (4) circuit breakers, (14) MOAB disconnect switches, (9) CVTs, (1 lot) of steel structures, (4) grounding switches. - Expand the Bedington substation fence. - Rebuild Bedington 500 kV substation to a 12-breaker, breaker-and-a-half configuration - Install a 600 MVAR STATCOM - Re-locate and re-terminate the Bedington - Black Oak & Bedington - Doubs 500 kV Lines.

Transformer Information

None	
New equipment description	All new equipment to be rated at 5000 A or higher.

Substation assumptions	Bedington Substation Assumptions: - There is adequate space in the existing control house for the new panels. - Land does not need to be purchase. Expansion is on existing substation property. - Expansion may require wetland mitigation such as stream enclosure or relocation. - No new metering needed for 500 kV lines - No new metering is required for the 138 kV lines - Assumed that the existing SCADA transport at Bedington 500kV Substation is sufficient for additional SCADA telemetry.
Real-estate description	Bedington 500 kV Substation will require a fence expansion, but no property acquisition is required. There is a stream channel to the west of the sub, where the expansion is currently proposed. Wetland mitigation may be required.
Construction responsibility	Company specific
Benefits/Comments	The rebuild of Bedington Substation and installation of a STATCOM will provide significant reactive support for the Hatfield - Black Oak - Bedington - Doubs 500 kV path. The loss of this path results in no-solves and voltage collapse issues from P1 contingencies in the power flow model. The rebuild of the 500 kV switchyard will also provide for additional 500 kV expansion, providing great support and power flow through that corridor.

Component Cost Details - In Current Year \$

Engineering & design	This information is considered confidential and proprietary
Permitting / routing / siting	This information is considered confidential and proprietary
ROW / land acquisition	This information is considered confidential and proprietary
Materials & equipment	This information is considered confidential and proprietary
Construction & commissioning	This information is considered confidential and proprietary
Construction management	This information is considered confidential and proprietary
Overheads & miscellaneous costs	This information is considered confidential and proprietary
Contingency	This information is considered confidential and proprietary
Total component cost	\$131,384,996.00
Component cost (in-service year)	\$153,799,133.00

Greenfield Transmission Line Component

Component title	Fort Martin - Doubs 500 kV #1 Line	
Project description	Construct ~158 miles of new 500 kV line from Fort Martin Substation to Doubs Substation. Terminate the new transmission line and revise relay settings at Doubs and Fort Martin substations. Install fiber OPGW along the new line route. The construction of this new line will require the acquisition of 158 miles of new right-of-way, forestry clearing, permitting, and access road construction. Re-terminate the Bismark 500 kV Line at Doubs Substation. Aerial LiDAR will be required. This new transmission line will require Proposal Components 1 (Doubs Substation - Install 500 kV Breaker), 2 (Doubs Substation - Expand 500 kV), and 4 (Fort Martin Substation - Install 500 kV Breaker) to be completed. Note: total cost of Proposal Component 7 is included in Proposal Component 32.	
Point A	Fort Martin (235106)	
Point B	Doubs (235105)	
Point C		
	Normal ratings	Emergency ratings
Summer (MVA)	4625.000000	5670.000000
Winter (MVA)	5252.000000	6724.000000
Conductor size and type	3x 1590 KCMIL 45/7 ACSR rated at 212°F	
Nominal voltage	AC	
Nominal voltage	500	
Line construction type	Overhead	
General route description	- This new 500 kV line will be constructed in West Virginia, Virginia, and Maryland. Full Applications will be required in each state. - It is assumed that the new 500 kV line will parallel existing ROW for approximately (85.6) miles and require (74.4) miles of new ROW not adjacent to existing ROW. It is assumed that no existing lines will be overbuilt with double circuit structures, but existing line rebuilds will be considered where applicable. - Approximately (695) parcels will be affected by the line route. Assumed 5% condemnation (35 parcels).	
Terrain description	- The terrain for this line is hilly/mountainous with state lands, national parks, and rivers along the proposed route of this new line. Traditional access and construction may be affected. Alternative access and construction methods will be considered.	

Right-of-way width by segment	- The right-of-way width is assumed to be 200 ft. This width is based on the widest ROW needed for 500 kV and does not account for structure configuration or span lengths. Widths needed may vary upon final design.
Electrical transmission infrastructure crossings	See information below. Each crossing will not be listed as the route is subject to change.
Civil infrastructure/major waterway facility crossing plan	- The new 500 kV line will cross (23) major roads. Traffic control and flagging will be required. - The new 500 kV line will cross (4) CSX Railroads, (1) Norfolk Southern Railroad, and parallels railroad ROW for (3.2) miles. Crossing permits and flagging will be required. - The new 500 kV line will cross (14) rivers or other bodies of water. Crossing permits and FAA coordination may be required. - The new 500 kV line crosses through (9) wetlands and (5) parks. Environmental considerations and special coordination may be required. - The new 500 kV line will cross (2) 500kV, (25) 138kV, (1) 115kV, and (9) 34.5kV transmission lines multiple times. - Crosses DNR owned land in WV/MD/VA. Licensing and permitting of new ROW with either state's DNR could take 24 months and may need to be approved by the state's legislature. - Crosses the Youghiogheny River, a state designated scenic river. Permitting of new ROW over a scenic river is estimated to be 12-18 months. - Crossing of large wetland complexes in WV and MD could result in lengthier permitting 12-18 months and increased mitigation cost. - Crosses C&O Canal National Park. Licensing and permitting of new ROW with National Park Service could take 24 months to complete.
Environmental impacts	- The new 500 kV line will cross (14) rivers or other bodies of water. Crossing permits and FAA coordination may be required. - The new 500 kV line crosses through (9) wetlands and (5) parks. Environmental considerations and special coordination may be required. - Crosses DNR owned land in WV/MD/VA. Licensing and permitting of new ROW with either state's DNR could take 24 months and may need to be approved by the state's legislature. - Crosses the Youghiogheny River, a state designated scenic river. Permitting of new ROW over a scenic river is estimated to be 12-18 months. - Crossing of large wetland complexes in WV and MD could result in lengthier permitting 12-18 months and increased mitigation cost. - Crosses C&O Canal National Park. Licensing and permitting of new ROW with National Park Service could take 24 months to complete. - Road Bonds are required. - Environmental Filming (Documentation of Existing roads) is required. - Environmental Access and Road Crossing Permit Fees is required. - Environmental Development of Permit Binder is required. - Environmental Cultural Resource Consultation is required. - Environmental Construction walk down is required.
Tower characteristics	- The new Fort Martin-Doubs #1 500 kV Line will be constructed on double circuit 500 kV tubular steel monopole and two-Pole structures. The second 500 kV circuit is component 32. Component 32 has the costs for the complete double circuit construction, including this component. - The average span length is 1200 ft. - It is assumed that the new double circuit monopole structures will have an average height of 180 ft. Final structure heights will need to be determined during project development. FAA filing and application may be required. - The new structures will utilize custom 500 kV V-string and double I-string suspension and dead-end insulator assemblies.
Construction responsibility	Company specific

Benefits/Comments

- This new 500 kV line provides a direct connection from the west side of the system to the east side. - This new line provides the ability to install a second Fort Martin - Doubs 500 kV Line on the same structures, without additional right-of-way acquisition. - This new line route will provide the opportunity to loop the Fort Martin - Doubs 500 kV Line into Bedington and/or Black Oak substations in the future, if necessary for reliability or resiliency. - Greenfield construction is assumed due to outage constraints, but existing rights-of-way and corridors to rebuild lower voltage lines will be considered where applicable.

Component Cost Details - In Current Year \$

Engineering & design

This information is considered confidential and proprietary

Permitting / routing / siting

This information is considered confidential and proprietary

ROW / land acquisition

This information is considered confidential and proprietary

Materials & equipment

This information is considered confidential and proprietary

Construction & commissioning

This information is considered confidential and proprietary

Construction management

This information is considered confidential and proprietary

Overheads & miscellaneous costs

This information is considered confidential and proprietary

Contingency

This information is considered confidential and proprietary

Total component cost

\$.00

Component cost (in-service year)

\$.00

Greenfield Transmission Line Component

Component title

Meadow Brook - Doubs 500 kV Line

Project description

Construct 55.3 miles of new 500 kV line from Meadow Brook Substation to Doubs Substation. Terminate the new transmission line and revise relay settings at Doubs and Meadow Brook substations. Install fiber along the new line route. The construction of this new line will require the acquisition of 55.3 miles of new right-of-way, forestry clearing, permitting, and access road construction. Re-terminate the Meadow Brook - Loudon & Meadow Brook - Front Royal 500 kV lines at Meadow Brook Substation. Aerial LiDAR will be required. This new transmission line will require Proposal Components 1 (Doubs Substation - Install 500 kV Breaker), Component 2 (Doubs Substation - Expand 500 kV), and Component 3 (Meadow Brook Substation - Expand 500 kV) to be completed.

Point A	Meadow Brook (235110)
Point B	Doubs (235105)
Point C	

	Normal ratings	Emergency ratings
Summer (MVA)	4625.000000	5670.000000
Winter (MVA)	5252.000000	6724.000000
Conductor size and type	3x 1590 KCMIL 45/7 ACSR rated at 212°F	
Nominal voltage	AC	
Nominal voltage	500	
Line construction type	Overhead	
General route description	<p>- This new 500 kV line will be constructed in Virginia, West Virginia, and Maryland. Full Applications will be required in each state. - It is assumed that the new line will parallel existing ROW for approximately (22.8) miles and require (32.5) miles of new ROW not adjacent to existing ROW. It is assumed that no existing lines will be overbuilt with double circuit structures, but existing line rebuilds will be considered where applicable. - Approximately (146) parcels will be affected by the line route. Assumed 5% condemnation (7 parcels).</p>	
Terrain description	<p>- The terrain for this line is flat/hilly/semi-mountainous with state lands, national parks, and rivers along the proposed route of this new line.</p>	
Right-of-way width by segment	<p>- The right-of-way width is assumed to be 200 ft. This width is based on the widest ROW needed for 500 kV and does not account for structure configuration or span lengths. Widths needed can vary upon final design.</p>	
Electrical transmission infrastructure crossings	<p>See information below. Each crossing will not be listed as the route is subject to change.</p>	

Civil infrastructure/major waterway facility crossing plan	<ul style="list-style-type: none"> - The new line will cross (9) major roads. Traffic control and flagging will be required - The new line will cross (4) CSX Railroads. Crossing permits and flagging will be required. - The new line will cross (4) rivers or other bodies of water. Crossing permits and FAA coordination may be required. - The new line crosses through (5) wetlands and (3) parks. Environmental considerations and special coordination may be required. - The new line will cross (1) 500kV, (5) 138kV, and (3) 34.5kV transmission lines multiple times. - Crosses DNR state owned land in WV/VA. Licensing and permitting of new ROW on state DNR land could take 24 months and may need to be approved by the state's legislature. - Crosses the Shenandoah and Potomac rivers in sections designated as state scenic rivers. Permitting of new ROW over a scenic river is estimated to be 12-18 months. - Crosses the Appalachian Trail National Park and the C&O Canal National Park. Licensing and permitting of new ROW with National Park Service could take 24 months to complete.
Environmental impacts	<ul style="list-style-type: none"> - The new line crosses through (5) wetlands and (3) parks. Environmental considerations and special coordination may be required. - Crosses DNR state owned land in WV/VA. Licensing and permitting of new ROW on state DNR land could take 24 months and may need to be approved by the state's legislature. - Crosses the Shenandoah and Potomac rivers in sections designated as state scenic rivers. Permitting of new ROW over a scenic river is estimated to be 12-18 months. - Crosses the Appalachian Trail National Park and the C&O Canal National Park. Licensing and permitting of new ROW with National Park Service could take 24 months to complete. - Road Bonds are required. - Environmental Filming (Documentation of Existing roads) is required. - Environmental Access and Road Crossing Permit Fees is required. - Environmental Development of Permit Binder is required. - Environmental Cultural Resource Consultation is required. - Environmental Construction walk down is required.
Tower characteristics	<ul style="list-style-type: none"> - This new line will be constructed on single circuit 500 kV tubular steel monopole structures with an average span length of 1200 ft. - The new structures will utilize custom 500 kV V-string and double I-string suspension and dead-end insulator assemblies. - New single circuit structures will have an average height of 150 ft.
Construction responsibility	Company specific
Benefits/Comments	<ul style="list-style-type: none"> - This new 500 kV Line will provide an additional and much shorter electrical path between Meadow Brook and Doubs linking the Black Oak-Bedington corridor with the 'AP South' corridor. - Greenfield construction is assumed due to outage constraints, but existing rights-of-way and corridors to rebuild lower voltage lines will be considered where applicable.
Component Cost Details - In Current Year \$	
Engineering & design	This information is considered confidential and proprietary
Permitting / routing / siting	This information is considered confidential and proprietary
ROW / land acquisition	This information is considered confidential and proprietary

Materials & equipment	This information is considered confidential and proprietary
Construction & commissioning	This information is considered confidential and proprietary
Construction management	This information is considered confidential and proprietary
Overheads & miscellaneous costs	This information is considered confidential and proprietary
Contingency	This information is considered confidential and proprietary
Total component cost	\$460,601,488.00
Component cost (in-service year)	\$519,274,823.00

Greenfield Transmission Line Component

Component title	Meadow Brook - Pruntytown 500 kV Line	
Project description	Construct approximately (50.8) miles of new 500 kV line from Pruntytown Substation to Structure #5 on the Meadow Brook - Mount Storm #529 500 kV Line (located adjacent to Mt Storm Substation). Cut the existing Meadow Brook - Mount Storm #529 500 kV Line from the Mt. Storm line terminal and connect the new 500 kV line from Pruntytown Substation. This will eliminate the Meadow Brook - Mt Storm 500 kV Line and create the new Meadow Brook - Pruntytown 500 kV Line. Install fiber and splice into the existing Meadow Brook - Mount Storm #529 500 kV Line fiber. The construction of this new line will require the acquisition of 50.8 miles of new right-of-way, forestry clearing, permitting, and access road construction. This new transmission line will require Proposal Component 5 (Pruntytown Substation - Expand 500 kV) to be completed.	
Point A	Pruntytown (235112)	
Point B	Meadow Brook (235110)	
Point C		
	Normal ratings	Emergency ratings
Summer (MVA)	5840.000000	6730.000000
Winter (MVA)	5847.000000	7081.000000
Conductor size and type	3x 1113 KCMIL 54/19 ACSS rated at 392°F	

Nominal voltage	AC
Nominal voltage	500
Line construction type	Overhead
General route description	- This new 500 kV line will be constructed in Maryland and West Virginia. Full Applications will be required in each state. - It is assumed that the new line will parallel existing ROW for approximately (14.5) miles and require (36.3) miles of new ROW not adjacent to existing ROW. It is assumed that no existing lines will be overbuilt with double circuit structures, but existing line rebuilds will be considered where applicable. - Approximately (170) parcels will be affected by the line route. Assumed 3% condemnation (5 parcels).
Terrain description	- The terrain for this line is hilly/mountainous with state lands, national parks, and rivers along the proposed route of this new line. Traditional access and construction may be affected. Alternative access and construction may need to be considered.
Right-of-way width by segment	- The right-of-way width is assumed to be 200 ft. This width is based on the widest ROW needed for 500 kV and does not account for structure configuration or span lengths. Widths needed can vary upon final design.
Electrical transmission infrastructure crossings	See information below. Each crossing will not be listed as the route is subject to change.
Civil infrastructure/major waterway facility crossing plan	- The new Meadow Brook-Pruntytown 500 kV Line will cross (9) major roads. Traffic control and flagging will be required. - The new Meadow Brook-Pruntytown 500 kV Line will cross (3) CSX & Appalachian and Ohio Railroads. Crossing permits and flagging will be required. - The new Meadow Brook-Pruntytown 500 kV Line will cross (3) rivers or other bodies of water. Crossing permits and FAA coordination may be required. - The new Meadow Brook-Pruntytown 500 kV Line crosses through (6) wetlands and (2) parks: the Monongahela National Forest and State Park Land. Environmental considerations and special coordination may be required. Licensing and permitting of new ROW in these areas could take 24 months. - The new Meadow Brook-Pruntytown 500 kV Line will cross (2) 500kV, (4) 138kV, and (3) 34.5kV transmission lines multiple times.
Environmental impacts	- The new Meadow Brook-Pruntytown 500 kV Line will cross (3) rivers or other bodies of water. Crossing permits and FAA coordination may be required. - The new Meadow Brook-Pruntytown 500 kV Line crosses through (6) wetlands and (2) parks: the Monongahela National Forest and State Park Land. Environmental considerations and special coordination may be required. Licensing and permitting of new ROW in these areas could take 24 months. - Road Bonds are required. - Environmental Filming (Documentation of Existing roads) is required. - Environmental Access and Road Crossing Permit Fees is required. - Environmental Development of Permit Binder is required. - Environmental Cultural Resource Consultation is required. - Environmental Construction walk down is required.

Tower characteristics - This new line will be constructed on single circuit 500 kV tubular steel monopole structures with an average span length of 1200 ft. - The new structures will utilize custom 500 kV V-string and double I-string suspension and dead-end insulator assemblies. - New single circuit structures will have an average height of 150 ft.

Construction responsibility Company specific

Benefits/Comments This new transmission line will provide an additional electrical path for power to flow from Pruntytown Substation into Doubs Substation, Meadow Brook Substation, and to the Dominion Zone. This project will also provide future expansion capability with a potential to re-network the 500 kV lines emanating from Mt. Storm Substation for increased reliability benefit. - Greenfield construction is assumed due to outage constraints, but existing rights-of-way and corridors to rebuild lower voltage lines will be considered where applicable.

Component Cost Details - In Current Year \$

Engineering & design This information is considered confidential and proprietary

Permitting / routing / siting This information is considered confidential and proprietary

ROW / land acquisition This information is considered confidential and proprietary

Materials & equipment This information is considered confidential and proprietary

Construction & commissioning This information is considered confidential and proprietary

Construction management This information is considered confidential and proprietary

Overheads & miscellaneous costs This information is considered confidential and proprietary

Contingency This information is considered confidential and proprietary

Total component cost \$418,587,195.00

Component cost (in-service year) \$473,990,145.00

Substation Upgrade Component

Component title Black Oak Substation - Install Redundant Relaying

Project description Install relaying at Black Oak substation to ensure there is redundancy for 500 kV and 138 kV bus & stuck breaker faults to avoid remote-end clearing to resolve TPL-001-5 identified violations. This project will resolve all P5 contingencies at Black Oak Substation.

Substation name	Black Oak (235446)
Substation zone	APS (Area 201, Zone 1203)
Substation upgrade scope	- Extend the No 3 500/138 kV Transformer backup HU differential to the bus side of the BO3 138kV breaker to provide redundant protection for the 138 kV low side leads. - Adjust existing relaying as necessary at Black Oak Substation. - Testing and commissioning.

Transformer Information

None	
New equipment description	New equipment will not affect the ratings of any line terminals or transformers. This project serves to resolve P5 contingencies at Black Oak Substation.
Substation assumptions	- The existing SCADA transport at Black Oak Substation is sufficient for additional SCADA telemetry. This project assumes the completion of the following projects: - Install online battery monitors in at Black Oak Substation. - Replace Black Oak A 138 kV Bus Differential Relays with Primary and backup SEL-487B's. - Replace BO3 138 kV Breaker at Black Oak Substation. - Replace the line relays, breaker, line trap, tuner and CCVT and install PCM 5350 and Smartgap on the Black Oak and Cross School terminals of the Black Oak - Cross School 138 kV Line. - Replace the line relays, breaker, line trap, tuner and CCVT and install PCM 5350 and Smartgap on the Black Oak and Cumberland terminals of the Black Oak - Cumberland 138 kV Line. - Replace the line relays, breaker, line trap, tuner and CCVT and install PCM 5350 and Smartgap on the Black Oak and Junction terminals of the Black Oak - Junction 138 kV Line.
Real-estate description	N/A - No real estate or right-of-way acquisition is necessary.
Construction responsibility	Company specific
Benefits/Comments	This project serves to resolve P5 contingencies at Black Oak Substation.

Component Cost Details - In Current Year \$

Engineering & design	This information is considered confidential and proprietary
Permitting / routing / siting	This information is considered confidential and proprietary
ROW / land acquisition	This information is considered confidential and proprietary
Materials & equipment	This information is considered confidential and proprietary
Construction & commissioning	This information is considered confidential and proprietary

Construction management	This information is considered confidential and proprietary
Overheads & miscellaneous costs	This information is considered confidential and proprietary
Contingency	This information is considered confidential and proprietary
Total component cost	\$168,399.00
Component cost (in-service year)	\$190,897.00

Substation Upgrade Component

Component title	Reid Substation - Install Redundant Relaying
Project description	Install relaying at Reid Substation to ensure there is redundancy for 138 kV bus & stuck breaker faults to avoid remote-end clearing and resolve identified TPL-001-5 violations. This will resolve all P5 contingencies at Reid Substation.
Substation name	Reid (235503)
Substation zone	APS (Area 201, Zone 1203)
Substation upgrade scope	- Replacement of the existing CA-16 A & B 138 kV bus differential schemes with dual SEL-487B relays. - Installation of an online station battery monitor with the capability of reporting voltage and open circuit alarms to the System Control Center. - Installation of a second trip coil on the Paramount No 1 REI and the Guilford RGU GCBs. - Relay setting revisions. - Testing and commissioning.

Transformer Information

None	
New equipment description	New equipment will not affect the ratings of any line terminals or transformers. This project serves to resolve P5 contingencies at Reid Substation.
Substation assumptions	- Assumed that the existing SCADA transport at Reid Substation is sufficient for additional SCADA telemetry. This project assumes the completion of the following projects: - Replace the line relays, breaker, line trap, tuner and CCVT and install PCM 5350 and Smartgap on the following lines: Antietam - Reid 138 kV, Bedington - Reid 138 kV, and Ringgold - Reid 138 kV. - Replace the 138 kV bus tiebreaker at Reid Substation.
Real-estate description	N/A - No real estate or right-of-way acquisition is necessary.

Construction responsibility	Company specific
Benefits/Comments	This project serves to resolve P5 contingencies at Reid Substation.
Component Cost Details - In Current Year \$	
Engineering & design	This information is considered confidential and proprietary
Permitting / routing / siting	This information is considered confidential and proprietary
ROW / land acquisition	This information is considered confidential and proprietary
Materials & equipment	This information is considered confidential and proprietary
Construction & commissioning	This information is considered confidential and proprietary
Construction management	This information is considered confidential and proprietary
Overheads & miscellaneous costs	This information is considered confidential and proprietary
Contingency	This information is considered confidential and proprietary
Total component cost	\$1,021,429.00
Component cost (in-service year)	\$1,161,122.00
Substation Upgrade Component	
Component title	Pruntytown - Install Redundant Relaying
Project description	Install relaying at Pruntytown Substation to ensure there is redundancy for 500 kV and 138 kV bus & stuck breaker faults to avoid remote-end clearing and resolve identified TPL-001-5 violations. This will resolve all P5 contingencies at Pruntytown Substation.
Substation name	Pruntytown (235112)
Substation zone	APS (Area 201, Zone 1201)
Substation upgrade scope	- Install a second set of SEL-587Z relays and associated CTs to provide redundant North & South 138 kV bus differential schemes. - Install a second trip coil and install a redundant set of CTs for bus protection to the P1, B2, B3, P4, P5, P6, P7, P8, P9, P10, P11, P12, P13, P14, P15, P16, and P20 circuit breakers. - Relay setting revisions. - Testing and commissioning.

Transformer Information

None

New equipment description

New equipment will not affect the ratings of any line terminals or transformers. This project serves to resolve P5 contingencies at Pruntytown Substation.

Substation assumptions

- The existing SCADA transport at Pruntytown Substation is sufficient for additional SCADA telemetry. This project assumes the completion of the following projects: - Replacement of the Pruntytown 138 kV bus differential relays. - Install online battery monitors at Pruntytown Substation. - Replace Pruntytown 138 kV breakers P17, P18, and P19.

Real-estate description

N/A - No real estate or right-of-way acquisition is necessary.

Construction responsibility

Company specific

Benefits/Comments

This project serves to resolve P5 contingencies at Pruntytown Substation.

Component Cost Details - In Current Year \$

Engineering & design

This information is considered confidential and proprietary

Permitting / routing / siting

This information is considered confidential and proprietary

ROW / land acquisition

This information is considered confidential and proprietary

Materials & equipment

This information is considered confidential and proprietary

Construction & commissioning

This information is considered confidential and proprietary

Construction management

This information is considered confidential and proprietary

Overheads & miscellaneous costs

This information is considered confidential and proprietary

Contingency

This information is considered confidential and proprietary

Total component cost

\$5,460,530.00

Component cost (in-service year)

\$6,285,945.00

Substation Upgrade Component

Component title

Junction - Install Redundant Relaying

Project description	Install relaying at Junction Substation to ensure there is redundancy for 138 kV bus & stuck breaker faults to avoid remote-end clearing and resolve identified TPL-001-5 violations. This will resolve all P5 contingencies at Junction Substation.
Substation name	Junction (235479)
Substation zone	APS (Area 201, Zone 1203)
Substation upgrade scope	- Installation of dual SEL-487B relays. - Installation of an online station battery monitor with the capability of reporting voltage and open circuit alarms to the System Control Center. - Replace the No 1 138-34.5kV Transformer 138 kV breaker. - Relay setting revisions. - Testing and commissioning.

Transformer Information

None	
New equipment description	New equipment will not affect the ratings of any line terminals or transformers. This project serves to resolve P5 contingencies at Junction Substation.
Substation assumptions	- The existing SCADA transport at Junction Substation is sufficient for additional SCADA telemetry. This project assumes the completion of the following projects: - Replacement of line relaying on the Junction - Hardy 138 kV Line. - Replacement of line relaying on the Junction - Parr Run 138 kV Line. - Replacement of the JBO 138 kV Breaker at Junction Substation.
Real-estate description	N/A - No real estate or right-of-way acquisition is necessary.
Construction responsibility	Company specific
Benefits/Comments	This project serves to resolve P5 contingencies at Junction Substation.

Component Cost Details - In Current Year \$

Engineering & design	This information is considered confidential and proprietary
Permitting / routing / siting	This information is considered confidential and proprietary
ROW / land acquisition	This information is considered confidential and proprietary
Materials & equipment	This information is considered confidential and proprietary
Construction & commissioning	This information is considered confidential and proprietary
Construction management	This information is considered confidential and proprietary

Overheads & miscellaneous costs This information is considered confidential and proprietary

Contingency This information is considered confidential and proprietary

Total component cost \$1,623,259.00

Component cost (in-service year) \$1,855,887.00

Substation Upgrade Component

Component title Doubs 500 kV - Overduty Breaker Replacements

Project description Replace eight over duty 500 kV breakers at Doubs Substation. Terminal equipment to be upgraded as well. These breakers were identified as overduty due to this proposal. Depending on the selected proposals, a new short circuit analysis will be required to confirm this upgrade is necessary.

Substation name Doubs (235105)

Substation zone APS (Area 201, Zone 1203)

Substation upgrade scope - Install foundations, conduit, and grounding for new equipment. - Install (8) 500 kV circuit breakers. - Install (20) 500kV MOAB disconnect switch, 5000 A, SCADA Controlled. - Install (1) lot of steel structures, cables, rigid bus, and grounding for new equipment. - Install (4) line relay panels. - Install (2) bus relay panels. - Install (1) lot of control cables.

Transformer Information

None

New equipment description All new equipment to be rated 5000 A or higher and have an interrupting capability of 63 kA.

Substation assumptions - It is assumed the control house has adequate space. - It is assumed the new breakers can be installed without rebuilding the bus work.

Real-estate description Land acquisition and substation fence expansion are not required.

Construction responsibility Company specific

Benefits/Comments This will alleviate the overduty breaker concern at Doubs Substation.

Component Cost Details - In Current Year \$

Engineering & design This information is considered confidential and proprietary

Permitting / routing / siting	This information is considered confidential and proprietary
ROW / land acquisition	This information is considered confidential and proprietary
Materials & equipment	This information is considered confidential and proprietary
Construction & commissioning	This information is considered confidential and proprietary
Construction management	This information is considered confidential and proprietary
Overheads & miscellaneous costs	This information is considered confidential and proprietary
Contingency	This information is considered confidential and proprietary
Total component cost	\$43,358,354.00
Component cost (in-service year)	\$50,351,658.00

Substation Upgrade Component

Component title	Pruntytown - Rebuild 138 kV Switchyard Due to Over Duty Breakers
Project description	Rebuild the 138 kV switchyard of the Pruntytown Substation due to short circuit over-duty of the breakers, the buses and the ground grid. The 138 kV breakers and switchyard facilities were identified as over dutied due to this proposal. Depending on the selected proposals, a new short circuit analysis will be required to confirm this upgrade is necessary.
Substation name	Pruntytown (235391)
Substation zone	APS (Area 201, Zone 1201)
Substation upgrade scope	- Rebuild the Pruntytown 138 kV Substation with 80 kA breakers. This will include replacing (20) 138 kV breakers and associated equipment, along with new bus construction and termination of the existing (9) 138 kV lines.

Transformer Information

None	
New equipment description	All new equipment will be rated at 80 kA.
Substation assumptions	It is assumed that a new substation yard will be required, located adjacent to the existing substation.

Real-estate description There will be no real estate acquisition as the substation property is adequate for the new switchyard. Land clearing and development may be required.

Construction responsibility Company specific

Benefits/Comments This will alleviate the over duty breaker violations at Pruntytown 138 kV Substation.

Component Cost Details - In Current Year \$

Engineering & design This information is considered confidential and proprietary

Permitting / routing / siting This information is considered confidential and proprietary

ROW / land acquisition This information is considered confidential and proprietary

Materials & equipment This information is considered confidential and proprietary

Construction & commissioning This information is considered confidential and proprietary

Construction management This information is considered confidential and proprietary

Overheads & miscellaneous costs This information is considered confidential and proprietary

Contingency This information is considered confidential and proprietary

Total component cost \$72,971,950.00

Component cost (in-service year) \$83,638,899.00

Transmission Line Upgrade Component

Component title Doubs - Goose Creek 500 kV Rebuild

Project description NOTE: The proposing entity has worked closely with other PJM TOs in developing a transmission solution and this component as well as the overall proposal should be reviewed in conjunction with proposal 2022-W3-129 and proposal 2023-W3-660. Rebuild the Doubs - Goose Creek 500 kV Line. The existing corridor encompasses the Doubs - Goose Creek 500 kV Line, the Doubs - Dickerson 230 kV Line, the Doubs - Aqueduct 230 kV Line, the Aqueduct - Dickerson 230 kV Line, and the Dickerson - Pleasant View 230 kV Line (PEPCO). The Doubs - Goose Creek 500 kV Line will be rebuilt and the Doubs - Dickerson 230 kV will be relocated and underbuilt on the same structure. Install fiber and re-terminate all lines.

Impacted transmission line Doubs - Goose Creek 500 kV

Point A	Doubs (235105)
Point B	Goose Creek (314939)
Point C	
Terrain description	The terrain is hilly.
Existing Line Physical Characteristics	
Operating voltage	500 kV
Conductor size and type	2x 2049.5 AAAC 61 Rated at 200 Degrees F
Hardware plan description	No existing hardware will be utilized. This existing line will be demolished and rebuilt.
Tower line characteristics	The existing line is constructed on single circuit steel lattice tower structures.

Proposed Line Characteristics

	Designed	Operating
Voltage (kV)	500.000000	500.000000
	Normal ratings	Emergency ratings
Summer (MVA)	4357.000000	4357.000000
Winter (MVA)	5155.000000	5155.000000
Conductor size and type	3x 1351.5 ACSR (45/7) "DIPPER" @ 110 Degrees C	
Shield wire size and type	N/A	
Rebuild line length	15.3 mi	

Rebuild portion description	- The 500 kV and 230 kV corridor rebuild will follow the same route as the existing Doubs - Goose Creek 500 kV Line. - The new 500 & 230 kV line crosses the Aqueduct-Lime Kiln 34.5 kV Line, Doubs-Dickerson 230 kV Line, and the Aqueduct-Dickerson 230 kV Lines (1) time each. - The new 500 & 230 kV line crosses the PEPCO-owned six-wired Dickerson H-Quince Orchard 230 kV Line, Dickerson D-Quince Orchard 230 kV Line, and the six-wire Dickerson D-Pleasant View 230 kV Line (1) time each. - The new 500 & 230 kV line will parallel the other new 500 and 230 kV line for approximately (15.1) miles. - The new 500 & 230 kV line crosses minor roads (13) times. Traffic control and flagging may be required. - The new 500 & 230 kV line crosses through the Dickerson Conservation Park for approximately (0.4) miles and parallels the Chesapeake and Ohio Canal National Historical Park for approximately (2.0) miles. - The Doubs-Goose Creek 500 kV line crosses the Monocacy and Potomac River (1) time each. - The POI with Dominion Energy is assumed to be structure #1841. Structure #1841 is the first structure across the Potomac River inside the state of Virginia. Coordination with Dominion during project development, engineering, and construction will be required. - It is assumed that the new double circuit structures will have an average height of 180 ft. It is assumed that the double circuit 2-pole and single circuit structures will have an average height of 150 ft.
Right of way	No new right of way will be required for this rebuild.
Construction responsibility	Company specific
Benefits/Comments	The rebuild of this 500 kV and 230 kV corridor will allow the construction of an additional 500 kV line from Doubs into the Dominion zone.

Component Cost Details - In Current Year \$

Engineering & design	This information is considered confidential and proprietary
Permitting / routing / siting	This information is considered confidential and proprietary
ROW / land acquisition	This information is considered confidential and proprietary
Materials & equipment	This information is considered confidential and proprietary
Construction & commissioning	This information is considered confidential and proprietary
Construction management	This information is considered confidential and proprietary
Overheads & miscellaneous costs	This information is considered confidential and proprietary
Contingency	This information is considered confidential and proprietary
Total component cost	\$87,740,544.00

Component cost (in-service year) \$99,749,023.00

Greenfield Transmission Line Component

Component title Doubs - Aspen 500 kV Line

Project description NOTE: The proposing entity has worked closely with other PJM TOs in developing a transmission solution and this component as well as the overall proposal should be reviewed in conjunction with proposal 2022-W3-129 and proposal 2023-W3-660. Rebuild the Doubs - Goose Creek 500 and 230 kV corridor. This existing corridor encompasses the Doubs - Goose Creek 500 kV Line, the Doubs - Dickerson 230 kV Line, the Doubs - Aqueduct 230 kV Line, the Aqueduct - Dickerson 230 kV Line, and the Dickerson - Pleasant View 230 kV Line (PEPCO). This component will construct a new Doubs - Aspen 500 kV Line. Aspen Substation is not yet constructed but is a component in Dominion's proposal 2022-W3-129. The Doubs - Aqueduct and Aqueduct - Dickerson 230 kV lines will be rebuilt and attached on the same structures. Install fiber on the new route.

Point A Doubs (235105)

Point B Aspen (313403)

Point C

	Normal ratings	Emergency ratings
Summer (MVA)	4357.000000	4357.000000
Winter (MVA)	5155.000000	5155.000000
Conductor size and type	3x 1351.5 ACSR (45/7) "DIPPER" @ 110 Degrees C	
Nominal voltage	AC	
Nominal voltage	500 kV	
Line construction type	Overhead	

General route description

- The 500 kV and 230 kV corridor rebuild will follow the same route as the existing Doubs - Goose Creek 500 kV Line. - The new 500 & 230 kV line crosses the Aqueduct-Lime Kiln 34.5 kV Line, Doubs-Dickerson 230 kV Line, and the Aqueduct-Dickerson 230 kV Lines (1) time each. - The new 500 & 230 kV line crosses the PEPCO Owned six-wired Dickerson H-Quince Orchard 230 kV Line, Dickerson D-Quince Orchard 230 kV Line, and the six-wire Dickerson D-Pleasant View 230 kV Line (1) time each. - The new 500 & 230 kV line parallels the Doubs-Goose Creek 500 kV line for approximately (15.1) miles. - The new 500 & 230 kV line crosses minor roads (13) times. Traffic control and flagging may be required. - The new 500 & 230 kV line crosses through the Dickerson Conservation Park for approximately (0.4) miles and parallels the Chesapeake and Ohio Canal National Historical Park for approximately (2.0) miles. - The new 500 and 230 kV line will cross the Monocacy and Potomac River (1) time each. - The POI with Exelon is assumed to be near Dickerson Substation. Coordination with Exelon during project development, engineering, and construction will be required. - It is assumed that the new double circuit structures will have an average height of 180 ft. It is assumed that the double circuit two-pole and single circuit structures will have an average height of 150 ft.

Terrain description

The terrain is hilly.

Right-of-way width by segment

- The right-of-way width is assumed to be 200 ft. but will share part of the right-of-way with the existing Doubs-Goose Creek 500 kV Line. This width is based on the widest ROW needed for 500 kV and does not account for structure configuration or span lengths. Widths needed can vary upon final design. - Right of way acquisition is not necessary.

Electrical transmission infrastructure crossings

the Doubs-Dickerson 230 kV Line, and the Aqueduct-Dickerson 230 kV Lines (1) time each, The new 500 & 230 kV line crosses the Aqueduct-Lime Kiln 34.5 kV Line, The new 500 & 230 kV line crosses the PEPCO Owned six-wired Dickerson H-Quince Orchard 230 kV Line, Dickerson D-Quince Orchard 230 kV Line, Owned six-wire Dickerson D-Pleasant View 230 kV Line (1) time each

Civil infrastructure/major waterway facility crossing plan

- The new 500 & 230 kV line crosses the Aqueduct-Lime Kiln 34.5 kV Line, Doubs-Dickerson 230 kV Line, and the Aqueduct-Dickerson 230 kV Lines (1) time each. - The new 500 & 230 kV line crosses the PEPCO Owned six-wired Dickerson H-Quince Orchard 230 kV Line, Dickerson D-Quince Orchard 230 kV Line, Owned six-wire Dickerson D-Pleasant View 230 kV Line (1) time each. - The new 500 & 230 kV line parallels the new 500 kV line for approximately (7.5) miles. - The new 500 & 230 kV line crosses minor roads (13) times. Traffic control and flagging may be required. - The new 500 & 230 kV line crosses through the Dickerson Conservation Park for approximately (0.4) miles and parallels the Chesapeake and Ohio Canal National Historical Park for approximately (2.0) miles. - The new 500 and 230 kV line crosses the Monocacy and Potomac River (1) time each. - The POI with Exelon is assumed to be near Dickerson Substation. Coordination with Exelon during project development, engineering, and construction will be required.

Environmental impacts	- The new 500 & 230 kV line crosses through the Dickerson Conservation Park for approximately (0.4) miles and parallels the Chesapeake and Ohio Canal National Historical Park for approximately (2.0) miles. - The new 500 and 230 kV line crosses the Monocacy and Potomac River (1) time each. - Road Bonds are required. - Environmental Filming (Documentation of Existing roads) is required. - Environmental Access and Road Crossing Permit Fees is required. - Environmental Development of Permit Binder is required. - Environmental Cultural Resource Consultation is required. - Environmental Construction walk down is required.
Tower characteristics	- It is assumed the new double circuit structures will have an average height of 180 ft. It is assumed the double circuit 2-pole and single circuit structures will have an average height of 150 ft.
Construction responsibility	Company specific
Benefits/Comments	The rebuild of this 500 kV and 230 kV corridor will allow the construction of this additional 500 kV line from Doubs into the Dominion zone.

Component Cost Details - In Current Year \$

Engineering & design	This information is considered confidential and proprietary
Permitting / routing / siting	This information is considered confidential and proprietary
ROW / land acquisition	This information is considered confidential and proprietary
Materials & equipment	This information is considered confidential and proprietary
Construction & commissioning	This information is considered confidential and proprietary
Construction management	This information is considered confidential and proprietary
Overheads & miscellaneous costs	This information is considered confidential and proprietary
Contingency	This information is considered confidential and proprietary
Total component cost	\$115,635,838.00
Component cost (in-service year)	\$131,873,150.00

Transmission Line Upgrade Component

Component title	Rebuild the Germantown - Carroll 138 kV Line to 230 kV double circuit construction
-----------------	--

Project description	Note: Components 18-30 are all a single project. Rebuild the Germantown - Carroll 138 kV Line to 230 kV double circuit construction
Impacted transmission line	Germantown - Carroll 138 kV Line
Point A	Germantown
Point B	Carroll
Point C	Taneytown
Terrain description	Terrain is hilly. Project will utilize existing right-of-way.

Existing Line Physical Characteristics

Operating voltage	138 kV
Conductor size and type	556.5 kcmil 26/7 ACSR
Hardware plan description	Single circuit wood H-Frame structures are to be replaced with double circuit steel monopole suspension structures. 13.8 miles of OPGW 48-fiber SFSJ-J-6641 to be installed.
Tower line characteristics	Existing structures being replaced to meet standards for double circuit construction.

Proposed Line Characteristics

	Designed	Operating
Voltage (kV)	230.000000	138.000000
	Normal ratings	Emergency ratings
Summer (MVA)	425.000000	522.000000
Winter (MVA)	483.000000	619.000000
Conductor size and type	1590 KCMIL 45/7 ACSR	
Shield wire size and type	OPGW 48-fiber SFSJ-J-6641	
Rebuild line length	13.8 miles	

Rebuild portion description	13.8 miles to be rebuilt. Single circuit wood H-Frame structures are to be replaced with double circuit steel monopole suspension structures. Assuming structure for structure replacement, and existing ROW. The Scope is as follows: Assuming a structure for structure replacement: -(15) 230 kV Double Circuit Tubular Steel Monopole Suspension Structure on Drilled Shaft Foundations -(45) Suspension Insulator Assemblies -(1) 230 kV Double Circuit Tubular Steel Monopole Suspension Structure on Drilled Shaft foundations -(3) Suspension Insulator Assemblies -(2) 230 kV Double Circuit Tubular Steel Monopole Deadend Structure on Drilled Shaft Foundations -(12) Deadend Insulator Assemblies -(1) 138 kV Single Circuit Tubular Steel Monopole Deadend Structure on Drilled Shaft foundation -(3) 138 kV Substation Assemblies -Install (2.8) miles of 1590 kcmil 45/7 ACSR 'Lapwing' shielded by (1) OPGW 48-fiber SFSJ-J-6641 -Approximately (0.7) miles of 7#8 Alumoweld.
Right of way	All work is assumed to be performed within existing ROW and no new ROW will be required.
Construction responsibility	Company specific
Benefits/Comments	
Component Cost Details - In Current Year \$	
Engineering & design	This information is considered confidential and proprietary
Permitting / routing / siting	This information is considered confidential and proprietary
ROW / land acquisition	This information is considered confidential and proprietary
Materials & equipment	This information is considered confidential and proprietary
Construction & commissioning	This information is considered confidential and proprietary
Construction management	This information is considered confidential and proprietary
Overheads & miscellaneous costs	This information is considered confidential and proprietary
Contingency	This information is considered confidential and proprietary
Total component cost	\$47,306,977.77
Component cost (in-service year)	\$55,449,152.40
Substation Upgrade Component	
Component title	Taneytown Substation terminal upgrade

Project description	Install conduit for fiber. Note: Components 18-30 are all a single project.
Substation name	Taneytown
Substation zone	APS (Area 201)
Substation upgrade scope	Install conduit for fiber.
Transformer Information	
None	
New equipment description	SEL-2506 DTT Relaying for both Carroll and Germantown terminals.
Substation assumptions	SEL-2506 DTT relaying and patch panel needed, Existing DC system and SCADA RTU are adequate, Adequate space in existing panel for the new relays.
Real-estate description	N/A - Work to be performed in existing substation.
Construction responsibility	Company specific
Benefits/Comments	
Component Cost Details - In Current Year \$	
Engineering & design	This information is considered confidential and proprietary
Permitting / routing / siting	This information is considered confidential and proprietary
ROW / land acquisition	This information is considered confidential and proprietary
Materials & equipment	This information is considered confidential and proprietary
Construction & commissioning	This information is considered confidential and proprietary
Construction management	This information is considered confidential and proprietary
Overheads & miscellaneous costs	This information is considered confidential and proprietary
Contingency	This information is considered confidential and proprietary
Total component cost	\$527,018.33
Component cost (in-service year)	\$634,969.93

Substation Upgrade Component

Component title	Carroll 230 kV Substation Expansion
Project description	Expand Carroll 230 kV Substation for new circuit. Add a ring bus configuration and new terminal for new 230 kV line and existing 230 kV facilities. Note: Components 18-30 are all a single project.
Substation name	Carroll
Substation zone	APS (Area 201)
Substation upgrade scope	Add ring bus configuration to Carroll 230 kV Substation. Add a new 230 kV line terminal for the new Carroll - Hunterstown 230 kV Line. Upgrade / Add relays for existing and new equipment.

Transformer Information

None	
New equipment description	230 kV three-breaker ring bus and associated disconnects. New Relays. all 230 kV equipment expected to meet or exceed 709 / 869 / 805 / 1031 MVA SN / SE / WN / WE. Below Grade -Install foundation, trench, conduit, and grounding for new equipment. -Install fencing, stoning, grading, access road, and ground grid for substation expansion. -Install conduit for fiber. Above Grade -Install (3) 230 kV, 3000 A, 63 kAIC circuit breakers. -Install (6) 230 kV, 2000 A GOAB disconnect switches. -Install (2) 230 kV, 2000 A MOAB disconnect switches. -Install (6) 230 kV CVTs, three each for the Hunterstown and Mt. Airy line terminals. -Install (6) 230 kV surge arresters, three each for the Hunterstown and Mt. Airy line terminals. -Install (1) 230 kV, 2000 A wide band wave trap, line tuner and coax for the Mt. Airy line terminal. -Install (3) 230 kV H-frames. -Install (1) 230 kV SSVT. -Install (1) medium control building. -Install (1) lot of cables, rigid and strain bus, fittings, steel structures, and grounding as shown in the attached layout. Relay & Control -Revise relay settings for the 138 kV Germantown line terminal relays. -Install (1) standard relaying panel for the 230 kV Hunterstown line terminal containing (1) SEL-421 and (1) SEL-411L. -Install (3) breaker control panels containing (1) SEL-451 and (1) SATEC meter. -Install (1) SCADA RTU and (1) HMI panel, including RTAC and GPS clock. -Install (1) fiber patch panel. -Install (1) ATS. -Install (1) lot of control cables, SEL cables, and fiber.
Substation assumptions	-Backup station service will be from local distribution. -Execution engineer to conduct AC/DC system, lightning, and grounding studies. -Property to the west of current Carroll Substation is available. -Property purchase, clearing, grading, and access road are required. -There may be a need for lead abatement and asbestos removal, but neither are included in this estimate.
Real-estate description	Land will need to be acquired for this expansion.
Construction responsibility	Company specific

Benefits/Comments

Component Cost Details - In Current Year \$

Engineering & design	This information is considered confidential and proprietary
Permitting / routing / siting	This information is considered confidential and proprietary
ROW / land acquisition	This information is considered confidential and proprietary
Materials & equipment	This information is considered confidential and proprietary
Construction & commissioning	This information is considered confidential and proprietary
Construction management	This information is considered confidential and proprietary
Overheads & miscellaneous costs	This information is considered confidential and proprietary
Contingency	This information is considered confidential and proprietary
Total component cost	\$7,618,026.50
Component cost (in-service year)	\$9,121,917.03

Transmission Line Upgrade Component

Component title	Rebuild the Germantown - Lincoln 115 kV Line for 230 kV double circuit construction
Project description	Rebuild the Germantown - Lincoln 115 kV Line for 230 kV double circuit construction Note: Components 18-30 are all a single project.
Impacted transmission line	Germantown - Lincoln 115 kV Line
Point A	Germantown
Point B	Lincoln
Point C	Straban
Terrain description	Terrain is hilly. Project will use existing ROW.

Existing Line Physical Characteristics

Operating voltage	115 kV
Conductor size and type	556.5 kcmil 26/7 ACSR
Hardware plan description	Single circuit wood structures are to be replaced with double circuit steel monopole suspension structures. 7.5 miles of OPGW 48-fiber SFSJ-J-6641 to be installed.
Tower line characteristics	Existing structures are being replaced to meet standards for double circuit construction.

Proposed Line Characteristics

	Designed	Operating
Voltage (kV)	230.000000	115.000000
	Normal ratings	Emergency ratings
Summer (MVA)	355.000000	435.000000
Winter (MVA)	403.000000	515.000000
Conductor size and type	1590 KCMIL 45/7 ACSR	
Shield wire size and type	OPGW 48-fiber SFSJ-J-6641	
Rebuild line length	7.5 miles	
Rebuild portion description	7.5 miles of 115 kV line to be rebuilt. Single circuit wood structures are to be replaced with double circuit steel monopole suspension structures. Assuming structure for structure replacement. Assume a structure for structure rebuild -(41) 230 kV Double Circuit Tubular Steel Monopole Suspension Structure on Drilled Shaft Foundations -(3) 230 kV Double Circuit Tubular Steel Monopole Suspension Structure on Drilled Shaft Foundations -(2) 230 kV Double Circuit Tubular Steel Monopole Deadend Structure on Drilled Shaft Foundations -(2) 230 kV Double Circuit Tubular Steel Monopole Deadend Structure on Drilled Shaft Foundations -(1) 230 kV Triple Circuit Tubular Steel Monopole Loop Structure on Drilled Shaft Foundations -(12) Deadend Insulator Assemblies -(2) 115 kV Single Circuit Tubular Steel Monopole Suspension Structure on Drilled Shaft Foundations -(1) 115 kV Single Circuit Tubular Steel Monopole Deadend Structure on Drilled Shaft Foundations -(12) 115 kV Substation Insulator Assemblies -Install (7.5) miles of 1590 kcmil 45/7 ACSR 'Lapwing' shielded by (1) OPGW 48-fiber SFSJ-J-6641	
Right of way	All work is assumed to be performed within existing ROW and no new ROW will be required.	

Construction responsibility

Company specific

Benefits/Comments

Component Cost Details - In Current Year \$

Engineering & design

This information is considered confidential and proprietary

Permitting / routing / siting

This information is considered confidential and proprietary

ROW / land acquisition

This information is considered confidential and proprietary

Materials & equipment

This information is considered confidential and proprietary

Construction & commissioning

This information is considered confidential and proprietary

Construction management

This information is considered confidential and proprietary

Overheads & miscellaneous costs

This information is considered confidential and proprietary

Contingency

This information is considered confidential and proprietary

Total component cost

\$30,099,573.04

Component cost (in-service year)

\$35,535,340.94

Transmission Line Upgrade Component

Component title

Rebuild the Hunterstown- Lincoln 115 kV Line for 230 kV double circuit construction

Project description

Rebuild the Hunterstown- Lincoln 115 kV Line for 230 kV double circuit construction. Note: Components 18-30 are all a single project.

Impacted transmission line

Hunterstown - Lincoln 115 kV Line

Point A

Hunterstown

Point B

Lincoln

Point C

Terrain description

Terrain is hilly. Project will use existing ROW.

Existing Line Physical Characteristics

Operating voltage	115 kV
Conductor size and type	795 kcmil 26/7 ACSR
Hardware plan description	Single circuit wood structures are to be replaced with double circuit steel monopole suspension structures. 2.6 miles of OPGW 48-fiber SFSJ-J-6641 to be installed.
Tower line characteristics	Existing structures being replaces to meet standards for double circuit construction.

Proposed Line Characteristics

	Designed	Operating
Voltage (kV)	230.000000	115.000000
	Normal ratings	Emergency ratings
Summer (MVA)	355.000000	435.000000
Winter (MVA)	403.000000	515.000000
Conductor size and type	1590 KCMIL 45/7 ACSR	
Shield wire size and type	OPGW 48-fiber SFSJ-J-6641	
Rebuild line length	2.6 miles	
Rebuild portion description	2.6 miles of 115 kV line to be rebuilt. Single circuit wood structures are to be replaced with double circuit steel monopole suspension structures. Assuming a structure for structure replacement: -(13) 230 kV Double Circuit Tubular Steel Suspension Structure on Drilled Shaft Foundations -(4) 230 kV Double Circuit Tubular Steel Suspension Structure on Drilled Shaft Foundations -(1) 230 kV Double Circuit Tubular Steel Deadend Structure on Drilled Shaft Foundations -(3) 115 kV Single Circuit Tubular Steel Monopole Suspension Structure on Drilled Shaft Foundations -(2) 115 kV Single Circuit Tubular Steel Monopole Deadend Structure on Drilled Shaft Foundations -(1) 115 kV Single Circuit Tubular Steel 3-Pole Deadend Structure -(1) 115 kV Single Circuit Tubular Steel H-Frame Suspension Structure on Drilled Shaft Foundations. -(6) 115 kV Substation Deadend Assemblies -(6) 115 kV Deadend Assemblies -Install (2.6) miles of 1590 kcmil 45/7 ACSR 'Lapwing' shielded by (1) OPGW 48-fiber SFSJ-J-6641	
Right of way	All work is assumed to be performed within existing ROW and no new ROW will be required.	

Construction responsibility	Company specific	
Benefits/Comments		
Component Cost Details - In Current Year \$		
Engineering & design	This information is considered confidential and proprietary	
Permitting / routing / siting	This information is considered confidential and proprietary	
ROW / land acquisition	This information is considered confidential and proprietary	
Materials & equipment	This information is considered confidential and proprietary	
Construction & commissioning	This information is considered confidential and proprietary	
Construction management	This information is considered confidential and proprietary	
Overheads & miscellaneous costs	This information is considered confidential and proprietary	
Contingency	This information is considered confidential and proprietary	
Total component cost	\$11,475,570.19	
Component cost (in-service year)	\$13,368,189.33	
Greenfield Transmission Line Component		
Component title	Construct New 230 kV Hunterstown - Carroll Line (MAIT section)	
Project description	Build new 230 kV line between Hunterstown (ME) and Carroll (APS-PE) substations (13.1 miles) along existing 115/138kV corridor on double circuit steel structures. Note: Components 18-30 are all a single project.	
Point A	Hunterstown	
Point B	Carroll	
Point C		
	Normal ratings	Emergency ratings
Summer (MVA)	709.000000	869.000000

Winter (MVA)	805.000000	1031.000000
Conductor size and type	1590 KCMIL 45/7 ACSR	
Nominal voltage	AC	
Nominal voltage	230 kV	
Line construction type	Overhead	
General route description	The new 230kV Hunterstown - Carroll will follow the existing ROW of the 115/138kV path from Hunterstown - Lincoln - Germantown - Carroll substations.	
Terrain description	Terrain is Hilly. Project will use existing ROW.	
Right-of-way width by segment	The segments will use existing ROW.	
Electrical transmission infrastructure crossings	None	
Civil infrastructure/major waterway facility crossing plan	None	
Environmental impacts	An environmental review will be required to identify any additional construction constraints or additional permitting requirements.	
Tower characteristics	New towers for this segment will be single circuit tubular steel monopole suspension structures. Structures Installed -(2) 230 kV Single Circuit Tubular Steel Monopole Suspension Structure (TR-230310) on Drilled Shaft Foundations -(4) 230 kV Single Circuit Tubular Steel Monopole Angle Structure on Drilled Shaft Foundations -(3) 230 kV Single Circuit Tubular Steel Monopole Deadend Structure on Drilled Shaft Foundations -(1) 230 kV Single Circuit Tubular Steel 3-Pole Deadend Structure on Drilled Shaft Foundations -(1) 230 kV Single Circuit Tubular Steel 3-Pole Deadend Structure on Drilled Shaft Foundations -(2) 230 kV Single Circuit Tubular Steel H-Frame Suspension Structure (Similar to TR-230045) on Drilled Shaft Foundations -(231) 230 kV Suspension Insulator Assemblies -(48) 230 kV Deadend Insulator Assemblies -(3) 230 kV Substation Assemblies -Approximately (13.1) miles of 1590 kcmil 45/7 ACSR 'Lapwing' shielded by (1) OPGW 48-fiber SFSJ-J-6641 -Approximately (1.2) miles of 7#8 Alumoweld.	
Construction responsibility	Company specific	
Benefits/Comments		
Component Cost Details - In Current Year \$		
Engineering & design	This information is considered confidential and proprietary	

Permitting / routing / siting	This information is considered confidential and proprietary
ROW / land acquisition	This information is considered confidential and proprietary
Materials & equipment	This information is considered confidential and proprietary
Construction & commissioning	This information is considered confidential and proprietary
Construction management	This information is considered confidential and proprietary
Overheads & miscellaneous costs	This information is considered confidential and proprietary
Contingency	This information is considered confidential and proprietary
Total component cost	\$17,370,010.64
Component cost (in-service year)	\$20,301,682.47

Transmission Line Upgrade Component

Component title	Rebuild the Germantown - Carroll 138 kV Line for 230 kV double circuit construction (MAIT)
Project description	Rebuild the Germantown - Carroll 138 kV Line for 230 kV double circuit construction (MAIT). Note: Components 18-30 are all a single project.
Impacted transmission line	Germantown - Carroll 138 kV Line
Point A	Germantown
Point B	Carroll
Point C	Taneytown
Terrain description	Terrain is hilly. Existing ROW to be used.

Existing Line Physical Characteristics

Operating voltage	138 kV
Conductor size and type	556.5 kcmil 26/7 ACSR
Hardware plan description	Single circuit wood structures are to be replaced with double circuit steel monopole suspension structures. 2.8 miles of OPGW 48-fiber SFSJ-J-6641 to be installed.

Tower line characteristics

Existing structures being replaced to meet standards for double circuit construction.

Proposed Line Characteristics

	Designed	Operating
Voltage (kV)	230.000000	138.000000
	Normal ratings	Emergency ratings
Summer (MVA)	425.000000	522.000000
Winter (MVA)	483.000000	619.000000
Conductor size and type	1590 KCMIL 45/7 ACSR	
Shield wire size and type	OPGW 48-fiber SFSJ-J-6641	
Rebuild line length	2.8 miles	
Rebuild portion description	2.8 miles to be rebuilt. Single circuit wood structures are to be replaced with double circuit steel monopole suspension structures. Assuming a structure for structure replacement: -(15) 230 kV Double Circuit Tubular Steel Monopole Suspension Structure on Drilled Shaft Foundations -(1) 230 kV Double Circuit Tubular Steel Monopole Suspension Structure on Drilled Shaft foundations -(2) 230 kV Double Circuit Tubular Steel Monopole Deadend Structure on Drilled Shaft Foundations -(1) 138 kV Single Circuit Tubular Steel Monopole Deadend Structure on Drilled Shaft foundation -(3) 138 kV Substation Assemblies -Install (2.8) miles of 1590 kcmil 45/7 ACSR 'Lapwing' shielded by (1) OPGW 48-fiber SFSJ-J-6641 -Approximately (0.7) miles of 7#8 Alumoweld.	
Right of way	All work is assumed to be performed within existing ROW and no new ROW will be required.	
Construction responsibility	Company specific	
Benefits/Comments		
Component Cost Details - In Current Year \$		
Engineering & design	This information is considered confidential and proprietary	
Permitting / routing / siting	This information is considered confidential and proprietary	
ROW / land acquisition	This information is considered confidential and proprietary	

Materials & equipment	This information is considered confidential and proprietary
Construction & commissioning	This information is considered confidential and proprietary
Construction management	This information is considered confidential and proprietary
Overheads & miscellaneous costs	This information is considered confidential and proprietary
Contingency	This information is considered confidential and proprietary
Total component cost	\$12,160,267.60
Component cost (in-service year)	\$14,189,329.51

Substation Upgrade Component

Component title	Revise Relay Settings at Germantown Substation
Project description	Install conduit for fiber and revise relay settings for 115 kV 998 line and 115/138 kV 999 line. Note: Components 18-30 are all a single project.
Substation name	Germantown
Substation zone	ME
Substation upgrade scope	Install conduit for fiber, Revise relay settings for 115 kV 998 line and 115/138 kV 999 line. Upgrade relay equipment.

Transformer Information

None	
New equipment description	New fiber. Relay setting changes.
Substation assumptions	Existing relays for 998 and 999 will be reused.
Real-estate description	N/A
Construction responsibility	Company specific
Benefits/Comments	

Component Cost Details - In Current Year \$

Engineering & design	This information is considered confidential and proprietary
Permitting / routing / siting	This information is considered confidential and proprietary
ROW / land acquisition	This information is considered confidential and proprietary
Materials & equipment	This information is considered confidential and proprietary
Construction & commissioning	This information is considered confidential and proprietary
Construction management	This information is considered confidential and proprietary
Overheads & miscellaneous costs	This information is considered confidential and proprietary
Contingency	This information is considered confidential and proprietary
Total component cost	\$474,000.75
Component cost (in-service year)	\$572,899.92

Substation Upgrade Component

Component title	Install new 230 kV line terminal at Hunterstown Substation
Project description	Install 230 kV line terminal equipment at Hunterstown Substation for new 230 kV line. Note: Components 18-30 are all a single project.
Substation name	Hunterstown
Substation zone	ME
Substation upgrade scope	Install 230 kV CB and associated disconnects, CVTs, surge arresters, structures, and relays. Below Grade -Install foundation, conduit, and grounding for new equipment. -Install conduit for fiber. Above Grade -Install (1) 230 kV, 3000A, 63 kAIC circuit breaker. -Install (1) 230 kV, 2000 A MOAB disconnect switch. -Install (2) 230 kV, 2000 A GOAB disconnect switches. -Install (3) 230 kV CVTs. -Install (3) 230 kV surge arresters. -Install (1) 230 kV H-frame. -Install (1) lot of cables, steel structures, rigid bus, fittings, and grounding as shown in the attached layout. Relay & Control -Revise relay settings for the 115 kV Hunterstown-Lincoln 962 line and SEL-352 for B2 breaker failure relaying. -Install (1) standard relay panel for the new 230 kV Carroll line terminal containing (1) SEL-421, (1) SEL-411L, and (1) SEL-451 BFT. -Install (1) lot of control cables, SEL cables, and fiber.

Transformer Information

None

New equipment description

New 230 kV CB and associated disconnects. ratings are to meet or exceed 709 / 869 / 805 / 1031 MVA SN / SE / WN / WE Below Grade -Install foundation, conduit, and grounding for new equipment. -Install conduit for fiber. Above Grade -Install (1) 230 kV, 3000 A, 63 kAIC circuit breaker. -Install (1) 230 kV, 2000 A MOAB disconnect switch. -Install (2) 230 kV, 2000 A GOAB disconnect switches. -Install (3) 230 kV CVTs. -Install (3) 230 kV surge arresters. -Install (1) 230 kV H-frame. -Install (1) lot of cables, steel structures, rigid bus, fittings, and grounding as shown in the attached layout. Relay & Control -Revise relay settings for the 115 kV Hunterstown-Lincoln 962 line and SEL-352 for B2 breaker failure relaying. -Install (1) standard relay panel for the new 230 kV Carroll line terminal containing (1) SEL-421, (1) SEL-411L, and (1) SEL-451 BFT. -Install (1) lot of control cables, SEL cables, and fiber.

Substation assumptions

Existing AC/DC systems and SCADA RTU are adequate. Related existing relays to be reused. Adequate space in control house for the new panel.

Real-estate description

N/A

Construction responsibility

Company specific

Benefits/Comments

Component Cost Details - In Current Year \$

Engineering & design

This information is considered confidential and proprietary

Permitting / routing / siting

This information is considered confidential and proprietary

ROW / land acquisition

This information is considered confidential and proprietary

Materials & equipment

This information is considered confidential and proprietary

Construction & commissioning

This information is considered confidential and proprietary

Construction management

This information is considered confidential and proprietary

Overheads & miscellaneous costs

This information is considered confidential and proprietary

Contingency

This information is considered confidential and proprietary

Total component cost

\$2,306,685.28

Component cost (in-service year) \$2,776,386.44

Substation Upgrade Component

Component title Revise Relay Settings at Lincoln Substation

Project description Install conduit for fiber and revise relay settings for 115 kV 998 line to Germantown and the 962 line to AD1-020. Note: Components 18-30 are all a single project.

Substation name Lincoln

Substation zone ME

Substation upgrade scope Install conduit for fiber and revise relay settings for 115 kV 998 line to Germantown and the 962 line to AD1-020. Upgrade relay equipment.

Transformer Information

None

New equipment description New fiber. Relay setting changes.

Substation assumptions Existing relays for 998 and 962 lines will be reused.

Real-estate description N/A

Construction responsibility Company specific

Benefits/Comments

Component Cost Details - In Current Year \$

Engineering & design This information is considered confidential and proprietary

Permitting / routing / siting This information is considered confidential and proprietary

ROW / land acquisition This information is considered confidential and proprietary

Materials & equipment This information is considered confidential and proprietary

Construction & commissioning This information is considered confidential and proprietary

Construction management This information is considered confidential and proprietary

Overheads & miscellaneous costs	This information is considered confidential and proprietary
Contingency	This information is considered confidential and proprietary
Total component cost	\$306,713.30
Component cost (in-service year)	\$370,187.80

Substation Upgrade Component

Component title	Install DTT relaying at Straban Substation
Project description	Install DTT relaying for Lincoln and Germantown line terminals. Note: Components 18-30 are all a single project.
Substation name	Straban
Substation zone	ME
Substation upgrade scope	Install DTT relaying for Lincoln and Germantown line terminals, and fiber patch panel.

Transformer Information

None	
New equipment description	New SEL-2506 DTT relaying for Lincoln and Germantown line terminals.
Substation assumptions	Existing DC system and SCADA RTU are adequate. Adequate space in existing panel for new DTT relays.
Real-estate description	N/A
Construction responsibility	Company specific
Benefits/Comments	

Component Cost Details - In Current Year \$

Engineering & design	This information is considered confidential and proprietary
Permitting / routing / siting	This information is considered confidential and proprietary
ROW / land acquisition	This information is considered confidential and proprietary

Materials & equipment	This information is considered confidential and proprietary
Construction & commissioning	This information is considered confidential and proprietary
Construction management	This information is considered confidential and proprietary
Overheads & miscellaneous costs	This information is considered confidential and proprietary
Contingency	This information is considered confidential and proprietary
Total component cost	\$668,530.58
Component cost (in-service year)	\$804,260.89

Substation Upgrade Component

Component title	Network Upgrades at Carroll Substation
Project description	Design, install, and test/commission MPLS Equipment for SCADA transport in the 138 kV and 230 kV control houses at Carroll Substation. Note: Components 18-30 are all a single project.
Substation name	Carroll
Substation zone	APS (Area 201)
Substation upgrade scope	Design, install, and test/commission MPLS Equipment for SCADA transport in the 138 kV and 230 kV control houses at Carroll Substation.

Transformer Information

None	
New equipment description	Network Upgrades
Substation assumptions	New MPLS Equipment
Real-estate description	N/A
Construction responsibility	Company specific
Benefits/Comments	

Component Cost Details - In Current Year \$

Engineering & design	This information is considered confidential and proprietary
Permitting / routing / siting	This information is considered confidential and proprietary
ROW / land acquisition	This information is considered confidential and proprietary
Materials & equipment	This information is considered confidential and proprietary
Construction & commissioning	This information is considered confidential and proprietary
Construction management	This information is considered confidential and proprietary
Overheads & miscellaneous costs	This information is considered confidential and proprietary
Contingency	This information is considered confidential and proprietary
Total component cost	\$425,560.77
Component cost (in-service year)	\$476,628.06

Greenfield Transmission Line Component

Component title	Construct New 230 kV Hunterstown - Carroll Line (APS-PE section)	
Project description	Build new 230 kV line between Hunterstown Substation (ME) and Carroll Substation (APS-PE) (11.2 miles) along existing 115/138kV corridor on double circuit steel structures. Note: Components 18-30 are all a single project.	
Point A	Hunterstown	
Point B	Carroll	
Point C		

	Normal ratings	Emergency ratings
Summer (MVA)	709.000000	869.000000
Winter (MVA)	805.000000	1031.000000
Conductor size and type	1590 KCMIL 45/7 ACSR	

Nominal voltage	AC
Nominal voltage	230 kV
Line construction type	Overhead
General route description	The new 230 kV Hunterstown - Carroll line will follow the existing ROW of the 115/138kV path from Hunterstown - Lincoln - Germantown - Carroll substations.
Terrain description	Terrain is Hilly. Existing ROW to be used.
Right-of-way width by segment	The segments will use existing ROW.
Electrical transmission infrastructure crossings	None
Civil infrastructure/major waterway facility crossing plan	None
Environmental impacts	An environmental review will be required to identify any additional construction constraints or additional permitting requirements.
Tower characteristics	New towers for this segment will be single circuit tubular steel monopole suspension structures. Tower Characteristics identified in the other line rebuild components. Additional Structures are as follows: Structures Installed -(2) 230 kV Single Circuit Steel Monopole Deadend Structure -(240) 230 kV Suspension Insulators Assemblies -(30) 230 kV Deadend Insulator Assemblies -(3) 230 kV Substation Assemblies -Install (11.2) miles of 1590 kcmil 45/7 ACSR 'Lapwing' (1) OPGW 48-fiber SFSJ-J-6641 -Approximately (0.1) miles of 7#8 Alumoweld.
Construction responsibility	Company specific
Benefits/Comments	
Component Cost Details - In Current Year \$	
Engineering & design	This information is considered confidential and proprietary
Permitting / routing / siting	This information is considered confidential and proprietary
ROW / land acquisition	This information is considered confidential and proprietary
Materials & equipment	This information is considered confidential and proprietary
Construction & commissioning	This information is considered confidential and proprietary

Construction management	This information is considered confidential and proprietary
Overheads & miscellaneous costs	This information is considered confidential and proprietary
Contingency	This information is considered confidential and proprietary
Total component cost	\$6,708,410.79
Component cost (in-service year)	\$7,832,824.63

Substation Upgrade Component

Component title	Fort Martin Substation - Expand 500 kV
Project description	Expand Fort Martin 500 kV Substation by installing a new 500 kV breaker string with three breakers and associated equipment. This will require the 500 kV Bus N & S to be extended to the west, along with a fence expansion, and relay installations. No land acquisition should be needed. This upgrade will only be required for the construction of the Fort Martin - Doubs #2 500 kV Line (Component 32).
Substation name	Fort Martin (235106)
Substation zone	APS (Area 201, Zone 1201)
Substation upgrade scope	- Install foundation, conduit, and grounding for new equipment. - Install fencing and stoning for substation expansion. - Install (3) 500kV circuit breakers. - Install (6) 500kV GOAB disconnect switches. - Install (2) 500kV MOAB disconnect switches. - Install (6) 500kV surge arresters. - Install (6) 500 CVTs. - Install (2) H-frames. - Install (1) lot of rigid bus, cables, grounding, and fittings. - Install (2) line relaying panel including BFT.

Transformer Information

None	
New equipment description	All new equipment to be rated at 5000 A or higher.
Substation assumptions	- There is adequate space in the existing control house for the new panels. - Land does not need to be purchased. Expansion is on existing substation property.
Real-estate description	Fort Martin 500 kV Substation will require a fence expansion, but no property acquisition is required. There are no identified wetlands to the west of Fort Martin Substation, where the expansion is proposed. There is a wide stream valley to the east and channels to the south of Fort Martin Substation, which would require wetland mitigation if the substation is expanded in those directions. The terrain is hilly.

Construction responsibility

Company specific

Benefits/Comments

This 500 kV expansion at Fort Martin Substation will allow two additional 500 kV lines to be terminated at Fort Martin Substation.

Component Cost Details - In Current Year \$

Engineering & design

This information is considered confidential and proprietary

Permitting / routing / siting

This information is considered confidential and proprietary

ROW / land acquisition

This information is considered confidential and proprietary

Materials & equipment

This information is considered confidential and proprietary

Construction & commissioning

This information is considered confidential and proprietary

Construction management

This information is considered confidential and proprietary

Overheads & miscellaneous costs

This information is considered confidential and proprietary

Contingency

This information is considered confidential and proprietary

Total component cost

\$30,334,428.00

Component cost (in-service year)

\$35,306,215.00

Greenfield Transmission Line Component

Component title

Fort Martin - Doubs 500 kV #2 Line

Project description

Construct ~158 miles of new double circuit 500 kV line from Fort Martin Substation to Doubs Substation. Terminate the new transmission line and revise relay settings at Doubs and Fort Martin substations. Install fiber along the new route. The construction of this new line will require the acquisition of 158 miles of new right-of-way, forestry clearing, permitting, and access road construction. Re-terminate the Bismark 500 kV line at Doubs Substation. Aerial LiDAR will be required. This new transmission line will require Proposal Components 1 (Doubs Substation - Install 500 kV Breaker), 2 (Doubs Substation - Expand 500 kV), 4 (Fort Martin Substation - Install 500 kV Breaker), 7 (Doubs - Fort Martin 500 kV Line #1), and 31 (Fort Martin - Expand 500 kV) to be completed. Note: This component includes the cost of Proposal Component 7.

Point A

Fort Martin (235106)

Point B Doubs (235105)

Point C

	Normal ratings	Emergency ratings
Summer (MVA)	4625.000000	5670.000000
Winter (MVA)	5252.000000	6724.000000
Conductor size and type	3x 1590 KCMIL 45/7 ACSR rated at 212°F	
Nominal voltage	AC	
Nominal voltage	500	
Line construction type	Overhead	
General route description	<p>- This new 500 kV line will be constructed in West Virginia, Virginia, and Maryland. Full Applications will be required in each state. - It is assumed that the new 500 kV line will parallel existing ROW for approximately (85.6) miles and require (74.4) miles of new ROW not adjacent to existing ROW. It is assumed that no existing lines will be overbuilt with double circuit structures, but existing line rebuilds will be considered where applicable. - Approximately (695) parcels will be affected by the line route. Assumed 5% condemnation (35 parcels).</p>	
Terrain description	<p>- The terrain for this line is hilly/mountainous with state lands, national parks, and rivers along the proposed route of this new line. Traditional access and construction may be affected. Alternative access and construction may need to be considered.</p>	
Right-of-way width by segment	<p>- The right-of-way width is assumed to be 200 ft. This width is based on the widest ROW needed for 500 kV and does not account for structure configuration or span lengths. Widths needed can vary upon final design.</p>	
Electrical transmission infrastructure crossings	<p>See information below. Each crossing will not be listed as the route is subject to change.</p>	

Civil infrastructure/major waterway facility crossing plan

- The new 500 kV line will cross (23) major roads. Traffic control and flagging will be required. - The new 500 kV line will cross (4) CSX Railroads, (1) Norfolk Southern Railroad, and parallels railroad ROW for (3.2) miles. Crossing permits and flagging will be required. - The new 500 kV line will cross (14) rivers or other bodies of water. Crossing permits and FAA coordination may be required. - The new 500 kV line crosses through (9) wetlands and (5) parks. Environmental considerations and special coordination may be required. - The new 500 kV line will cross (2) 500kV, (25) 138kV, (1) 115kV, and (9) 34.5kV transmission lines multiple times. - Crosses DNR owned land in WV/MD/VA. Licensing and permitting of new ROW with either state's DNR could take 24 months and may need to be approved by the state's legislature. - Crosses the Youghiogheny River, a state designated scenic river. Permitting of new ROW over a scenic river is estimated to be 12-18 months. - Crossing of large wetland complexes in WV and MD could result in lengthier permitting 12-18 months and increased mitigation cost. - Crosses C&O Canal National Park. Licensing and permitting of new ROW with National Park Service could take 24 months to complete.

Environmental impacts

- The new 500 kV line will cross (14) rivers or other bodies of water. Crossing permits and FAA coordination may be required. - The new 500 kV line crosses through (9) wetlands and (5) parks. Environmental considerations and special coordination may be required. - Crosses DNR owned land in WV/MD/VA. Licensing and permitting of new ROW with either state's DNR could take 24 months and may need to be approved by the state's legislature. - Crosses the Youghiogheny River, a state designated scenic river. Permitting of new ROW over a scenic river is estimated to be 12-18 months. - Crossing of large wetland complexes in WV and MD could result in lengthier permitting 12-18 months and increased mitigation cost. - Crosses C&O Canal National Park. Licensing and permitting of new ROW with National Park Service could take 24 months to complete. - Road Bonds are required. - Environmental Filming (Documentation of Existing roads) is required. - Environmental Access and Road Crossing Permit Fees is required. - Environmental Development of Permit Binder is required. - Environmental Cultural Resource Consultation is required. - Environmental Construction walk down is required.

Tower characteristics

- The new Fort Martin-Doubs #2 500 kV line will be constructed on double circuit 500 kV tubular steel monopole and two-pole structures. - The average span length is 1200 ft. - It is assumed that the new double circuit monopole structures will have an average height of 180 ft. Final structure heights will need to be determined during project development. FAA filing and application will be required. - The new structures will utilize custom 500 kV V-string and double I-string suspension and dead-end insulator assemblies.

Construction responsibility

Company specific

Benefits/Comments

- This new 500 kV line provides a direct connection from the west side of the system to the east side. - This new line route will provide the opportunity to loop the Fort Martin - Doubs 500 kV Line into Bedington and/or Black Oak substations in the future, if necessary for reliability or resiliency. - Greenfield construction is assumed due to outage constraints, but existing rights-of-way and corridors to rebuild lower voltage lines will be considered where applicable.

Component Cost Details - In Current Year \$

Engineering & design	This information is considered confidential and proprietary
Permitting / routing / siting	This information is considered confidential and proprietary
ROW / land acquisition	This information is considered confidential and proprietary
Materials & equipment	This information is considered confidential and proprietary
Construction & commissioning	This information is considered confidential and proprietary
Construction management	This information is considered confidential and proprietary
Overheads & miscellaneous costs	This information is considered confidential and proprietary
Contingency	This information is considered confidential and proprietary
Total component cost	\$1,927,594,834.00
Component cost (in-service year)	\$2,177,283,110.00

Congestion Drivers

None

Existing Flowgates

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-GD-S779200512		26LEWISTWN	200519	26REED TAP	1	115	226	Summer Gen Deliv	Included
2022W3-N1-ST95235518		01WESTVA	237506	01CROSSCHOOL	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-ST96235518		01WESTVA	237506	01CROSSCHOOL	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-ST97235503		01REID	235505	01RINGLD	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-ST98314009		6BRADOCK	314052	6IDYLWOD	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-GD-S165213846		NOTTREAC	213869	PCHBTMTP	1	230	230	Summer Gen Deliv	Included
2022W3-GD-S165814084		6SULLY	314035	6DISCOVR	1	230	345	Summer Gen Deliv	Included
2022W3-GD-S165205912		AD1-020 TAP	204544	27LINCOLN	1	115	227	Summer Gen Deliv	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-N1-ST89	314009	6BRADOCK	314052	6IDYLWOD	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-GD-S166	205912	AD1-020 TAP	204544	27LINCOLN	1	115	227	Summer Gen Deliv	Included
2022W3-N1-ST90	235101	01BEDNGT	235445	01BEDNGT	2	500/138	201/201	Summer N-1 Thermal	Included
2022W3-GD-S70	235503	01REID	235505	01RINGLD	1	138	201	Summer Gen Deliv	Included
2022W3-N1-ST91	314939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-GD-S166	205912	AD1-020 TAP	204544	27LINCOLN	1	115	227	Summer Gen Deliv	Included
2022W3-N1-ST92	235518	01WESTVA	237506	01CROSSCHOOL	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-GD-S73	223938	DICKH230	223937	DICK 230	1	230	233	Summer Gen Deliv	Included
2022W3-N1-ST93	235518	01WESTVA	237506	01CROSSCHOOL	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-GD-S72	223938	DICKH230	223937	DICK 230	2	230	233	Summer Gen Deliv	Included
2022W3-N1-ST94	235518	01WESTVA	237506	01CROSSCHOOL	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-GD-S201	1914041	6GLEBE	314185	6RADNOR	1	230	345	Summer Gen Deliv	Included
2022W3-GD-S84	213844	NOTTINGHM	213846	NOTTREAC	1	230	230	Summer Gen Deliv	Included
2022W3-GD-S85	213846	NOTTREAC	213869	PCHBTMTP	1	230	230	Summer Gen Deliv	Included
2022W3-N1-ST100	223938	DICKH230	223937	DICK 230	1	230/230	233/233	Summer N-1 Thermal	Included
2022W3-N1-ST107	314006	6ASHBURA	314010	6BEAMEAD	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST108	313752	6TAKEOFF	313774	6LINC PRK	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-GD-S780	200512	26LEWISTWN	200519	26REED TAP	1	115	226	Summer Gen Deliv	Included
2022W3-GD-S76	235479	01JUNCTN	235467	01FRNCHM	1	138	201	Summer Gen Deliv	Included
2022W3-N1-ST99	313399	6MARS	313746	6SOJOURNER	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-GD-S78	235479	01JUNCTN	235467	01FRNCHM	1	138	201	Summer Gen Deliv	Included
2022W3-N1-ST100	313393	8MARS	313399	6MARS	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-GD-S166	314916	8MORRSVL	313440	8VINTHIL	1	500	345	Summer Gen Deliv	Included
2022W3-N1-ST102	223938	DICKH230	223937	DICK 230	2	230/230	233/233	Summer N-1 Thermal	Included
2022W3-GD-S166	314916	8MORRSVL	313440	8VINTHIL	1	500	345	Summer Gen Deliv	Included
2022W3-N1-ST102	223938	DICKH230	223937	DICK 230	1	230/230	233/233	Summer N-1 Thermal	Included
2022W3-GD-S166	204539	27HUNTRSTN	205912	AD1-020 TAP	1	115	227	Summer Gen Deliv	Included
2022W3-N1-ST102	223938	DICKH230	223937	DICK 230	2	230/230	233/233	Summer N-1 Thermal	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-GD-S166	200064	PCHBTM1S	200004	CNASTONE	1	500	232/230	Summer Gen Deliv	Included
2022W3-N1-ST10	223938	DICKH230	223937	DICK 230	2	230/230	233/233	Summer N-1 Thermal	Included
2022W3-GD-S83	314041	6GLEBE	314185	6RADNOR	1	230	345	Summer Gen Deliv	Included
2022W3-N1-ST10	223938	DICKH230	223937	DICK 230	1	230/230	233/233	Summer N-1 Thermal	Included
2022W3-GD-S167	204530	27GERMANTN	235463	01TANEY	1	138	227/201	Summer Gen Deliv	Included
2022W3-GD-S94	235523	01BETHEL+	235507	01RIVERT	1	138	201	Summer Gen Deliv	Included
2022W3-GD-S95	213844	NOTTINGHM	213846	NOTTREAC	1	230	230	Summer Gen Deliv	Included
2022W3-GD-S96	213846	NOTTREAC	213869	PCHBTMTP	1	230	230	Summer Gen Deliv	Included
2022W3-N1-ST11	313393	8MARS	313399	6MARS	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST11	314916	8MORRSVL	313440	8VINTHIL	1	500/500	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST11	314916	8MORRSVL	313440	8VINTHIL	1	500/500	345/345	Summer N-1 Thermal	Included
2022W3-GD-S166	213869	PCHBTMTP	214087	COOPER2	1	230	230	Summer Gen Deliv	Included
2022W3-N1-ST10	221092	FIVE.FOR	221096	ROCKRGE1	1	115/115	232/232	Summer N-1 Thermal	Included
2022W3-GD-S166	204530	27GERMANTN	235463	01TANEY	1	138	227/201	Summer Gen Deliv	Included
2022W3-N1-ST11	313399	6MARS	313746	6SOJOURNER	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-GD-S88	314916	8MORRSVL	313440	8VINTHIL	1	500	345	Summer Gen Deliv	Included
2022W3-N1-ST11	314006	6ASHBURA	314010	6BEAMEAD	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-GD-S89	314916	8MORRSVL	313440	8VINTHIL	1	500	345	Summer Gen Deliv	Included
2022W3-N1-ST11	314009	6BRADOCK	314052	6IDYLWOD	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-GD-S167	014749	6CHARLVL	314772	6PROFFIT	1	230	345	Summer Gen Deliv	Included
2022W3-N1-ST11	235101	01BEDNGT	235445	01BEDNGT	4	500/138	201/201	Summer N-1 Thermal	Included
2022W3-GD-S91	223938	DICKH230	223937	DICK 230	1	230	233	Summer Gen Deliv	Included
2022W3-N1-ST11	314039	6GALLOWS A	314052	6IDYLWOD	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-GD-S90	223938	DICKH230	223937	DICK 230	2	230	233	Summer Gen Deliv	Included
2022W3-N1-ST11	314068	6OX	314039	6GALLOWS A	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST11	207922	BRIS	204515	27YORKANA	1	230/230	229/227	Summer N-1 Thermal	Included
2022W3-N1-ST12	221092	FIVE.FOR	221096	ROCKRGE1	1	115/115	232/232	Summer N-1 Thermal	Included
2022W3-N1-ST13	314006	6ASHBURA	314010	6BEAMEAD	1	230/230	345/345	Summer N-1 Thermal	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-N1-WT133	313904	6GOOSECRK	314006	6ASHBURA	1	230/230	345/345	Winter N-1 Thermal	Included
2022W3-N1-ST122	204539	27HUNTRSTN	205912	AD1-020 TAP	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-WT133	313904	6GOOSECRK	314006	6ASHBURA	1	230/230	345/345	Winter N-1 Thermal	Included
2022W3-N1-WT143	313752	6TAKEOFF	313774	6LINC PRK	1	230/230	345/345	Winter N-1 Thermal	Included
2022W3-GD-S97	207922	BRIS	204515	27YORKANA	1	230	227/229	Summer Gen Deliv	Included
2022W3-N1-ST123	313393	8MARS	313399	6MARS	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-GD-S1672	204539	27HUNTRSTN	205912	AD1-020 TAP	1	115	227	Summer Gen Deliv	Included
2022W3-N1-ST123	314004	6ASHBURN	314010	6BEAMEAD	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-GD-S1672	204539	27HUNTRSTN	205912	AD1-020 TAP	1	115	227	Summer Gen Deliv	Included
2022W3-N1-WT132	314006	6ASHBURA	314010	6BEAMEAD	1	230/230	345/345	Winter N-1 Thermal	Included
2022W3-N1-ST122	313815	6SPRINGH	314079	6RESTON	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-GD-S1676	313904	6GOOSECRK	314006	6ASHBURA	1	230	345	Summer Gen Deliv	Included
2022W3-N1-WT133	313904	6GOOSECRK	314006	6ASHBURA	1	230/230	345/345	Winter N-1 Thermal	Included
2022W3-N1-ST123	313393	8MARS	313399	6MARS	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-GD-S1032	200064	PCHBTM1S	200004	CNASTONE	1	500	232/230	Summer Gen Deliv	Included
2022W3-N1-WT133	313399	6MARS	313746	6SOJOURNER	1	230/230	345/345	Winter N-1 Thermal	Included
2022W3-N1-ST124	313393	8MARS	313399	6MARS	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-GD-S1042	213844	NOTTNGHM	213846	NOTTREAC	1	230	230	Summer Gen Deliv	Included
2022W3-N1-ST125	314006	6ASHBURA	314010	6BEAMEAD	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST126	314068	6OX	314039	6GALLOWS A	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST127	205912	AD1-020 TAP	204544	27LINCOLN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-ST132	207922	BRIS	204515	27YORKANA	1	230/230	229/227	Summer N-1 Thermal	Included
2022W3-N1-ST142	207922	BRIS	204515	27YORKANA	1	230/230	229/227	Summer N-1 Thermal	Included
2022W3-N1-ST143	313393	8MARS	313399	6MARS	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-WT142	200512	26LEWISTWN	200519	26REED TAP	1	115/115	226/226	Winter N-1 Thermal	Included
2022W3-N1-ST133	314006	6ASHBURA	314010	6BEAMEAD	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST133	314035	6DISCOVER	313774	6LINC PRK	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST132	207922	BRIS	204515	27YORKANA	1	230/230	229/227	Summer N-1 Thermal	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-N1-WT143	13399	6MARS	313746	6SOJOURNER	1	230/230	345/345	Winter N-1 Thermal	Included
2022W3-N1-ST134	14916	8MORRSVL	313440	8VINTHIL	1	500/500	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST135	235503	01REID	235505	01RINGLD	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-ST136	235187	01GRANDP	235180	01FAYETT	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-ST137	14068	6OX	314039	6GALLOWS A	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST138	14939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST149	14009	6BRADOCK	314052	6IDYLOWD	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST150	14009	6BRADOCK	314052	6IDYLOWD	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-WT163	14006	6ASHBURA	314010	6BEAMEAD	1	230/230	345/345	Winter N-1 Thermal	Included
2022W3-N1-ST158	14925	8PL VIEW	314072	6PL VIEW	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-WT162	242514	05J.FERR	242684	05J.FERR	3	765/138	205/205	Winter N-1 Thermal	Included
2022W3-N1-ST152	235467	01FRNCHM	235592	01HAMPS1	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-WT160	14006	6ASHBURA	314010	6BEAMEAD	1	230/230	345/345	Winter N-1 Thermal	Included
2022W3-N1-ST142	14939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-WT153	14006	6ASHBURA	314010	6BEAMEAD	1	230/230	345/345	Winter N-1 Thermal	Included
2022W3-N1-ST143	14939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-WT152	7922	BRIS	204515	27YORKANA	1	230/230	229/227	Winter N-1 Thermal	Included
2022W3-N1-ST144	14925	8PL VIEW	314072	6PL VIEW	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST145	235467	01FRNCHM	235592	01HAMPS1	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-WT156	14916	8MORRSVL	313440	8VINTHIL	1	500/500	345/345	Winter N-1 Thermal	Included
2022W3-N1-ST146	235592	01HAMPS1	235471	01GORE	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-ST147	14068	6OX	314039	6GALLOWS A	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST148	13805	6SHELLHORN1	314098	6GREENWAY1	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-WT159	14916	8MORRSVL	313440	8VINTHIL	1	500/500	345/345	Winter N-1 Thermal	Included
2022W3-N1-ST159	235592	01HAMPS1	235471	01GORE	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-ST160	235592	01HAMPS1	235471	01GORE	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-ST161	14072	6PL VIEW	314004	6ASHBURN	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST162	14939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345/345	Summer N-1 Thermal	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-GD-W95	214084	COOPER	220964	GRACETON	1	230	230/232	Winter Gen Deliv	Included
2022W3-N1-ST16	314072	6PL VIEW	314004	6ASHBURN	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST15	235592	01HAMPS1	235471	01GORE	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-WT16	235483	01MDWBRK	235444	01BART 1	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-ST15	314925	8PL VIEW	314072	6PL VIEW	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST15	205912	AD1-020 TAP	204544	27LINCOLN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-WT16	235471	01GORE	235512	01STONEW	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-ST15	204539	27HUNTRSTN	205912	AD1-020 TAP	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-WT16	235483	01MDWBRK	235444	01BART 1	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-ST15	235467	01FRNCHM	235592	01HAMPS1	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-WT16	207922	BRIS	204515	27YORKANA	1	230/230	229/227	Winter N-1 Thermal	Included
2022W3-N1-ST15	235467	01FRNCHM	235592	01HAMPS1	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-WT16	314068	6OX	314039	6GALLOWS A	1	230/230	345/345	Winter N-1 Thermal	Included
2022W3-N1-ST16	313399	6MARS	313805	6SHELLHORN1	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST17	313399	6MARS	313805	6SHELLHORN1	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-WNC	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-ST17	314039	6GALLOWS A	314052	6IDYLOWOD	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-WNC	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-ST17	313393	8MARS	313399	6MARS	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-WNC	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-ST17	313743	6INTERCONNEC	313733	6NIMBUS	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-WNC	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-ST17	314039	6GALLOWS A	314052	6IDYLOWOD	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-GD-W15	313393	8MARS	313399	6MARS	1	500/230	345	Winter Gen Deliv	Included
2022W3-N1-ST16	313399	6MARS	313805	6SHELLHORN1	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-GD-W14	313399	6MARS	313746	6SOJOURNER	1	230	345	Winter Gen Deliv	Included
2022W3-N1-ST16	314916	8MORRSVL	313440	8VINTHIL	1	500/500	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST16	235503	01REID	235505	01RINGLD	1	138/138	201/201	Summer N-1 Thermal	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-N1-ST162	205912	AD1-020 TAP	204544	27LINCOLN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-GD-W1398	313440	8VINTHIL	314913	8LOUDOUN	1	500	345	Winter Gen Deliv	Included
2022W3-N1-ST162	204539	27HUNTRSTN	205912	AD1-020 TAP	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-WT173	314004	6ASHBURN	314010	6BEAMEAD	1	230/230	345/345	Winter N-1 Thermal	Included
2022W3-GD-W960	242802	05SMITHMTN	242701	05LEESVI	1	138	205	Winter Gen Deliv	Included
2022W3-GD-W1562	200762	26GARRETT	235470	01GARRET	1	115	226/201	Winter Gen Deliv	Included
2022W3-N1-WNC17	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-WNC17	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-WNC18	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-WNC18	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-WNC15	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-GD-W972	204515	27YORKANA	208048	OTCR	1	230	227/229	Winter Gen Deliv	Included
2022W3-N1-WNC5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-ST175	314939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-WNC6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-ST176	314072	6PL VIEW	314004	6ASHBURN	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-GD-W163	314004	6ASHBURN	314010	6BEAMEAD	1	230	345	Winter Gen Deliv	Included
2022W3-N1-WNC7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-WNC8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-ST178	208069	PPL-BGE TIE	220964	GRACETON	1	230/230	229/232	Summer N-1 Thermal	Included
2022W3-N1-WNC9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-GD-W1407	313440	8VINTHIL	314913	8LOUDOUN	1	500	345	Winter Gen Deliv	Included
2022W3-N1-WNC10	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-GD-W174	235120	01ALBRIG	235492	01MTZION	1	138	201	Winter Gen Deliv	Included
2022W3-GD-W173	235120	01ALBRIG	235492	01MTZION	1	138	201	Winter Gen Deliv	Included
2022W3-N1-WNC11	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-WNC12	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-GD-W1002	208047	PPL-BGE TIE	220963	CONASTON	1	230	229/232	Winter Gen Deliv	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-N1-WNC18A	18A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-WNC19A	19A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-WNC20A	20A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-WNC21A	21A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-GD-W98200065	200065	PCHBTM2S	200064	PCHBTM1S	Z2	500	230	Winter Gen Deliv	Included
2022W3-N1-WNC16A	16A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-WNC17A	17A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-GD-W99242701	242701	05LEESVI	314667	4ALTVSTA	1	138	205/345	Winter Gen Deliv	Included
2022W3-N1-WNC18A	18A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-GD-W99200065	200065	PCHBTM2S	200064	PCHBTM1S	Z1	500	230	Winter Gen Deliv	Included
2022W3-N1-WNC19A	19A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-WNC20A	20A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-GD-W99242701	242701	05LEESVI	314667	4ALTVSTA	1	138	205/345	Winter Gen Deliv	Included
2022W3-N1-WNC19A	19A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-WNC20A	20A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-GD-W19235469	235469	01GARRET	235449	01CARLOS	1	138	201	Winter Gen Deliv	Included
2022W3-N1-WNC18A	18A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-GD-W10208048	208048	OTCR	208047	PPL-BGE TIE	1	230	229	Winter Gen Deliv	Included
2022W3-N1-WNC19A	19A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-GD-S181313805	1313805	6SHELLHORN1	313841	6ENTERPRIS	1	230	345	Summer Gen Deliv	Included
2022W3-N1-WNC15A	15A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-GD-W192313805	2313805	6SHELLHORN1	314098	6GREENWAY1	1	230	345	Winter Gen Deliv	Included
2022W3-N1-WNC16A	16A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-GD-S361235105	1235105	01DOUBS	235459	01DOUBS	1	500/230	201	Summer Gen Deliv	Included
2022W3-GD-W10223937	223937	DICK 230	314290	6EDFERRY	1	230	233/345	Winter Gen Deliv	Included
2022W3-N1-WNC17A	17A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-GD-W10223938	223938	DICKH230	223937	DICK 230	1	230	233	Winter Gen Deliv	Included
2022W3-N1-WNC17A	17A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-GD-W1002	223938	DICKH230	223937	DICK 230	2	230	233	Winter Gen Deliv	Included
2022W3-N1-WNC28	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-WNC29	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-GD-W183	314991	8VALLEY SC	314926	8VALLEY	1	500	345	Winter Gen Deliv	Included
2022W3-N1-WNC30	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-GD-W103	313440	8VINTHIL	314125	6VINTHIL	2	500/230	345	Winter Gen Deliv	Included
2022W3-GD-W191	235469	01GARRET	235449	01CARLOS	1	138	201	Winter Gen Deliv	Included
2022W3-N1-WNC41	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-WNC42	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-WNC43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-WNC44	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-GD-S181	235105	01DOUBS	235459	01DOUBS	3	500/230	201	Summer Gen Deliv	Included
2022W3-N1-WNC45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-GD-W152	313440	8VINTHIL	314913	8LOUDOUN	1	500	345	Winter Gen Deliv	Included
2022W3-N1-WNC46	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-GD-S862	235105	01DOUBS	235459	01DOUBS	2	500/230	201	Summer Gen Deliv	Included
2022W3-N1-WNC47	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-GD-W793	314290	6EDFERRY	313911	6TWINCREEKS	1	230	345	Winter Gen Deliv	Included
2022W3-GD-S372	244446	05SOAPSTONE	242792	05SCOTSV	1	138	205	Summer Gen Deliv	Included
2022W3-N1-WNC48	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-GD-W793	314290	6EDFERRY	313911	6TWINCREEKS	1	230	345	Winter Gen Deliv	Included
2022W3-GD-S181	314918	8NO ANNA	314911	8LADYSMITH	1	500	345	Summer Gen Deliv	Included
2022W3-N1-WNC38	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-WNC39	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-WNC40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-GD-S181	314068	6OX	314039	6GALLOWS A	1	230	345	Summer Gen Deliv	Included
2022W3-GD-S181	235105	01DOUBS	235459	01DOUBS	3	500/230	201	Summer Gen Deliv	Included
2022W3-GD-S384	314138	6MINE RD	314137	6FREDBRG	1	230	345	Summer Gen Deliv	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-N1-WT1	205463	01TANEY	235450	01CARROL	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-WT1	205492	01MTZION	235518	01WESTVA	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-WT1	204530	27GERMANTN	235463	01TANEY	1	138/138	227/201	Winter N-1 Thermal	Included
2022W3-N1-WT1	205518	01WESTVA	237506	01CROSSCHOOL	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-WNC	40A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-GD-S18	2013440	8VINTHIL	314913	8LOUDOUN	1	500	345	Summer Gen Deliv	Included
2022W3-N1-WNC	50A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-GD-W79	205938	DICKH230	223937	DICK 230	2	230	233	Winter Gen Deliv	Included
2022W3-GD-S21	2314138	6MINE RD	314137	6FREDBRG	1	230	345	Summer Gen Deliv	Included
2022W3-GD-S38	2314138	6MINE RD	314137	6FREDBRG	1	230	345	Summer Gen Deliv	Included
2022W3-N1-WT1	205483	01MDWBRK	235444	01BART 1	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-GD-W3	205912	AD1-020 TAP	204544	27LINCOLN	1	115	227	Winter Gen Deliv	Included
2022W3-N1-WT3	205912	AD1-020 TAP	204544	27LINCOLN	1	115/115	227/227	Winter N-1 Thermal	Included
2022W3-N1-WT1	205938	DICKH230	223937	DICK 230	2	230/230	233/233	Winter N-1 Thermal	Included
2022W3-GD-W74	205912	AD1-020 TAP	204544	27LINCOLN	1	115	227	Winter Gen Deliv	Included
2022W3-N1-WT4	205912	AD1-020 TAP	204544	27LINCOLN	1	115/115	227/227	Winter N-1 Thermal	Included
2022W3-GD-W74	235471	01GORE	235512	01STONEW	1	138	201	Winter Gen Deliv	Included
2022W3-N1-WT2	205938	DICKH230	223937	DICK 230	2	230/230	233/233	Winter N-1 Thermal	Included
2022W3-GD-W4	235471	01GORE	235512	01STONEW	1	138	201	Winter Gen Deliv	Included
2022W3-N1-WT1	205938	DICKH230	223937	DICK 230	2	230/230	233/233	Winter N-1 Thermal	Included
2022W3-N1-WT7	235471	01GORE	235512	01STONEW	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-WT2	205938	DICKH230	223937	DICK 230	1	230/230	233/233	Winter N-1 Thermal	Included
2022W3-GD-W75	235467	01FRNCHM	235592	01HAMPS1	1	138	201	Winter Gen Deliv	Included
2022W3-N1-WT8	235471	01GORE	235512	01STONEW	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-WT2	205938	DICKH230	223937	DICK 230	2	230/230	233/233	Winter N-1 Thermal	Included
2022W3-N1-WT1	204544	27LINCOLN	204538	27STRABAN	1	115/115	227/227	Winter N-1 Thermal	Included
2022W3-N1-WT1	204539	27HUNTRSTN	205912	AD1-020 TAP	1	115/115	227/227	Winter N-1 Thermal	Included
2022W3-N1-WT1	205912	AD1-020 TAP	204544	27LINCOLN	1	115/115	227/227	Winter N-1 Thermal	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-N1-WT19204538	27	STRABAN	204529	27GERMANTN	1	115/115	227/227	Winter N-1 Thermal	Included
2022W3-N1-WT19218938	223	DICKH230	223937	DICK 230	1	230/230	233/233	Winter N-1 Thermal	Included
2022W3-N1-WT19218938	223	DICKH230	223937	DICK 230	2	230/230	233/233	Winter N-1 Thermal	Included
2022W3-N1-WT12314916	8	MORRSVL	313440	8VINTHIL	1	500/500	345/345	Winter N-1 Thermal	Included
2022W3-GD-W769235187	01	GRANDP	235180	01FAYETT	1	138	201	Winter Gen Deliv	Included
2022W3-N1-WT13314939	8	GOOSE CREEK	313904	6GOOSECRK	1	500/230	345/345	Winter N-1 Thermal	Included
2022W3-GD-W12 204530	27	GERMANTN	235463	01TANEY	1	138	227/201	Winter Gen Deliv	Included
2022W3-N1-WT14235101	01	BEDNGT	235445	01BEDNGT	2	500/138	201/201	Winter N-1 Thermal	Included
2022W3-GD-W1 2513440	8	VINTHIL	314913	8LOUDOUN	1	500	345	Winter Gen Deliv	Included
2022W3-GD-S105213846		NOTTREAC	213869	PCHBTMTP	1	230	230	Summer Gen Deliv	Included
2022W3-GD-W15 213844		NOTTINGHM	213846	NOTTREAC	1	230	230	Winter Gen Deliv	Included
2022W3-N1-WT15314916	8	MORRSVL	313440	8VINTHIL	1	500/500	345/345	Winter N-1 Thermal	Included
2022W3-GD-W1 2513440	8	VINTHIL	314913	8LOUDOUN	1	500	345	Winter Gen Deliv	Included
2022W3-GD-S110207922		BRIS	204515	27YORKANA	1	230	227/229	Summer Gen Deliv	Included
2022W3-GD-W16 213846		NOTTREAC	213869	PCHBTMTP	1	230	230	Winter Gen Deliv	Included
2022W3-N1-WT16314916	8	MORRSVL	313440	8VINTHIL	1	500/500	345/345	Winter N-1 Thermal	Included
2022W3-GD-W1 4113440	8	VINTHIL	314913	8LOUDOUN	1	500	345	Winter Gen Deliv	Included
2022W3-GD-S1679204539	27	HUNTRSTN	205912	AD1-020 TAP	1	115	227	Summer Gen Deliv	Included
2022W3-GD-W77235467	01	FRNCHM	235592	01HAMPS1	1	138	201	Winter Gen Deliv	Included
2022W3-N1-WT17314939	8	GOOSE CREEK	313904	6GOOSECRK	1	500/230	345/345	Winter N-1 Thermal	Included
2022W3-GD-W1 3013440	8	VINTHIL	314913	8LOUDOUN	1	500	345	Winter Gen Deliv	Included
2022W3-GD-S168014925	8	PL VIEW	314072	6PL VIEW	1	500/230	345	Summer Gen Deliv	Included
2022W3-GD-W19 207922		BRIS	204515	27YORKANA	1	230	227/229	Winter Gen Deliv	Included
2022W3-N1-WT18314939	8	GOOSE CREEK	313904	6GOOSECRK	1	500/230	345/345	Winter N-1 Thermal	Included
2022W3-GD-W3 5135504	01	RIDGLY	235484	01MESSCK	1	138	201	Winter Gen Deliv	Included
2022W3-GD-S168313399	6	MARS	313805	6SHELLHORN1	1	230	345	Summer Gen Deliv	Included
2022W3-GD-W775235105	01	DOUBS	235459	01DOUBS	1	500/230	201	Winter Gen Deliv	Included
2022W3-N1-WT19314939	8	GOOSE CREEK	313904	6GOOSECRK	1	500/230	345/345	Winter N-1 Thermal	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-GD-W3143	235504	01RIDGLY	235484	01MESSCK	1	138	201	Winter Gen Deliv	Included
2022W3-N1-WT1	1235471	01GORE	235512	01STONEW	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-GD-W75	235592	01HAMPS1	235471	01GORE	1	138	201	Winter Gen Deliv	Included
2022W3-N1-WT202	223938	DICKH230	223937	DICK 230	1	230/230	233/233	Winter N-1 Thermal	Included
2022W3-N1-WT102	235471	01GORE	235512	01STONEW	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-WT202	223938	DICKH230	223937	DICK 230	1	230/230	233/233	Winter N-1 Thermal	Included
2022W3-GD-W1363	314916	8MORRSVL	313440	8VINTHIL	1	500	345	Winter Gen Deliv	Included
2022W3-N1-WT202	223938	DICKH230	223937	DICK 230	1	230/230	233/233	Winter N-1 Thermal	Included
2022W3-GD-W23	235050	AD2-180 TAP	235501	01PARRN	1	138	201	Winter Gen Deliv	Included
2022W3-N1-WT232	204530	27GERMANTN	235463	01TANEY	1	138/138	227/201	Winter N-1 Thermal	Included
2022W3-GD-S81N2	200004	CNASTONE	200003	BRIGHTON	1	500	233/232	Summer Gen Deliv	Included
2022W3-GD-W786	314916	8MORRSVL	313440	8VINTHIL	1	500	345	Winter Gen Deliv	Included
2022W3-N1-WT243	14041	6GLEBE	314185	6RADNOR	1	230/230	345/345	Winter N-1 Thermal	Included
2022W3-GD-S1683	314916	8MORRSVL	313440	8VINTHIL	1	500	345	Summer Gen Deliv	Included
2022W3-GD-W790	235503	01REID	235505	01RINGLD	1	138	201	Winter Gen Deliv	Included
2022W3-N1-WT253	14041	6GLEBE	314185	6RADNOR	1	230/230	345/345	Winter N-1 Thermal	Included
2022W3-N1-LLT50	235592	01HAMPS1	235471	01GORE	1	138/138	201/201	Light Load N-1	Included
2022W3-GD-S1182	204544	27LINCOLN	204538	27STRABAN	1	115	227	Summer Gen Deliv	Included
2022W3-GD-S1682	204530	27GERMANTN	235463	01TANEY	1	138	227/201	Summer Gen Deliv	Included
2022W3-N1-WT262	235492	01MTZION	235518	01WESTVA	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-GD-S1213	314290	6EDFERRY	313911	6TWINCREEKS	1	230	345	Summer Gen Deliv	Included
2022W3-GD-S1682	204530	27GERMANTN	235463	01TANEY	1	138	227/201	Summer Gen Deliv	Included
2022W3-N1-WT272	235492	01MTZION	235518	01WESTVA	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-LLT52	244423	05JAMES RIVR	244446	05SOAPSTONE	1	138/138	205/205	Light Load N-1	Included
2022W3-GD-S1418	314939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345	Summer Gen Deliv	Included
2022W3-GD-S114	235101	01BEDNGT	235445	01BEDNGT	2	500/138	201	Summer Gen Deliv	Included
2022W3-GD-W793	235479	01JUNCTN	235467	01FRNCHM	1	138	201	Winter Gen Deliv	Included
2022W3-N1-WT282	235492	01MTZION	235518	01WESTVA	1	138/138	201/201	Winter N-1 Thermal	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-GD-S1232	235463	01TANEY	235450	01CARROL	1	138	201	Summer Gen Deliv	Included
2022W3-GD-S1687	223938	DICKH230	223937	DICK 230	1	230	233	Summer Gen Deliv	Included
2022W3-GD-W794	235101	01BEDNGT	235445	01BEDNGT	2	500/138	201	Winter Gen Deliv	Included
2022W3-N1-WT292	235492	01MTZION	235518	01WESTVA	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-LLT54	244423	05JAMES RIVR	244446	05SOAPSTONE	1	138/138	205/205	Light Load N-1	Included
2022W3-N1-ST244	204539	27HUNTRSTN	205912	AD1-020 TAP	1	115/115	227/227	Summer N-1	Included
2022W3-GD-S1688	223938	DICKH230	223937	DICK 230	1	230	233	Summer Gen Deliv	Included
2022W3-GD-W28	205912	AD1-020 TAP	204544	27LINCOLN	1	115	227	Winter Gen Deliv	Included
2022W3-N1-WT302	235492	01MTZION	235518	01WESTVA	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-LLT53	244423	05JAMES RIVR	244446	05SOAPSTONE	1	138/138	205/205	Light Load N-1	Included
2022W3-GD-S1468	214939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345	Summer Gen Deliv	Included
2022W3-N1-WT213	313393	8MARS	313399	6MARS	1	500/230	345/345	Winter N-1 Thermal	Included
2022W3-N1-WT223	313393	8MARS	313399	6MARS	1	500/230	345/345	Winter N-1 Thermal	Included
2022W3-GD-S1682	204514	27TMI	204502	27JACKSON	1	230	227	Summer Gen Deliv	Included
2022W3-GD-W780	235592	01HAMPS1	235471	01GORE	1	138	201	Winter Gen Deliv	Included
2022W3-N1-WT202	204530	27GERMANTN	235463	01TANEY	1	138/138	227/201	Winter N-1 Thermal	Included
2022W3-GD-W806	220047	PPL-BGE TIE	220963	CONASTON	1	230	229/232	Winter Gen Deliv	Included
2022W3-GD-W781	235187	01GRANDP	235180	01FAYETT	1	138	201	Winter Gen Deliv	Included
2022W3-GD-W319	313440	8VINTHIL	314913	8LOUDOUN	1	500	345	Winter Gen Deliv	Included
2022W3-GD-W22	235050	AD2-180 TAP	235501	01PARRN	1	138	201	Winter Gen Deliv	Included
2022W3-GD-S762	200064	PCHBTM1S	200004	CNASTONE	1	500	232/230	Summer Gen Deliv	Included
2022W3-GD-S1683	204544	27LINCOLN	204538	27STRABAN	1	115	227	Summer Gen Deliv	Included
2022W3-GD-S422	205912	AD1-020 TAP	204544	27LINCOLN	1	115	227	Summer Gen Deliv	Included
2022W3-GD-W35	235446	01BLACKO	235103	01BLACKO	3	138/500	201	Winter Gen Deliv	Included
2022W3-N1-ST249	223938	DICKH230	223937	DICK 230	2	230/230	233/233	Summer N-1	Included
2022W3-GD-S1692	204530	27GERMANTN	235463	01TANEY	1	138	227/201	Summer Gen Deliv	Included
2022W3-GD-W38	213869	PCHBTMTP	214087	COOPER2	1	230	230	Winter Gen Deliv	Included
2022W3-GD-S1192	213869	PCHBTMTP	214087	COOPER2	1	230	230	Summer Gen Deliv	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-GD-W39	235467	01FRNCHM	235592	01HAMPS1	1	138	201	Winter Gen Deliv	Included
2022W3-N1-LLT6	242524	05CLOVRD	242519	05CLOVRD	16	345/500	205/205	Light Load N-1	Included
2022W3-N1-ST25	314004	6ASHBURN	314010	6BEAMEAD	1	230/230	345/345	Summer N-1	Included
2022W3-GD-S203	200004	CNASTONE	200003	BRIGHTON	1	500	233/232	Summer Gen Deliv	Included
2022W3-GD-W40	235467	01FRNCHM	235592	01HAMPS1	1	138	201	Winter Gen Deliv	Included
2022W3-GD-W41	204544	27LINCOLN	204538	27STRABAN	1	115	227	Winter Gen Deliv	Included
2022W3-N1-LLT6	244446	05SOAPSTONE	242792	05SCOTSV	1	138/138	205/205	Light Load N-1	Included
2022W3-N1-ST25	314290	6EDFERRY	313911	6TWINCREEKS	1	230/230	345/345	Summer N-1	Included
2022W3-GD-S169	314006	6ASHBURA	314010	6BEAMEAD	1	230	345	Summer Gen Deliv	Included
2022W3-GD-W80	235101	01BEDNGT	235445	01BEDNGT	4	500/138	201	Winter Gen Deliv	Included
2022W3-N1-LLT6	244446	05SOAPSTONE	242792	05SCOTSV	1	138/138	205/205	Light Load N-1	Included
2022W3-N1-ST25	314290	6EDFERRY	313911	6TWINCREEKS	1	230/230	345/345	Summer N-1	Included
2022W3-GD-S125	204529	27GERMANTN	204530	27GERMANTN	1	115/138	227	Summer Gen Deliv	Included
2022W3-GD-W42	314916	8MORRSVL	313440	8VINTHIL	1	500	345	Winter Gen Deliv	Included
2022W3-N1-LLT6	270193	AC1-083 TAP	242802	05SMITHMTN	1	138/138	205/205	Light Load N-1	Included
2022W3-N1-ST25	314939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345/345	Summer N-1	Included
2022W3-GD-S169	235463	01TANEY	235450	01CARROL	1	138	201	Summer Gen Deliv	Included
2022W3-GD-W43	314916	8MORRSVL	313440	8VINTHIL	1	500	345	Winter Gen Deliv	Included
2022W3-N1-LLT6	244446	05SOAPSTONE	242792	05SCOTSV	1	138/138	205/205	Light Load N-1	Included
2022W3-N1-ST25	314939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345/345	Summer N-1	Included
2022W3-GD-W36	235446	01BLACKO	235103	01BLACKO	3	138/500	201	Winter Gen Deliv	Included
2022W3-GD-S168	223938	DICKH230	223937	DICK 230	2	230	233	Summer Gen Deliv	Included
2022W3-GD-W29	235463	01TANEY	235450	01CARROL	1	138	201	Winter Gen Deliv	Included
2022W3-N1-ST24	223938	DICKH230	223937	DICK 230	1	230/230	233/233	Summer N-1	Included
2022W3-GD-S169	223938	DICKH230	223937	DICK 230	2	230	233	Summer Gen Deliv	Included
2022W3-GD-W31	204550	27ORRTANNA	204544	27LINCOLN	1	115	227	Winter Gen Deliv	Included
2022W3-N1-LLT5	244446	05SOAPSTONE	242792	05SCOTSV	1	138/138	205/205	Light Load N-1	Included
2022W3-N1-ST24	204544	27LINCOLN	204538	27STRABAN	1	115/115	227/227	Summer N-1	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-GD-S1692	214084	COOPER	220964	GRACETON	1	230	230/232	Summer Gen Deliv	Included
2022W3-N1-ST247	2233938	DICKH230	223937	DICK 230	1	230/230	233/233	Summer N-1	Included
2022W3-GD-S1693	314290	6EDFERRY	313911	6TWINCREEKS	1	230	345	Summer Gen Deliv	Included
2022W3-GD-W814	204544	27LINCOLN	204538	27STRABAN	1	115	227	Winter Gen Deliv	Included
2022W3-N1-ST258	314316	6LOCKS	314314	3LOCKS	2	230/115	345/345	Summer N-1	Included
2022W3-GD-S1352	213869	PCHBTMTP	214087	COOPER2	1	230	230	Summer Gen Deliv	Included
2022W3-GD-W815	235503	01REID	235505	01RINGLD	1	138	201	Winter Gen Deliv	Included
2022W3-N1-ST257	314316	6LOCKS	314314	3LOCKS	2	230/115	345/345	Summer N-1	Included
2022W3-GD-S1692	235518	01WESTVA	237506	01CROSSCHOOL	1	138	201	Summer Gen Deliv	Included
2022W3-GD-W49	314939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345	Winter Gen Deliv	Included
2022W3-GD_118	314290	6EDFERRY	313911	6TWINCREEKS	1	230	345	Light Load Gen Deliv	Included
2022W3-GD-S1692	235518	01WESTVA	237506	01CROSSCHOOL	1	138	201	Summer Gen Deliv	Included
2022W3-GD-W823	314916	8MORRSVL	313440	8VINTHIL	1	500	345	Winter Gen Deliv	Included
2022W3-N1-ST259	314316	6LOCKS	314314	3LOCKS	2	230/115	345/345	Summer N-1	Included
2022W3-GD-S1700	313393	8MARS	313399	6MARS	1	500/230	345	Summer Gen Deliv	Included
2022W3-GD-W823	314916	8MORRSVL	313440	8VINTHIL	1	500	345	Winter Gen Deliv	Included
2022W3-GD-S1703	313393	8MARS	313399	6MARS	1	500/230	345	Summer Gen Deliv	Included
2022W3-GD-W50	200064	PCHBTM1S	200004	CNASTONE	1	500	232/230	Winter Gen Deliv	Included
2022W3-GD_117	314290	6EDFERRY	313911	6TWINCREEKS	1	230	345	Light Load Gen Deliv	Included
2022W3-GD-S1362	235101	01BEDNGT	235445	01BEDNGT	4	500/138	201	Summer Gen Deliv	Included
2022W3-GD-W51	214084	COOPER	220964	GRACETON	1	230	230/232	Winter Gen Deliv	Included
2022W3-GD-S1392	208071	SAHA34TP	208069	PPL-BGE TIE	1	230	229	Summer Gen Deliv	Included
2022W3-GD-W1367	314041	6GLEBE	314185	6RADNOR	1	230	345	Winter Gen Deliv	Included
2022W3-GD-W45	235592	01HAMPS1	235471	01GORE	1	138	201	Winter Gen Deliv	Included
2022W3-GD-W46	235592	01HAMPS1	235471	01GORE	1	138	201	Winter Gen Deliv	Included
2022W3-GD-S1272	208069	PPL-BGE TIE	220964	GRACETON	1	230	229/232	Summer Gen Deliv	Included
2022W3-GD-W44	204550	27ORRTANNA	204544	27LINCOLN	1	115	227	Winter Gen Deliv	Included
2022W3-N1-LLT67	270193	AC1-083 TAP	242802	05SMITHMTN	1	138/138	205/205	Light Load N-1	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-GD_128	223938	DICKH230	223937	DICK 230	2	230/230	233/233	Light Load Gen Deliv	Included
2022W3-GD-S1692	235463	01TANEY	235450	01CARROL	1	138	201	Summer Gen Deliv	Included
2022W3-N1-LLT62	270193	AC1-083 TAP	242802	05SMITHMTN	1	138/138	205/205	Light Load N-1	Included
2022W3-GD_122	223938	DICKH230	223937	DICK 230	1	230/230	233/233	Light Load Gen Deliv	Included
2022W3-GD-S1698	14290	6EDFERRY	313911	6TWINCREEKS	1	230	345	Summer Gen Deliv	Included
2022W3-N1-LLT62	270193	AC1-083 TAP	242802	05SMITHMTN	1	138/138	205/205	Light Load N-1	Included
2022W3-N1-LLT62	270193	AC1-083 TAP	242802	05SMITHMTN	1	138/138	205/205	Light Load N-1	Included
2022W3-GD-S1703	14939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345	Summer Gen Deliv	Included
2022W3-GD-W55	235518	01WESTVA	237506	01CROSSCHOOL	1	138	201	Winter Gen Deliv	Included
2022W3-GD-S1705	14072	6PL VIEW	314004	6ASHBURN	1	230	345	Summer Gen Deliv	Included
2022W3-GD-W56	235518	01WESTVA	237506	01CROSSCHOOL	1	138	201	Winter Gen Deliv	Included
2022W3-GD-S1472	13869	PCHBTMTP	214087	COOPER2	1	230	230	Summer Gen Deliv	Included
2022W3-GD-W832	13844	NOTTINGHM	213846	NOTTREAC	1	230	230	Winter Gen Deliv	Included
2022W3-GD-S1706	14009	6BRADOCK	314052	6IDYLWOD	1	230	345	Summer Gen Deliv	Included
2022W3-GD-W832	13846	NOTTREAC	213869	PCHBTMTP	1	230	230	Winter Gen Deliv	Included
2022W3-GD-S1707	204544	27LINCOLN	204538	27STRABAN	1	115	227	Summer Gen Deliv	Included
2022W3-GD-W57	314939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345	Winter Gen Deliv	Included
2022W3-GD-S1522	200512	26LEWISTWN	200519	26REED TAP	1	115	226	Summer Gen Deliv	Included
2022W3-GD-S1552	208069	PPL-BGE TIE	220964	GRACETON	1	230	229/232	Summer Gen Deliv	Included
2022W3-GD-W58	204538	27STRABAN	204529	27GERMANTN	1	115	227	Winter Gen Deliv	Included
2022W3-GD-S2032	21092	FIVE.FOR	221096	ROCKRGE1	1	115	232	Summer Gen Deliv	Included
2022W3-GD-W823	14041	6GLEBE	314185	6RADNOR	1	230	345	Winter Gen Deliv	Included
2022W3-GD-W53	235492	01MTZION	235518	01WESTVA	1	138	201	Winter Gen Deliv	Included
2022W3-GD-S1412	235453	01CHERYR	235517	01HARMNY	1	138	201	Summer Gen Deliv	Included
2022W3-GD-W52	235492	01MTZION	235518	01WESTVA	1	138	201	Winter Gen Deliv	Included
2022W3-GD-S1702	200064	PCHBTM1S	200004	CNASTONE	1	500	232/230	Summer Gen Deliv	Included
2022W3-GD-S1703	14035	6DISCOVR	313774	6LINC PRK	1	230	345	Summer Gen Deliv	Included
2022W3-GD-S1712	14939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345	Summer Gen Deliv	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-GD-W843	235479	01JUNCTN	235467	01FRNCHM	1	138	201	Winter Gen Deliv	Included
2022W3-GD-S164	208071	SAHA34TP	208069	PPL-BGE TIE	1	230	229	Summer Gen Deliv	Included
2022W3-GD-W59	313393	8MARS	313399	6MARS	1	500/230	345	Winter Gen Deliv	Included
2022W3-GD-S165	314939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345	Summer Gen Deliv	Included
2022W3-GD-W60	313393	8MARS	313399	6MARS	1	500/230	345	Winter Gen Deliv	Included
2022W3-GD-S204	314939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345	Summer Gen Deliv	Included
2022W3-GD-W61	237310	01DANSMTN	235504	01RIDGLY	1	138	201	Winter Gen Deliv	Included
2022W3-GD-S171	200004	CNASTONE	200003	BRIGHTON	1	500	233/232	Summer Gen Deliv	Included
2022W3-GD-W62	237310	01DANSMTN	235504	01RIDGLY	1	138	201	Winter Gen Deliv	Included
2022W3-GD-S171	200004	CNASTONE	200003	BRIGHTON	1	500	233/232	Summer Gen Deliv	Included
2022W3-GD-W84	204538	27STRABAN	204529	27GERMANTN	1	115	227	Winter Gen Deliv	Included
2022W3-GD-S167	242563	05BOXWD	242603	05CLIFFR	1	138	205	Summer Gen Deliv	Included
2022W3-GD-S171	208071	SAHA34TP	208069	PPL-BGE TIE	1	230	229	Summer Gen Deliv	Included
2022W3-GD-W84	314939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345	Winter Gen Deliv	Included
2022W3-GD-W13	314939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345	Winter Gen Deliv	Included
2022W3-GD-S171	200004	CNASTONE	200003	BRIGHTON	1	500	233/232	Summer Gen Deliv	Included
2022W3-GD-W84	213844	NOTTINGHM	213846	NOTTREAC	1	230	230	Winter Gen Deliv	Included
2022W3-GD-W84	213846	NOTTREAC	213869	PCHBTMTP	1	230	230	Winter Gen Deliv	Included
2022W3-GD-S170	208069	PPL-BGE TIE	220964	GRACETON	1	230	229/232	Summer Gen Deliv	Included
2022W3-GD-S204	221092	FIVE.FOR	221096	ROCKRGE1	1	115	232	Summer Gen Deliv	Included
2022W3-GD-S171	235503	01REID	235505	01RINGLD	1	138	201	Summer Gen Deliv	Included
2022W3-GD-S205	200004	CNASTONE	200003	BRIGHTON	1	500	233/232	Summer Gen Deliv	Included
2022W3-GD-S172	200004	CNASTONE	200003	BRIGHTON	1	500	233/232	Summer Gen Deliv	Included
2022W3-GD-S172	200004	CNASTONE	200003	BRIGHTON	1	500	233/232	Summer Gen Deliv	Included
2022W3-GD-S172	313399	6MARS	313805	6SHELLHORN1	1	230	345	Summer Gen Deliv	Included
2022W3-GD-S171	223937	DICK 230	314290	6EDFERRY	1	230	233/345	Summer Gen Deliv	Included
2022W3-GD-S171	235463	01TANEY	235450	01CARROL	1	138	201	Summer Gen Deliv	Included
2022W3-GD-S171	235463	01TANEY	235450	01CARROL	1	138	201	Summer Gen Deliv	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-GD-S172835463	2835463	01TANEY	235450	01CARROL	1	138	201	Summer Gen Deliv	Included
2022W3-GD-S172800064	2800064	PCHBTM1S	200004	CNASTONE	1	500	232/230	Summer Gen Deliv	Included
2022W3-GD-S172200064	2200064	PCHBTM1S	200004	CNASTONE	1	500	232/230	Summer Gen Deliv	Included
2022W3-GD-S188214084	220964	COOPER	220964	GRACETON	1	230	230/232	Summer Gen Deliv	Included
2022W3-GD-S190242563	242563	05BOXWD	242603	05CLIFFR	1	138	205	Summer Gen Deliv	Included
2022W3-GD-S205200004	200004	CNASTONE	200003	BRIGHTON	1	500	233/232	Summer Gen Deliv	Included
2022W3-GD-S172204544	204544	27LINCOLN	204538	27STRABAN	1	115	227	Summer Gen Deliv	Included
2022W3-N1-LLT1242651	1242651	05GLENL2	242749	05PETERM	1	138/138	205/205	Light Load N-1	Included
2022W3-GD-S172204544	204544	27LINCOLN	204538	27STRABAN	1	115	227	Summer Gen Deliv	Included
2022W3-GD-S172513815	314079	6SPRINGH	314079	6RESTON	1	230	345	Summer Gen Deliv	Included
2022W3-N1-LLT1242651	1242651	05GLENL2	242749	05PETERM	1	138/138	205/205	Light Load N-1	Included
2022W3-N1-LLT1242651	1242651	05GLENL2	242749	05PETERM	1	138/138	205/205	Light Load N-1	Included
2022W3-GD-S173200064	2000064	PCHBTM1S	200004	CNASTONE	1	500	232/230	Summer Gen Deliv	Included
2022W3-GD-S201200004	200004	CNASTONE	200003	BRIGHTON	1	500	233/232	Summer Gen Deliv	Included
2022W3-N1-LLT2242638	2242638	05FIELDALE1	242831	05THORNT	1	138/138	205/205	Light Load N-1	Included
2022W3-GD-S202200004	200004	CNASTONE	200003	BRIGHTON	1	500	233/232	Summer Gen Deliv	Included
2022W3-GD-S214214084	220964	COOPER	220964	GRACETON	1	230	230/232	Summer Gen Deliv	Included
2022W3-GD-S172204544	204544	27LINCOLN	204538	27STRABAN	1	115	227	Summer Gen Deliv	Included
2022W3-N1-LLT2314041	2314041	6GLEBE	314185	6RADNOR	1	230/230	345/345	Light Load N-1	Included
2022W3-GD-S200314939	313904	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345	Summer Gen Deliv	Included
2022W3-N1-LLT2042651	2042651	05GLENL2	242749	05PETERM	1	138/138	205/205	Light Load N-1	Included
2022W3-N1-LLT2314041	2314041	6GLEBE	314185	6RADNOR	1	230/230	345/345	Light Load N-1	Included
2022W3-N1-LLT2314041	2314041	6GLEBE	314185	6RADNOR	1	230/230	345/345	Light Load N-1	Included
2022W3-GD-S173813399	313746	6MARS	313746	6SOJOURNER	1	230	345	Summer Gen Deliv	Included
2022W3-LD-SNC2N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Load Deliverability	Included
2022W3-GD-S221214084	220964	COOPER	220964	GRACETON	1	230	230/232	Summer Gen Deliv	Included
2022W3-LD-SNC1N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Load Deliverability	Included
2022W3-GD-S222313393	313399	8MARS	313399	6MARS	1	500/230	345	Summer Gen Deliv	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-LD-SNC4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Load Deliverability	Included
2022W3-GD-S1739	14916	8MORRSVL	313440	8VINTHIL	1	500	345	Summer Gen Deliv	Included
2022W3-LD-SNC3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Load Deliverability	Included
2022W3-LD-SNC5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Load Deliverability	Included
2022W3-GD-S1732	204538	27STRABAN	204529	27GERMANTN	1	115	227	Summer Gen Deliv	Included
2022W3-GD-S1732	223937	DICK 230	314290	6EDFERRY	1	230	233/345	Summer Gen Deliv	Included
2022W3-GD-S1732	223937	DICK 230	314290	6EDFERRY	1	230	233/345	Summer Gen Deliv	Included
2022W3-GD-S1733	14004	6ASHBURN	314010	6BEAMEAD	1	230	345	Summer Gen Deliv	Included
2022W3-LD-ST10	314290	6EDFERRY	313911	6TWINCREEKS	1	230/230	345/345	Load Deliverability	Included
2022W3-LD-ST5	223938	DICKH230	223937	DICK 230	1	230/230	233/233	Load Deliverability	Included
2022W3-LD-ST4	223938	DICKH230	223937	DICK 230	1	230/230	233/233	Load Deliverability	Included
2022W3-LD-ST7	223937	DICK 230	314290	6EDFERRY	1	230/230	233/345	Load Deliverability	Included
2022W3-LD-ST6	223938	DICKH230	223937	DICK 230	1	230/230	233/233	Load Deliverability	Included
2022W3-LD-ST9	314290	6EDFERRY	313911	6TWINCREEKS	1	230/230	345/345	Load Deliverability	Included
2022W3-LD-ST8	223937	DICK 230	314290	6EDFERRY	1	230/230	233/345	Load Deliverability	Included
2022W3-N1-ST183	14912	8LEXNGTN	314856	6LEXNGT2	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST184	208071	SAHA34TP	208069	PPL-BGE TIE	1	230/230	229/229	Summer N-1 Thermal	Included
2022W3-N1-ST185	13399	6MARS	313746	6SOJOURNER	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST186	13399	6MARS	313746	6SOJOURNER	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST187	14039	6GALLOWS A	314052	6IDYLWOD	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST179	14039	6GALLOWS A	314052	6IDYLWOD	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST180	14919	8OX	314068	6OX	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST181	14925	8PL VIEW	314072	6PL VIEW	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST182	14925	8PL VIEW	314072	6PL VIEW	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST194	200512	26LEWISTWN	200519	26REED TAP	1	115/115	226/226	Summer N-1 Thermal	Included
2022W3-N1-ST195	205912	AD1-020 TAP	204544	27LINCOLN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-ST196	204539	27HUNTRSTN	205912	AD1-020 TAP	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-ST197	235105	01DOUBS	235459	01DOUBS	3	500/230	201/201	Summer N-1 Thermal	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-N1-ST19	313393	8MARS	313399	6MARS	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST18	204538	27STRABAN	204544	27LINCOLN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-ST19	235187	01GRANDP	235180	01FAYETT	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-ST19	314009	6BRADOCK	314052	6IDYLWOD	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST19	313746	6SOJOURNER	313822	6RUNWAY	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST20	204539	27HUNTRSTN	205912	AD1-020 TAP	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-ST20	313399	6MARS	313746	6SOJOURNER	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST20	314004	6ASHBURN	314010	6BEAMEAD	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST20	313746	6SOJOURNER	313822	6RUNWAY	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST19	200512	26LEWISTWN	200519	26REED TAP	1	115/115	226/226	Summer N-1 Thermal	Included
2022W3-N1-ST20	200512	26LEWISTWN	200519	26REED TAP	1	115/115	226/226	Summer N-1 Thermal	Included
2022W3-N1-ST20	223937	DICK 230	314290	6EDFERRY	1	230/230	233/345	Summer N-1 Thermal	Included
2022W3-N1-ST20	213846	NOTTREAC	213869	PCHBTMP	1	230/230	230/230	Summer N-1 Thermal	Included
2022W3-N1-ST20	213844	NOTTINGHM	213846	NOTTREAC	1	230/230	230/230	Summer N-1 Thermal	Included
2022W3-N1-ST20	205912	AD1-020 TAP	204544	27LINCOLN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-ST21	204544	27LINCOLN	204538	27STRABAN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-ST21	204544	27LINCOLN	204538	27STRABAN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-ST21	235105	01DOUBS	235459	01DOUBS	3	500/230	201/201	Summer N-1 Thermal	Included
2022W3-N1-ST20	200512	26LEWISTWN	200519	26REED TAP	1	115/115	226/226	Summer N-1 Thermal	Included
2022W3-N1-ST21	235105	01DOUBS	235459	01DOUBS	3	500/230	201/201	Summer N-1 Thermal	Included
2022W3-N1-ST21	208069	PPL-BGE TIE	220964	GRACETON	1	230/230	229/232	Summer N-1 Thermal	Included
2022W3-N1-ST21	221090	GLENARM2	221089	WINDYED1	1	115/115	232/232	Summer N-1 Thermal	Included
2022W3-N1-ST21	314925	8PL VIEW	314072	6PL VIEW	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST21	314912	8LEXNGTN	314854	6LEXNGT1	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST21	314939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST22	235483	01MDWBRK	235444	01BART 1	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-WNC	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-ST22	235483	01MDWBRK	235444	01BART 1	1	138/138	201/201	Summer N-1 Thermal	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-N1-WNC58A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-ST22235483	01MDWBRK	235444	01BART 1		1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-WNC59A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-WNC60A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-ST21205912	AD1-020 TAP	204544	27LINCOLN		1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-ST22204539	27HUNTRSTN	205912	AD1-020 TAP		1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-WNC51A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-ST22235490	01MORGAN	235453	01CHERYR		1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-WNC52A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-ST22235483	01MDWBRK	235444	01BART 1		1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-WNC53A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-ST22235483	01MDWBRK	235444	01BART 1		1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-WNC54A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-ST22235483	01MDWBRK	235444	01BART 1		1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-WNC55A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-ST22235490	01MORGAN	235453	01CHERYR		1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-WNC56A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-ST22235483	01MDWBRK	235444	01BART 1		1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-ST23314290	6EDFERRY	313911	6TWINCREEKS		1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST24200512	26LEWISTWN	200519	26REED TAP		1	115/115	226/226	Summer N-1 Thermal	Included
2022W3-N1-WNC68A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-ST23314290	6EDFERRY	313911	6TWINCREEKS		1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-WNC69A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-WNC70A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-WNC61A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-ST23200064	PCHBTM1S	200004	CNASTONE		1	500/500	230/232	Summer N-1 Thermal	Included
2022W3-N1-WNC62A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-ST23204544	27LINCOLN	204538	27STRABAN		1	115/115	227/227	Summer N-1 Thermal	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-N1-WNC05A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-ST232	204544	27LINCOLN	204538	27STRABAN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-WNC06A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-ST232	208071	SAHA34TP	208069	PPL-BGE TIE	1	230/230	229/229	Summer N-1 Thermal	Included
2022W3-N1-WNC05A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-ST232	314004	6ASHBURN	314010	6BEAMEAD	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-WNC06A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-ST232	208069	PPL-BGE TIE	220964	GRACETON	1	230/230	229/232	Summer N-1 Thermal	Included
2022W3-N1-WNC07A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-ST232	208069	PPL-BGE TIE	220964	GRACETON	1	230/230	229/232	Summer N-1 Thermal	Included
2022W3-N1-SNC6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Summer N-1 Non Converge	Included
2022W3-N1-SNC7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Summer N-1 Non Converge	Included
2022W3-N1-ST9	204539	27HUNTRSTN	205912	AD1-020 TAP	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-SNC8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Summer N-1 Non Converge	Included
2022W3-N1-ST7	204539	27HUNTRSTN	205912	AD1-020 TAP	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-ST8	205912	AD1-020 TAP	204544	27LINCOLN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-WNC7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-ST242	200512	26LEWISTWN	200519	26REED TAP	1	115/115	226/226	Summer N-1 Thermal	Included
2022W3-N1-WNC7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Winter N-1 Non Converge	Included
2022W3-N1-ST242	313815	6SPRINGH	314079	6RESTON	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST242	313805	6SHELLHORN1	313841	6ENTERPRIS	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-SNC1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Summer N-1 Non Converge	Included
2022W3-N1-ST3	235105	01DOUBS	235459	01DOUBS	3	500/230	201/201	Summer N-1 Thermal	Included
2022W3-N1-SNC2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Summer N-1 Non Converge	Included
2022W3-N1-ST4	235105	01DOUBS	235459	01DOUBS	1	500/230	201/201	Summer N-1 Thermal	Included
2022W3-N1-SNC3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Summer N-1 Non Converge	Included
2022W3-N1-SNC4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Summer N-1 Non Converge	Included
2022W3-N1-ST6	205912	AD1-020 TAP	204544	27LINCOLN	1	115/115	227/227	Summer N-1 Thermal	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-N1-SNC5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Summer N-1 Non Converge	Included
2022W3-N1-ST19	204550	27ORRTANNA	204544	27LINCOLN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-GD_L11	235471	01GORE	235512	01STONEW	1	138/138	201/201	Light Load Gen Deliv	Included
2022W3-N1-ST20	204530	27GERMANTN	235463	01TANEY	1	138/138	227/201	Summer N-1 Thermal	Included
2022W3-GD_L12	235471	01GORE	235512	01STONEW	1	138/138	201/201	Light Load Gen Deliv	Included
2022W3-N1-ST18	204550	27ORRTANNA	204544	27LINCOLN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-ST10	235490	01MORGAN	235453	01CHERYR	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-SNC9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Summer N-1 Non Converge	Included
2022W3-N1-ST11	235490	01MORGAN	235453	01CHERYR	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-SNC10	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Summer N-1 Non Converge	Included
2022W3-N1-ST12	204550	27ORRTANNA	204544	27LINCOLN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-SNC11	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Summer N-1 Non Converge	Included
2022W3-N1-ST13	204550	27ORRTANNA	204544	27LINCOLN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-ST14	204550	27ORRTANNA	204544	27LINCOLN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-ST15	235490	01MORGAN	235453	01CHERYR	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-ST16	235490	01MORGAN	235453	01CHERYR	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-ST17	314084	6SULLY	314035	6DISCOVR	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-GD_L26	9314820	6BALLSTN	314120	6CLRNDNC	1	230/230	345/345	Light Load Gen Deliv	Included
2022W3-GD_L30	9314820	6BALLSTN	314120	6CLRNDNC	1	230/230	345/345	Light Load Gen Deliv	Included
2022W3-N1-ST29	235471	01GORE	235512	01STONEW	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-GD_L31	1235105	01DOUBS	235459	01DOUBS	3	500/230	201/201	Light Load Gen Deliv	Included
2022W3-N1-ST30	235471	01GORE	235512	01STONEW	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-WT41	235467	01FRNCHM	235592	01HAMPS1	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-ST31	313399	6MARS	313805	6SHELLHORN1	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-WT39	235467	01FRNCHM	235592	01HAMPS1	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-WT40	313399	6MARS	313805	6SHELLHORN1	1	230/230	345/345	Winter N-1 Thermal	Included
2022W3-N1-WT31	1235101	01BEDNGT	235445	01BEDNGT	4	500/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-ST21	204530	27GERMANTN	235463	01TANEY	1	138/138	227/201	Summer N-1 Thermal	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-GD_L35	235490	01MORGAN	235453	01CHERYR	1	138/138	201/201	Light Load Gen Deliv	Included
2022W3-N1-WT32	235518	01WESTVA	237506	01CROSSCHOOL	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-ST22	204550	27ORRTANNA	204544	27LINCOLN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-GD_L36	235490	01MORGAN	235453	01CHERYR	1	138/138	201/201	Light Load Gen Deliv	Included
2022W3-N1-WT33	235518	01WESTVA	237506	01CROSSCHOOL	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-ST23	314916	8MORRSVL	313440	8VINTHIL	1	500/500	345/345	Summer N-1 Thermal	Included
2022W3-N1-WT34	235518	01WESTVA	237506	01CROSSCHOOL	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-ST24	204544	27LINCOLN	204538	27STRABAN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-WT35	235518	01WESTVA	237506	01CROSSCHOOL	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-ST25	204544	27LINCOLN	204538	27STRABAN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-WT36	235518	01WESTVA	237506	01CROSSCHOOL	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-ST26	314010	6BEAMEAD	313743	6INTERCONN	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-WT37	314916	8MORRSVL	313440	8VINTHIL	1	500/500	345/345	Winter N-1 Thermal	Included
2022W3-N1-ST27	314041	6GLEBE	314185	6RADNOR	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-WT38	235467	01FRNCHM	235592	01HAMPS1	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-ST28	314041	6GLEBE	314185	6RADNOR	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST39	204539	27HUNTRSTN	205912	AD1-020 TAP	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-ST40	204544	27LINCOLN	205912	AD1-020 TAP	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-WT51	235592	01HAMPS1	235471	01GORE	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-ST41	204550	27ORRTANNA	204544	27LINCOLN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-WT52	2314939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345/345	Winter N-1 Thermal	Included
2022W3-N1-ST42	204550	27ORRTANNA	204544	27LINCOLN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-WT50	235592	01HAMPS1	235471	01GORE	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-WT42	235467	01FRNCHM	235592	01HAMPS1	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-ST32	235471	01GORE	235512	01STONEW	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-WT43	204550	27ORRTANNA	204544	27LINCOLN	1	115/115	227/227	Winter N-1 Thermal	Included
2022W3-N1-ST33	235471	01GORE	235512	01STONEW	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-WT44	204550	27ORRTANNA	204544	27LINCOLN	1	115/115	227/227	Winter N-1 Thermal	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-N1-ST34	314925	8PL VIEW	314072	6PL VIEW	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-GD_L81	242563	05BOXWD	242603	05CLIFFR	1	138/138	205/205	Light Load Gen Deliv	Included
2022W3-N1-WT45	204550	27ORRTANNA	204544	27LINCOLN	1	115/115	227/227	Winter N-1 Thermal	Included
2022W3-N1-ST35	235463	01TANEY	235450	01CARROL	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-WT46	235592	01HAMPS1	235471	01GORE	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-ST36	313904	6GOOSECRK	314006	6ASHBURA	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-WT47	235592	01HAMPS1	235471	01GORE	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-ST37	235463	01TANEY	235450	01CARROL	1	138/138	201/201	Summer N-1 Thermal	Included
2022W3-N1-WT48	314939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345/345	Winter N-1 Thermal	Included
2022W3-N1-ST38	314084	6SULLY	314035	6DISCOVR	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-WT49	313393	8MARS	313399	6MARS	1	500/230	345/345	Winter N-1 Thermal	Included
2022W3-N1-ST49	314035	6DISCOVR	313774	6LINC PRK	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST50	204538	27STRABAN	204529	27GERMANTN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-ST51	204538	27STRABAN	204529	27GERMANTN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-WT62	235463	01TANEY	235450	01CARROL	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-ST52	205912	AD1-020 TAP	204544	27LINCOLN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-WT63	235101	01BEDNGT	235445	01BEDNGT	1	500/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-ST53	204539	27HUNTRSTN	205912	AD1-020 TAP	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-WT53	204544	27LINCOLN	204538	27STRABAN	1	115/115	227/227	Winter N-1 Thermal	Included
2022W3-N1-ST43	313393	8MARS	313399	6MARS	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-WT54	314916	8MORRSVL	313440	8VINTHIL	1	500/500	345/345	Winter N-1 Thermal	Included
2022W3-N1-ST44	313393	8MARS	313399	6MARS	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-WT55	313904	6GOOSECRK	314006	6ASHBURA	1	230/230	345/345	Winter N-1 Thermal	Included
2022W3-N1-ST45	314939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-WT56	314916	8MORRSVL	313440	8VINTHIL	1	500/500	345/345	Winter N-1 Thermal	Included
2022W3-N1-ST46	314916	8MORRSVL	313440	8VINTHIL	1	500/500	345/345	Summer N-1 Thermal	Included
2022W3-N1-WT57	314010	6BEAMEAD	313743	6INTERCONN	1	230/230	345/345	Winter N-1 Thermal	Included
2022W3-N1-ST47	314916	8MORRSVL	313440	8VINTHIL	1	500/500	345/345	Summer N-1 Thermal	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-N1-WT58	204544	27LINCOLN	204538	27STRABAN	1	115/115	227/227	Winter N-1 Thermal	Included
2022W3-N1-ST48	314006	6ASHBURA	314010	6BEAMEAD	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-WT59	235101	01BEDNGT	235445	01BEDNGT	3	500/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-WT60	235463	01TANEY	235450	01CARROL	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-ST59	204539	27HUNTRSTN	205912	AD1-020 TAP	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-ST60	314939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-WT71	313393	8MARS	313399	6MARS	1	500/230	345/345	Winter N-1 Thermal	Included
2022W3-N1-ST61	314939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-WT72	204550	27ORRTANNA	204544	27LINCOLN	1	115/115	227/227	Winter N-1 Thermal	Included
2022W3-N1-ST62	205912	AD1-020 TAP	204544	27LINCOLN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-GD-W850	213844	NOTTINGHM	213846	NOTTREAC	1	230	230	Winter Gen Deliv	Included
2022W3-GD-W851	213846	NOTTREAC	213869	PCHBTMTP	1	230	230	Winter Gen Deliv	Included
2022W3-N1-WT74	314006	6ASHBURA	314010	6BEAMEAD	1	230/230	345/345	Winter N-1 Thermal	Included
2022W3-N1-ST64	223938	DICKH230	223937	DICK 230	2	230/230	233/233	Summer N-1 Thermal	Included
2022W3-N1-WT64	204550	27ORRTANNA	204544	27LINCOLN	1	115/115	227/227	Winter N-1 Thermal	Included
2022W3-N1-ST54	314939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-WT65	204550	27ORRTANNA	204544	27LINCOLN	1	115/115	227/227	Winter N-1 Thermal	Included
2022W3-N1-ST55	313399	6MARS	313805	6SHELLHORN1	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST56	205912	AD1-020 TAP	204544	27LINCOLN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-WT67	313393	8MARS	313399	6MARS	1	500/230	345/345	Winter N-1 Thermal	Included
2022W3-N1-ST57	205912	AD1-020 TAP	204544	27LINCOLN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-WT68	313393	8MARS	313399	6MARS	1	500/230	345/345	Winter N-1 Thermal	Included
2022W3-N1-ST58	204539	27HUNTRSTN	205912	AD1-020 TAP	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-WT70	313393	8MARS	313399	6MARS	1	500/230	345/345	Winter N-1 Thermal	Included
2022W3-N1-ST69	205912	AD1-020 TAP	204544	27LINCOLN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-ST70	205912	AD1-020 TAP	204544	27LINCOLN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-ST71	204539	27HUNTRSTN	205912	AD1-020 TAP	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-N1-ST72	204539	27HUNTRSTN	205912	AD1-020 TAP	1	115/115	227/227	Summer N-1 Thermal	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-GD-W73	200004	CNASTONE	200003	BRIGHTON	1	500	233/232	Winter Gen Deliv	Included
2022W3-N1-ST73	205912	AD1-020 TAP	204544	27LINCOLN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-GD-W74	200004	CNASTONE	200003	BRIGHTON	1	500	233/232	Winter Gen Deliv	Included
2022W3-N1-ST74	204539	27HUNTRSTN	205912	AD1-020 TAP	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-GD-W87	235490	01MORGAN	235453	01CHERYR	1	138	201	Winter Gen Deliv	Excluded
2022W3-N1-WT85	235483	01MDWBRK	235444	01BART 1	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-GD-W63	204514	27TMI	204502	27JACKSON	1	230	227	Winter Gen Deliv	Included
2022W3-N1-WT75	235483	01MDWBRK	235444	01BART 1	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-ST65	223938	DICKH230	223937	DICK 230	1	230/230	233/233	Summer N-1 Thermal	Included
2022W3-GD-W64	204539	27HUNTRSTN	205912	AD1-020 TAP	1	115	227	Winter Gen Deliv	Included
2022W3-N1-WT76	235483	01MDWBRK	235444	01BART 1	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-ST66	314009	6BRADOCK	314052	6IDYLWOD	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-GD-W65	200064	PCHBTM1S	200004	CNASTONE	1	500	232/230	Winter Gen Deliv	Included
2022W3-N1-WT77	235483	01MDWBRK	235444	01BART 1	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-ST67	313904	6GOOSECRK	314006	6ASHBURA	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-GD-W68	200004	CNASTONE	200003	BRIGHTON	1	500	233/232	Winter Gen Deliv	Included
2022W3-N1-WT78	235483	01MDWBRK	235444	01BART 1	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-ST68	314072	6PL VIEW	314004	6ASHBURN	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-GD-W67	200004	CNASTONE	200003	BRIGHTON	1	500	233/232	Winter Gen Deliv	Included
2022W3-N1-WT79	235483	01MDWBRK	235444	01BART 1	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-GD-W86	235101	01BEDNGT	235445	01BEDNGT	3	500/138	201	Winter Gen Deliv	Included
2022W3-GD-W72	235479	01JUNCTN	235467	01FRNCHM	1	138	201	Winter Gen Deliv	Included
2022W3-GD-W71	235479	01JUNCTN	235467	01FRNCHM	1	138	201	Winter Gen Deliv	Included
2022W3-N1-WT92	314072	6PL VIEW	314004	6ASHBURN	1	230/230	345/345	Winter N-1 Thermal	Included
2022W3-GD-W78	200512	26LEWISTWN	200519	26REED TAP	1	115	226	Winter Gen Deliv	Included
2022W3-N1-WT93	314916	8MORRSVL	313440	8VINTHIL	1	500/500	345/345	Winter N-1 Thermal	Included
2022W3-GD-W80	235483	01MDWBRK	235444	01BART 1	1	138	201	Winter Gen Deliv	Included
2022W3-N1-WT94	313399	6MARS	313805	6SHELLHORN1	1	230/230	345/345	Winter N-1 Thermal	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-GD-W79	235483	01MDWBRK	235444	01BART 1	1	138	201	Winter Gen Deliv	Included
2022W3-N1-WT9	5314916	8MORRSVL	313440	8VINTHIL	1	500/500	345/345	Winter N-1 Thermal	Included
2022W3-GD-W88	314939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345	Winter Gen Deliv	Included
2022W3-N1-WT9	6313393	8MARS	313399	6MARS	1	500/230	345/345	Winter N-1 Thermal	Included
2022W3-GD-W87	235101	01BEDNGT	235445	01BEDNGT	1	500/138	201	Winter Gen Deliv	Included
2022W3-N1-WT8	6204539	27HUNTRSTN	205912	AD1-020 TAP	1	115/115	227/227	Winter N-1 Thermal	Included
2022W3-GD-W87	235490	01MORGAN	235453	01CHERYR	1	138	201	Winter Gen Deliv	Excluded
2022W3-N1-ST77	313399	6MARS	313805	6SHELLHORN1	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-GD-W75	313399	6MARS	313805	6SHELLHORN1	1	230	345	Winter Gen Deliv	Included
2022W3-N1-WT8	8204539	27HUNTRSTN	205912	AD1-020 TAP	1	115/115	227/227	Winter N-1 Thermal	Included
2022W3-N1-ST78	313904	6GOOSECRK	314006	6ASHBURA	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-GD-W87	314939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345	Winter Gen Deliv	Included
2022W3-N1-WT8	9313399	6MARS	313805	6SHELLHORN1	1	230/230	345/345	Winter N-1 Thermal	Included
2022W3-GD-W76	313904	6GOOSECRK	314006	6ASHBURA	1	230	345	Winter Gen Deliv	Included
2022W3-N1-WT9	0235483	01MDWBRK	235444	01BART 1	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-GD-W77	314916	8MORRSVL	313440	8VINTHIL	1	500	345	Winter Gen Deliv	Included
2022W3-GD-W87	313393	8MARS	313399	6MARS	1	500/230	345	Winter Gen Deliv	Included
2022W3-N1-WT10	313393	8MARS	313399	6MARS	1	500/230	345/345	Winter N-1 Thermal	Included
2022W3-N1-WT10	0204538	27STRABAN	204529	27GERMANTN	1	115/115	227/227	Winter N-1 Thermal	Included
2022W3-GD-W86	208071	SAHA34TP	208069	PPL-BGE TIE	1	230	229	Winter Gen Deliv	Included
2022W3-N1-WT10	0235483	01MDWBRK	235444	01BART 1	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-GD-W88	204530	27GERMANTN	235463	01TANEY	1	138	227/201	Winter Gen Deliv	Included
2022W3-N1-WT10	0235483	01MDWBRK	235444	01BART 1	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-GD-W90	235501	01PARRN	235479	01JUNCTN	1	138	201	Winter Gen Deliv	Included
2022W3-GD-W89	235501	01PARRN	235479	01JUNCTN	1	138	201	Winter Gen Deliv	Included
2022W3-N1-WT10	0204538	27STRABAN	204529	27GERMANTN	1	115/115	227/227	Winter N-1 Thermal	Included
2022W3-GD-W88	7213869	PCHBTMTP	214087	COOPER2	1	230	230	Winter Gen Deliv	Included
2022W3-GD-W87	200064	PCHBTM1S	200004	CNASTONE	1	500	232/230	Winter Gen Deliv	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-N1-WT9	7313904	6GOOSECRK	314006	6ASHBURA	1	230/230	345/345	Winter N-1 Thermal	Included
2022W3-GD-W83	204515	27YORKANA	208048	OTCR	1	230	227/229	Winter Gen Deliv	Included
2022W3-GD-W84	235471	01GORE	235512	01STONEW	1	138	201	Winter Gen Deliv	Included
2022W3-N1-WT100	7313904	6GOOSECRK	314006	6ASHBURA	1	230/230	345/345	Winter N-1 Thermal	Included
2022W3-GD-W88	208071	SAHA34TP	208069	PPL-BGE TIE	1	230	229	Winter Gen Deliv	Included
2022W3-GD-W85	200512	26LEWISTWN	200519	26REED TAP	1	115	226	Winter Gen Deliv	Included
2022W3-N1-WT112	235479	01JUNCTN	235467	01FRNCHM	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-N1-WT112	235479	01JUNCTN	235467	01FRNCHM	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-GD-W89	313393	8MARS	313399	6MARS	1	500/230	345	Winter Gen Deliv	Included
2022W3-GD-W89	313393	8MARS	313399	6MARS	1	500/230	345	Winter Gen Deliv	Included
2022W3-GD-S174	235187	01GRANDP	235180	01FAYETT	1	138	201	Summer Gen Deliv	Included
2022W3-GD-W93	208069	PPL-BGE TIE	220964	GRACETON	1	230	229/232	Winter Gen Deliv	Included
2022W3-N1-WT112	235479	01JUNCTN	235467	01FRNCHM	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-GD-S206	221090	GLENARM2	221089	WINDYED1	1	115	232	Summer Gen Deliv	Included
2022W3-GD-W94	314939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345	Winter Gen Deliv	Included
2022W3-N1-WT112	235479	01JUNCTN	235467	01FRNCHM	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-GD-S174	200004	CNASTONE	200003	BRIGHTON	1	500	233/232	Summer Gen Deliv	Included
2022W3-GD-W89	207922	BRIS	204515	27YORKANA	1	230	227/229	Winter Gen Deliv	Included
2022W3-GD-S174	235467	01FRNCHM	235592	01HAMPS1	1	138	201	Summer Gen Deliv	Included
2022W3-GD-W95	200064	PCHBTM1S	200004	CNASTONE	1	500	232/230	Winter Gen Deliv	Included
2022W3-N1-WT112	235483	01MDWBRK	235444	01BART 1	1	138/138	201/201	Winter N-1 Thermal	Included
2022W3-GD-W138	200004	CNASTONE	200003	BRIGHTON	1	500	233/232	Winter Gen Deliv	Included
2022W3-GD-W92	314006	6ASHBURA	314010	6BEAMEAD	1	230	345	Winter Gen Deliv	Included
2022W3-N1-WT109	313399	6MARS	313805	6SHELLHORN1	1	230/230	345/345	Winter N-1 Thermal	Included
2022W3-GD-W89	208071	SAHA34TP	208069	PPL-BGE TIE	1	230	229	Winter Gen Deliv	Included
2022W3-N1-WT110	313399	6MARS	313805	6SHELLHORN1	1	230/230	345/345	Winter N-1 Thermal	Included
2022W3-GD-W89	208069	PPL-BGE TIE	220964	GRACETON	1	230	229/232	Winter Gen Deliv	Included
2022W3-GD-W124	200512	26LEWISTWN	200519	26REED TAP	1	115	226	Winter Gen Deliv	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-GD-S236313393		8MARS	313399	6MARS	1	500/230	345	Summer Gen Deliv	Included
2022W3-GD-W10235483		01MDWBRK	235444	01BART 1	1	138	201	Winter Gen Deliv	Included
2022W3-GD-S237313393		8MARS	313399	6MARS	1	500/230	345	Summer Gen Deliv	Included
2022W3-GD-W10235483		01MDWBRK	235444	01BART 1	1	138	201	Winter Gen Deliv	Included
2022W3-LD-ST15200064		PCHBTM1S	200004	CNASTONE	1	500/500	230/232	Load Deliverability	Included
2022W3-GD-W10314072		6PL VIEW	314004	6ASHBURN	1	230	345	Winter Gen Deliv	Included
2022W3-N1-WT12314006		6ASHBURA	314010	6BEAMEAD	1	230/230	345/345	Winter N-1 Thermal	Included
2022W3-LD-ST14200064		PCHBTM1S	200004	CNASTONE	1	500/500	230/232	Load Deliverability	Included
2022W3-GD-S240235105		01DOUBS	235459	01DOUBS	3	500/230	201	Summer Gen Deliv	Included
2022W3-GD-W903207922		BRIS	204515	27YORKANA	1	230	227/229	Winter Gen Deliv	Included
2022W3-LD-ST17200004		CNASTONE	200003	BRIGHTON	1	500/500	232/233	Load Deliverability	Included
2022W3-GD-W90413440		8VINTHIL	314913	8LOUDOUN	1	500	345	Winter Gen Deliv	Included
2022W3-LD-ST16200004		CNASTONE	200003	BRIGHTON	1	500/500	232/233	Load Deliverability	Included
2022W3-GD-S174235467		01FRNCHM	235592	01HAMPS1	1	138	201	Summer Gen Deliv	Included
2022W3-GD-W96200064		PCHBTM1S	200004	CNASTONE	1	500	232/230	Winter Gen Deliv	Included
2022W3-GD-S174235592		01HAMPS1	235471	01GORE	1	138	201	Summer Gen Deliv	Included
2022W3-GD-W90213869		PCHBTMTP	214087	COOPER2	1	230	230	Winter Gen Deliv	Included
2022W3-GD-S174235592		01HAMPS1	235471	01GORE	1	138	201	Summer Gen Deliv	Included
2022W3-GD-W97200004		CNASTONE	200003	BRIGHTON	1	500	233/232	Winter Gen Deliv	Included
2022W3-GD-S231242603		05CLIFFR	242613	05COLLEEN SS	1	138	205	Summer Gen Deliv	Included
2022W3-GD-W98314939		8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345	Winter Gen Deliv	Included
2022W3-GD-S232223937		DICK 230	314290	6EDFERRY	1	230	233/345	Summer Gen Deliv	Included
2022W3-GD-S175204529		27GERMANTN	204530	27GERMANTN	1	115/138	227	Summer Gen Deliv	Included
2022W3-GD-W10235468		01FROSTB	235504	01RIDGLY	1	138	201	Winter Gen Deliv	Included
2022W3-GD-S175208395		FARO FF	208393	FARO DC TIE	2	69/115	229	Summer Gen Deliv	Included
2022W3-GD-W10235468		01FROSTB	235504	01RIDGLY	1	138	201	Winter Gen Deliv	Included
2022W3-LD-ST24314939		8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345/345	Load Deliverability	Included
2022W3-GD-S247208047		PPL-BGE TIE	220963	CONASTON	1	230	229/232	Summer Gen Deliv	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-GD-W102	200004	CNASTONE	200003	BRIGHTON	1	500	233/232	Winter Gen Deliv	Included
2022W3-GD-S2492	235504	01RIDGLY	235484	01MESSCK	1	138	201	Summer Gen Deliv	Included
2022W3-GD-W91	213869	PCHBTMTP	214087	COOPER2	1	230	230	Winter Gen Deliv	Included
2022W3-LD-ST263	314939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345/345	Load Deliverability	Included
2022W3-GD-S1763	314068	6OX	314039	6GALLOWS A	1	230	345	Summer Gen Deliv	Included
2022W3-GD-W11	235490	01MORGAN	235453	01CHERYR	1	138	201	Winter Gen Deliv	Excluded
2022W3-LD-ST253	314939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345/345	Load Deliverability	Included
2022W3-GD-S2522	235504	01RIDGLY	235484	01MESSCK	1	138	201	Summer Gen Deliv	Included
2022W3-GD-W11	235490	01MORGAN	235453	01CHERYR	1	138	201	Winter Gen Deliv	Excluded
2022W3-LD-ST283	314939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345/345	Load Deliverability	Included
2022W3-GD-S2602	208048	OTCR	208047	PPL-BGE TIE	1	230	229	Summer Gen Deliv	Included
2022W3-LD-ST273	314939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345/345	Load Deliverability	Included
2022W3-GD-S2062	221090	GLENARM2	221089	WINDYED1	1	115	232	Summer Gen Deliv	Included
2022W3-GD-W902	208069	PPL-BGE TIE	220964	GRACETON	1	230	229/232	Winter Gen Deliv	Included
2022W3-LD-ST192	200004	CNASTONE	200003	BRIGHTON	1	500/500	232/233	Load Deliverability	Included
2022W3-GD-S1752	200512	26LEWISTWN	200519	26REED TAP	1	115	226	Summer Gen Deliv	Included
2022W3-LD-ST182	200004	CNASTONE	200003	BRIGHTON	1	500/500	232/233	Load Deliverability	Included
2022W3-GD-S1752	204538	27STRABAN	204529	27GERMANTN	1	115	227	Summer Gen Deliv	Included
2022W3-GD-S1752	200532	26ROXBURY	235188	01GREENE	1	138	226/201	Summer Gen Deliv	Included
2022W3-LD-ST202	208047	PPL-BGE TIE	220963	CONASTON	1	230/230	229/232	Load Deliverability	Included
2022W3-GD-S1762	208395	FARO FF	208393	FARO DC TIE	1	69/115	229	Summer Gen Deliv	Included
2022W3-LD-ST233	313904	6GOOSECRK	314006	6ASHBURA	1	230/230	345/345	Load Deliverability	Included
2022W3-LD-ST222	208048	OTCR	208047	PPL-BGE TIE	1	230/230	229/229	Load Deliverability	Included
2022W3-GD-W91	200004	CNASTONE	200003	BRIGHTON	1	500	233/232	Winter Gen Deliv	Included
2022W3-GD-S8272	235105	01DOUBS	235459	01DOUBS	3	500/230	201	Summer Gen Deliv	Included
2022W3-GD-S1763	313805	6SHELLHORN1	314098	6GREENWAY1	1	230	345	Summer Gen Deliv	Included
2022W3-LD-SNC7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Load Deliverability	Included
2022W3-GD-S1763	314939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345	Summer Gen Deliv	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-GD-W11	204530	27GERMANTN	235463	01TANEY	1	138	227/201	Winter Gen Deliv	Included
2022W3-LD-SNC6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Load Deliverability	Included
2022W3-GD-W11	235471	01GORE	235512	01STONEW	1	138	201	Winter Gen Deliv	Included
2022W3-LD-SNC9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Load Deliverability	Included
2022W3-GD-S1763	14939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345	Summer Gen Deliv	Included
2022W3-GD-W11	235471	01GORE	235512	01STONEW	1	138	201	Winter Gen Deliv	Included
2022W3-LD-SNC8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Load Deliverability	Included
2022W3-GD-S2702	242613	05COLLEEN SS	244423	05JAMES RIVR	1	138	205	Summer Gen Deliv	Included
2022W3-GD-W920	00064	PCHBTM1S	200004	CNASTONE	1	500	232/230	Winter Gen Deliv	Included
2022W3-LD-SNC11	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Load Deliverability	Included
2022W3-GD-S1768	14939	8GOOSE CREEK	313904	6GOOSECRK	1	500/230	345	Summer Gen Deliv	Included
2022W3-GD-W12	200519	26REED TAP	200522	26SHADE GP	1	115	226	Winter Gen Deliv	Included
2022W3-LD-SNC11	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Load Deliverability	Included
2022W3-GD-W11	200064	PCHBTM1S	200004	CNASTONE	1	500	232/230	Winter Gen Deliv	Included
2022W3-GD-S1762	242563	05BOXWD	242603	05CLIFFR	1	138	205	Summer Gen Deliv	Included
2022W3-GD-W11	237506	01CROSSCHOOL	235446	01BLACKO	1	138	201	Winter Gen Deliv	Included
2022W3-LD-ST30	313911	6TWINCREEKS	314072	6PL VIEW	1	230/230	345/345	Load Deliverability	Included
2022W3-GD-W11	237506	01CROSSCHOOL	235446	01BLACKO	1	138	201	Winter Gen Deliv	Included
2022W3-LD-ST29	314072	6PL VIEW	314004	6ASHBURN	1	230/230	345/345	Load Deliverability	Included
2022W3-GD-S262	235180	01FAYETT	235271	01WWAYNE	1	138	201	Summer Gen Deliv	Included
2022W3-LD-ST32	314006	6ASHBURA	314010	6BEAMEAD	1	230/230	345/345	Load Deliverability	Included
2022W3-GD-S264	242603	05CLIFFR	242613	05COLLEEN SS	1	138	205	Summer Gen Deliv	Included
2022W3-LD-ST31	313911	6TWINCREEKS	314072	6PL VIEW	1	230/230	345/345	Load Deliverability	Included
2022W3-LD-ST33	314004	6ASHBURN	314010	6BEAMEAD	1	230/230	345/345	Load Deliverability	Included
2022W3-GD-W12	204544	27LINCOLN	204538	27STRABAN	1	115	227	Winter Gen Deliv	Included
2022W3-LD-SNC11	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Load Deliverability	Included
2022W3-GD-S280	235105	01DOUBS	235459	01DOUBS	3	500/230	201	Summer Gen Deliv	Included
2022W3-GD-W920	235334	01GLENFL	235349	01HARR T	1	138	201	Winter Gen Deliv	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-GD-S177208047		PPL-BGE TIE	220963	CONASTON	1	230	229/232	Summer Gen Deliv	Included
2022W3-GD-W12413399		6MARS	313805	6SHELLHORN1	1	230	345	Winter Gen Deliv	Included
2022W3-LD-SNC118/A		N/A	N/A	N/A	N/A	N/A	N/A	Load Deliverability	Included
2022W3-GD-W931214084		COOPER	220964	GRACETON	1	230	230/232	Winter Gen Deliv	Included
2022W3-LD-SNC117/A		N/A	N/A	N/A	N/A	N/A	N/A	Load Deliverability	Included
2022W3-GD-S177314759		6HOLLYMD	314734	6CASHSCORNER	1	230	345	Summer Gen Deliv	Included
2022W3-GD-W125200519		26REED TAP	200522	26SHADE GP	1	115	226	Winter Gen Deliv	Included
2022W3-LD-SNC20/A		N/A	N/A	N/A	N/A	N/A	N/A	Load Deliverability	Included
2022W3-GD-S281200065		PCHBTM2S	200064	PCHBTM1S	Z1	500	230	Summer Gen Deliv	Included
2022W3-GD-W126200532		26ROXBURY	235188	01GREENE	1	138	226/201	Winter Gen Deliv	Included
2022W3-LD-SNC119/A		N/A	N/A	N/A	N/A	N/A	N/A	Load Deliverability	Included
2022W3-GD-W12813393		8MARS	313399	6MARS	1	500/230	345	Winter Gen Deliv	Included
2022W3-LD-SNC20/A		N/A	N/A	N/A	N/A	N/A	N/A	Load Deliverability	Included
2022W3-GD-W130235483		01MDWBRK	235444	01BART 1	1	138	201	Winter Gen Deliv	Included
2022W3-LD-SNC21/A		N/A	N/A	N/A	N/A	N/A	N/A	Load Deliverability	Included
2022W3-GD-W122200512		26LEWISTWN	200519	26REED TAP	1	115	226	Winter Gen Deliv	Included
2022W3-GD-S828235105		01DOUBS	235459	01DOUBS	3	500/230	201	Summer Gen Deliv	Included
2022W3-GD-W138200004		CNASTONE	200003	BRIGHTON	1	500	233/232	Winter Gen Deliv	Included
2022W3-LD-SNC119/A		N/A	N/A	N/A	N/A	N/A	N/A	Load Deliverability	Included
2022W3-GD-S276204514		27TMI	204502	27JACKSON	1	230	227	Summer Gen Deliv	Included
2022W3-LD-SNC118/A		N/A	N/A	N/A	N/A	N/A	N/A	Load Deliverability	Included
2022W3-LD-SNC115/A		N/A	N/A	N/A	N/A	N/A	N/A	Load Deliverability	Included
2022W3-LD-SNC114/A		N/A	N/A	N/A	N/A	N/A	N/A	Load Deliverability	Included
2022W3-GD-W94214084		COOPER	220964	GRACETON	1	230	230/232	Winter Gen Deliv	Included
2022W3-GD-S177314197		6LDYSMITH CT	313837	6SUMMIT	1	230	345	Summer Gen Deliv	Included
2022W3-GD-W138713440		8VINTHIL	314913	8LOUDOUN	1	500	345	Winter Gen Deliv	Included
2022W3-GD-S177204538		27STRABAN	204529	27GERMANTN	1	115	227	Summer Gen Deliv	Included
2022W3-GD-W138813440		8VINTHIL	314913	8LOUDOUN	1	500	345	Winter Gen Deliv	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-GD_L330242524	05CLOVRD	242519	05CLOVRD	16	345/500	205/205	Light Load Gen Deliv	Included	
2022W3-GD-S299235105	01DOUBS	235459	01DOUBS	3	500/230	201	Summer Gen Deliv	Included	
2022W3-GD-W125200519	26REED TAP	200522	26SHADE GP	1	115	226	Winter Gen Deliv	Included	
2022W3-GD_L310314820	6BALLSTN	314120	6CLRNDNC	1	230/230	345/345	Light Load Gen Deliv	Included	
2022W3-GD-S300235105	01DOUBS	235459	01DOUBS	3	500/230	201	Summer Gen Deliv	Included	
2022W3-GD-W949213844	NOTTNGHM	213846	NOTTREAC	1	230	230	Winter Gen Deliv	Included	
2022W3-GD_L82 235467	01FRNCHM	235592	01HAMPS1	1	138/138	201/201	Light Load Gen Deliv	Included	
2022W3-GD-S177913393	8MARS	313399	6MARS	1	500/230	345	Summer Gen Deliv	Included	
2022W3-GD-W139314749	6CHARLVL	314772	6PROFFIT	1	230	345	Winter Gen Deliv	Included	
2022W3-GD_L331235105	01DOUBS	235459	01DOUBS	1	500/230	201/201	Light Load Gen Deliv	Included	
2022W3-GD-S178014901	8BATH CO	314991	8VALLEY SC	1	500	345	Summer Gen Deliv	Included	
2022W3-GD-W95235105	01DOUBS	235459	01DOUBS	3	500/230	201	Winter Gen Deliv	Included	
2022W3-GD_L89 242603	05CLIFFR	242613	05COLLEEN SS	1	138/138	205/205	Light Load Gen Deliv	Included	
2022W3-GD-S304242613	05COLLEEN SS	244423	05JAMES RIVR	1	138	205	Summer Gen Deliv	Included	
2022W3-GD_L83 235467	01FRNCHM	235592	01HAMPS1	1	138/138	201/201	Light Load Gen Deliv	Included	
2022W3-GD-W132200065	PCHBTM2S	200064	PCHBTM1S	Z2	500	230	Winter Gen Deliv	Included	
2022W3-GD-W13314916	8MORRSVL	313440	8VINTHIL	1	500	345	Winter Gen Deliv	Included	
2022W3-GD-S177008048	OTCR	208047	PPL-BGE TIE	1	230	229	Summer Gen Deliv	Included	
2022W3-GD-S177235483	01MDWBRK	235444	01BART 1	1	138	201	Summer Gen Deliv	Included	
2022W3-GD-S177235483	01MDWBRK	235444	01BART 1	1	138	201	Summer Gen Deliv	Included	
2022W3-GD-S178314039	6GALLOWS A	314052	6IDYLWOD	1	230	345	Summer Gen Deliv	Included	
2022W3-GD_L104242613	05COLLEEN SS	244423	05JAMES RIVR	1	138/138	205/205	Light Load Gen Deliv	Included	
2022W3-GD-S178200512	26LEWISTWN	200519	26REED TAP	1	115	226	Summer Gen Deliv	Included	
2022W3-GD-S178314925	8PL VIEW	314072	6PL VIEW	1	500/230	345	Summer Gen Deliv	Included	
2022W3-GD_L109244423	05JAMES RIVR	244446	05SOAPSTONE	1	138/138	205/205	Light Load Gen Deliv	Included	
2022W3-GD-S178814916	8MORRSVL	313440	8VINTHIL	1	500	345	Summer Gen Deliv	Included	
2022W3-GD_L15 235471	01GORE	235512	01STONEW	1	138/138	201/201	Light Load Gen Deliv	Included	
2022W3-GD-S326208048	OTCR	208047	PPL-BGE TIE	1	230	229	Summer Gen Deliv	Included	

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-GD_L116	237310	01DANSMTN	235504	01RIDGLY	1	138/138	201/201	Light Load Gen Deliv	Included
2022W3-GD-S2088	14316	6LOCKS	314314	3LOCKS	2	230/115	345	Summer Gen Deliv	Included
2022W3-GD_L115	237310	01DANSMTN	235504	01RIDGLY	1	138/138	201/201	Light Load Gen Deliv	Included
2022W3-GD-S329	244423	05JAMES RIVR	244446	05SOAPSTONE	1	138	205	Summer Gen Deliv	Included
2022W3-GD_L359	314041	6GLEBE	314185	6RADNOR	1	230/230	345/345	Light Load Gen Deliv	Included
2022W3-GD-S179	235479	01JUNCTN	235467	01FRNCHM	1	138	201	Summer Gen Deliv	Included
2022W3-GD_L276	314041	6GLEBE	314185	6RADNOR	1	230/230	345/345	Light Load Gen Deliv	Included
2022W3-GD-S178	214991	8VALLEY SC	314926	8VALLEY	1	500	345	Summer Gen Deliv	Included
2022W3-GD-S312	2208047	PPL-BGE TIE	220963	CONASTON	1	230	229/232	Summer Gen Deliv	Included
2022W3-GD-S178	314734	6CASHSCORNER	314758	6GORDNVL	1	230	345	Summer Gen Deliv	Included
2022W3-GD_L92	235592	01HAMPS1	235471	01GORE	1	138/138	201/201	Light Load Gen Deliv	Included
2022W3-GD_L91	235592	01HAMPS1	235471	01GORE	1	138/138	201/201	Light Load Gen Deliv	Included
2022W3-GD-S179	221092	FIVE.FOR	221096	ROCKRGE1	1	115	232	Summer Gen Deliv	Included
2022W3-GD_L374	242632	05EDAN 2	242549	05BANSTR	1	138/138	205/205	Light Load Gen Deliv	Included
2022W3-GD-W13	200747	26PENN-MAR	200762	26GARRETT	1	115	226	Winter Gen Deliv	Included
2022W3-GD-W12	200532	26ROXBURY	235188	01GREENE	1	138	226/201	Winter Gen Deliv	Included
2022W3-GD-S333	314010	6BEAMEAD	313743	6INTERCONNEC	1	230	345	Summer Gen Deliv	Included
2022W3-GD-W12	200762	26GARRETT	235470	01GARRET	1	115	226/201	Winter Gen Deliv	Included
2022W3-GD-S179	220962	NWEST311	220972	GRANITE1	1	230	232	Summer Gen Deliv	Included
2022W3-GD_L127	242632	05EDAN 2	242549	05BANSTR	1	138/138	205/205	Light Load Gen Deliv	Included
2022W3-GD_L386	270193	AC1-083 TAP	242802	05SMITHMTN	1	138/138	205/205	Light Load Gen Deliv	Included
2022W3-GD-W10	204530	27GERMANTN	235463	01TANEY	1	138	227/201	Winter Gen Deliv	Included
2022W3-GD-S179	313746	6SOJOURNER	313822	6RUNWAY	1	230	345	Summer Gen Deliv	Included
2022W3-GD_L360	314041	6GLEBE	314185	6RADNOR	1	230/230	345/345	Light Load Gen Deliv	Included
2022W3-GD-W10	204530	27GERMANTN	235463	01TANEY	1	138	227/201	Winter Gen Deliv	Included
2022W3-GD-S336	235486	01MILLVL	235597	01LOVETT	1	138	201	Summer Gen Deliv	Included
2022W3-GD_L132	270193	AC1-083 TAP	242802	05SMITHMTN	1	138/138	205/205	Light Load Gen Deliv	Included
2022W3-GD-W10	205912	AD1-020 TAP	204544	27LINCOLN	1	115	227	Winter Gen Deliv	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-GD_L39	0235503	01REID	235505	01RINGLD	1	138/138	201/201	Light Load Gen Deliv	Included
2022W3-GD-W99	1205912	AD1-020 TAP	204544	27LINCOLN	1	115	227	Winter Gen Deliv	Included
2022W3-GD-S179	2035479	01JUNCTN	235467	01FRNCHM	1	138	201	Summer Gen Deliv	Included
2022W3-GD-S330	2035101	01BEDNGT	235445	01BEDNGT	3	500/138	201	Summer Gen Deliv	Included
2022W3-GD-W11	200532	26ROXBURY	235188	01GREENE	1	138	226/201	Winter Gen Deliv	Included
2022W3-GD-S179	204515	27YORKANA	208048	OTCR	1	230	227/229	Summer Gen Deliv	Included
2022W3-GD-W12	200512	26LEWISTWN	200519	26REED TAP	1	115	226	Winter Gen Deliv	Included
2022W3-GD_L126	244446	05SOAPSTONE	242792	05SCOTSV	1	138/138	205/205	Light Load Gen Deliv	Included
2022W3-GD-W11	500004	CNASTONE	200003	BRIGHTON	1	500	233/232	Winter Gen Deliv	Included
2022W3-GD-S340	204515	27YORKANA	208048	OTCR	1	230	227/229	Summer Gen Deliv	Included
2022W3-GD_L137	235504	01RIDGLY	235593	01HAMPS2	1	138/138	201/201	Light Load Gen Deliv	Included
2022W3-GD-W96	1235446	01BLACKO	235103	01BLACKO	3	138/500	201	Winter Gen Deliv	Included
2022W3-GD_L134	235479	01JUNCTN	235467	01FRNCHM	1	138/138	201/201	Light Load Gen Deliv	Included
2022W3-GD-W12	205188	01GREENE	235557	01LETTER	1	138	201	Winter Gen Deliv	Included
2022W3-GD_L147	235446	01BLACKO	235103	01BLACKO	3	138/500	201/201	Light Load Gen Deliv	Included
2022W3-GD-W11	405463	01TANEY	235450	01CARROL	1	138	201	Winter Gen Deliv	Included
2022W3-GD_L138	235504	01RIDGLY	235593	01HAMPS2	1	138/138	201/201	Light Load Gen Deliv	Included
2022W3-GD-W11	205463	01TANEY	235450	01CARROL	1	138	201	Winter Gen Deliv	Included
2022W3-GD-S210	314039	6GALLOWS A	314052	6IDYLWOD	1	230	345	Summer Gen Deliv	Included
2022W3-GD_L152	242651	05GLENL2	242749	05PETERM	1	138/138	205/205	Light Load Gen Deliv	Included
2022W3-GD-W10	205468	01FROSTB	235504	01RIDGLY	1	138	201	Winter Gen Deliv	Included
2022W3-GD-S180	314934	8SPOTSYL	314916	8MORRSVL	1	500	345	Summer Gen Deliv	Included
2022W3-GD_L148	235446	01BLACKO	235103	01BLACKO	3	138/500	201/201	Light Load Gen Deliv	Included
2022W3-GD-W11	205467	01FRNCHM	235592	01HAMPS1	1	138	201	Winter Gen Deliv	Included
2022W3-GD_L39	1235503	01REID	235505	01RINGLD	1	138/138	201/201	Light Load Gen Deliv	Included
2022W3-GD_L119	237310	01DANSMTN	235504	01RIDGLY	1	138/138	201/201	Light Load Gen Deliv	Included
2022W3-GD-W11	205469	01GARRET	235449	01CARLOS	1	138	201	Winter Gen Deliv	Included
2022W3-GD-W97	1235050	AD2-180 TAP	235501	01PARRN	1	138	201	Winter Gen Deliv	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-GD_L133	235479	01JUNCTN	235467	01FRNCHM	1	138/138	201/201	Light Load Gen Deliv	Included
2022W3-GD-W120	235120	01ALBRIG	235492	01MTZION	1	138	201	Winter Gen Deliv	Included
2022W3-GD-S1799	14749	6CHARLV	314772	6PROFFIT	1	230	345	Summer Gen Deliv	Included
2022W3-GD-W120	235050	AD2-180 TAP	235501	01PARRN	1	138	201	Winter Gen Deliv	Included
2022W3-GD_L18	235471	01GORE	235512	01STONEW	1	138/138	201/201	Light Load Gen Deliv	Included
2022W3-GD_L17	235471	01GORE	235512	01STONEW	1	138/138	201/201	Light Load Gen Deliv	Included
2022W3-GD-S1807	200512	26LEWISTWN	200519	26REED TAP	1	115	226	Summer Gen Deliv	Included
2022W3-GD_L142	235504	01RIDGLY	235593	01HAMPS2	1	138/138	201/201	Light Load Gen Deliv	Included
2022W3-GD-W981	235518	01WESTVA	237506	01CROSSCHOOL	1	138	201	Winter Gen Deliv	Included
2022W3-GD-S1802	242603	05CLIFFR	242613	05COLLEEN SS	1	138	205	Summer Gen Deliv	Included
2022W3-GD_L141	235504	01RIDGLY	235593	01HAMPS2	1	138/138	201/201	Light Load Gen Deliv	Included
2022W3-GD-W10	235501	01PARRN	235479	01JUNCTN	1	138	201	Winter Gen Deliv	Included
2022W3-GD-W10	237310	01DANSMTN	235504	01RIDGLY	1	138	201	Winter Gen Deliv	Included
2022W3-GD-W10	235592	01HAMPS1	235471	01GORE	1	138	201	Winter Gen Deliv	Included
2022W3-GD_L143	235504	01RIDGLY	235593	01HAMPS2	1	138/138	201/201	Light Load Gen Deliv	Included
2022W3-GD-W10	237506	01CROSSCHOOL	235446	01BLACKO	1	138	201	Winter Gen Deliv	Included
2022W3-GD-S1803	13393	8MARS	313399	6MARS	1	500/230	345	Summer Gen Deliv	Included
2022W3-GD-S1805	13837	6SUMMIT	314138	6MINE RD	1	230	345	Summer Gen Deliv	Included
2022W3-GD-W10	235483	01MDWBRK	235444	01BART 1	1	138	201	Winter Gen Deliv	Included
2022W3-GD-S346	200065	PCHBTM2S	200066	PCHBTM1N	2	500	230	Summer Gen Deliv	Included
2022W3-GD-W10	235471	01GORE	235512	01STONEW	1	138	201	Winter Gen Deliv	Included
2022W3-GD-S347	313440	8VINTHIL	314913	8LOUDOUN	1	500	345	Summer Gen Deliv	Included
2022W3-GD-W10	235492	01MTZION	235518	01WESTVA	1	138	201	Winter Gen Deliv	Included
2022W3-GD-S348	244423	05JAMES RIVR	244446	05SOAPSTONE	1	138	205	Summer Gen Deliv	Included
2022W3-GD_L153	242638	05FIELDALE1	242831	05THORNT	1	138/138	205/205	Light Load Gen Deliv	Included
2022W3-GD-W120	235483	01MDWBRK	235444	01BART 1	1	138	201	Winter Gen Deliv	Included
2022W3-GD-W798	23937	DICK 230	314290	6EDFERRY	1	230	233/345	Winter Gen Deliv	Included
2022W3-GD-W160	23937	DICK 230	314290	6EDFERRY	1	230	233/345	Winter Gen Deliv	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-N1-LLT6	235471	01GORE	235512	01STONEW	1	138/138	201/201	Light Load N-1	Included
2022W3-GD-W79	423938	DICKH230	223937	DICK 230	1	230	233	Winter Gen Deliv	Included
2022W3-N1-LLT5	235490	01MORGAN	235453	01CHERYR	1	138/138	201/201	Light Load N-1	Included
2022W3-GD-W79	923937	DICK 230	314290	6EDFERRY	1	230	233/345	Winter Gen Deliv	Included
2022W3-N1-LLT8	235490	01MORGAN	235453	01CHERYR	1	138/138	201/201	Light Load N-1	Included
2022W3-N1-LLT7	235490	01MORGAN	235453	01CHERYR	1	138/138	201/201	Light Load N-1	Included
2022W3-GD-W79	523938	DICKH230	223937	DICK 230	1	230	233	Winter Gen Deliv	Included
2022W3-N1-LLT9	235471	01GORE	235512	01STONEW	1	138/138	201/201	Light Load N-1	Included
2022W3-GD_L19	2242831	05THORNT	242642	05FRANKLIN	1	138/138	205/205	Light Load Gen Deliv	Included
2022W3-N1-WT1	825483	01MDWBRK	235444	01BART 1	1	138/138	201/201	Winter N-1	Included
2022W3-N1-LLT1	235490	01MORGAN	235453	01CHERYR	1	138/138	201/201	Light Load N-1	Included
2022W3-N1-LLT1	235471	01GORE	235512	01STONEW	1	138/138	201/201	Light Load N-1	Included
2022W3-N1-LLT1	235471	01GORE	235512	01STONEW	1	138/138	201/201	Light Load N-1	Included
2022W3-N1-LLT1	235490	01MORGAN	235453	01CHERYR	1	138/138	201/201	Light Load N-1	Included
2022W3-N1-LLT2	235490	01MORGAN	235453	01CHERYR	1	138/138	201/201	Light Load N-1	Excluded
2022W3-N1-LLT2	242603	05CLIFFR	242613	05COLLEEN SS	1	138/138	205/205	Light Load N-1	Included
2022W3-N1-LLT2	242603	05CLIFFR	242613	05COLLEEN SS	1	138/138	205/205	Light Load N-1	Included
2022W3-N1-LLT2	242603	05CLIFFR	242613	05COLLEEN SS	1	138/138	205/205	Light Load N-1	Included
2022W3-N1-LLT2	235490	01MORGAN	235453	01CHERYR	1	138/138	201/201	Light Load N-1	Included
2022W3-N1-LLT2	242563	05BOXWD	242603	05CLIFFR	1	138/138	205/205	Light Load N-1	Included
2022W3-N1-LLT2	242563	05BOXWD	242603	05CLIFFR	1	138/138	205/205	Light Load N-1	Included
2022W3-N1-LLT2	242563	05BOXWD	242603	05CLIFFR	1	138/138	205/205	Light Load N-1	Included
2022W3-N1-LLT2	242563	05BOXWD	242603	05CLIFFR	1	138/138	205/205	Light Load N-1	Included
2022W3-N1-LLT3	242613	05COLLEEN SS	244423	05JAMES RIVR	1	138/138	205/205	Light Load N-1	Included
2022W3-N1-LLT3	235592	01HAMPS1	235471	01GORE	1	138/138	201/201	Light Load N-1	Included
2022W3-N1-LLT3	242613	05COLLEEN SS	244423	05JAMES RIVR	1	138/138	205/205	Light Load N-1	Included
2022W3-N1-LLT3	242613	05COLLEEN SS	244423	05JAMES RIVR	1	138/138	205/205	Light Load N-1	Included
2022W3-N1-LLT3	314820	6BALLSTN	314120	6CLRNDNC	1	230/230	345/345	Light Load N-1	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-N1-LLT3	242613	05COLLEEN SS	244423	05JAMES RIVR	1	138/138	205/205	Light Load N-1	Included
2022W3-N1-LLT3	314820	6BALLSTN	314120	6CLRNDNC	1	230/230	345/345	Light Load N-1	Included
2022W3-N1-LLT3	314820	6BALLSTN	314120	6CLRNDNC	1	230/230	345/345	Light Load N-1	Included
2022W3-N1-LLT3	235467	01FRNCHM	235592	01HAMPS1	1	138/138	201/201	Light Load N-1	Included
2022W3-N1-LLT4	235467	01FRNCHM	235592	01HAMPS1	1	138/138	201/201	Light Load N-1	Included
2022W3-N1-LLT4	235471	01GORE	235512	01STONEW	1	138/138	201/201	Light Load N-1	Included
2022W3-N1-LLT4	235471	01GORE	235512	01STONEW	1	138/138	201/201	Light Load N-1	Included
2022W3-N1-LLT4	244423	05JAMES RIVR	244446	05SOAPSTONE	1	138/138	205/205	Light Load N-1	Included
2022W3-N1-LLT4	235467	01FRNCHM	235592	01HAMPS1	1	138/138	201/201	Light Load N-1	Included
2022W3-N1-LLT4	235467	01FRNCHM	235592	01HAMPS1	1	138/138	201/201	Light Load N-1	Included
2022W3-N1-LLT4	235592	01HAMPS1	235471	01GORE	1	138/138	201/201	Light Load N-1	Included
2022W3-N1-LLT4	235592	01HAMPS1	235471	01GORE	1	138/138	201/201	Light Load N-1	Included
2022W3-GD-S2	235490	01MORGAN	235453	01CHERYR	1	138	201	Summer Gen Deliv	Included
2022W3-GD-S6	235471	01GORE	235512	01STONEW	1	138	201	Summer Gen Deliv	Included
2022W3-GD-S7	235471	01GORE	235512	01STONEW	1	138	201	Summer Gen Deliv	Included
2022W3-GD-S8	205912	AD1-020 TAP	204544	27LINCOLN	1	115	227	Summer Gen Deliv	Included
2022W3-GD-S16	205912	AD1-020 TAP	204544	27LINCOLN	1	115	227	Summer Gen Deliv	Included
2022W3-GD-S1	235490	01MORGAN	235453	01CHERYR	1	138	201	Summer Gen Deliv	Included
2022W3-GD-S16	204550	27ORRTANNA	204544	27LINCOLN	1	115	227	Summer Gen Deliv	Included
2022W3-GD-S16	235463	01TANEY	235450	01CARROL	1	138	201	Summer Gen Deliv	Included
2022W3-GD-S17	235105	01DOUBS	235459	01DOUBS	1	500/230	201	Summer Gen Deliv	Included
2022W3-GD-S10	235105	01DOUBS	235459	01DOUBS	3	500/230	201	Summer Gen Deliv	Included
2022W3-GD-S13	235484	01MESSCK	235490	01MORGAN	1	138	201	Summer Gen Deliv	Included
2022W3-GD-S14	235484	01MESSCK	235490	01MORGAN	1	138	201	Summer Gen Deliv	Included
2022W3-GD-S16	204530	27GERMANTN	235463	01TANEY	1	138	227/201	Summer Gen Deliv	Included
2022W3-GD-S16	204539	27HUNTRSTN	205912	AD1-020 TAP	1	115	227	Summer Gen Deliv	Included
2022W3-GD-S15	204539	27HUNTRSTN	205912	AD1-020 TAP	1	115	227	Summer Gen Deliv	Included
2022W3-GD-S35	235592	01HAMPS1	235471	01GORE	1	138	201	Summer Gen Deliv	Included

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2022W3-GD-S39	235467	01FRNCHM	235592	01HAMPS1	1	138	201	Summer Gen Deliv	Included
2022W3-GD-S41	235592	01HAMPS1	235471	01GORE	1	138	201	Summer Gen Deliv	Included
2022W3-GD-S1642	204550	27ORRTANNA	204544	27LINCOLN	1	115	227	Summer Gen Deliv	Included
2022W3-GD-S23	204544	27LINCOLN	204538	27STRABAN	1	115	227	Summer Gen Deliv	Included
2022W3-GD-S1642	204544	27LINCOLN	204538	27STRABAN	1	115	227	Summer Gen Deliv	Included
2022W3-GD-S34	235467	01FRNCHM	235592	01HAMPS1	1	138	201	Summer Gen Deliv	Included
2022W3-GD-S1652	213844	NOTTINGHM	213846	NOTTREAC	1	230	230	Summer Gen Deliv	Included
2022W3-GD-S2018	314916	8MORRSVL	313440	8VINTHIL	1	500	345	Summer Gen Deliv	Included
2022W3-N1-ST84	204539	27HUNTRSTN	205912	AD1-020 TAP	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-GD-S1652	204539	27HUNTRSTN	205912	AD1-020 TAP	1	115	227	Summer Gen Deliv	Included
2022W3-N1-ST85	313399	6MARS	313805	6SHELLHORN1	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST86	313399	6MARS	313805	6SHELLHORN1	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST87	313904	6GOOSECRK	314006	6ASHBURA	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-N1-ST88	313904	6GOOSECRK	314006	6ASHBURA	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-GD-S1642	205912	AD1-020 TAP	204544	27LINCOLN	1	115	227	Summer Gen Deliv	Included
2022W3-GD-S47	204538	27STRABAN	204529	27GERMANTN	1	115	227	Summer Gen Deliv	Included
2022W3-GD-S1652	204538	27STRABAN	204529	27GERMANTN	1	115	227	Summer Gen Deliv	Included
2022W3-N1-ST79	314916	8MORRSVL	313440	8VINTHIL	1	500/500	345/345	Summer N-1 Thermal	Included
2022W3-GD-S1652	200064	PCHBTM1S	200004	CNASTONE	1	500	232/230	Summer Gen Deliv	Included
2022W3-N1-ST80	314916	8MORRSVL	313440	8VINTHIL	1	500/500	345/345	Summer N-1 Thermal	Included
2022W3-GD-S49	235503	01REID	235505	01RINGLD	1	138	201	Summer Gen Deliv	Included
2022W3-N1-ST81	314068	6OX	314039	6GALLOWS A	1	230/230	345/345	Summer N-1 Thermal	Included
2022W3-GD-S1652	207922	BRIS	204515	27YORKANA	1	230	227/229	Summer Gen Deliv	Included
2022W3-N1-ST82	205912	AD1-020 TAP	204544	27LINCOLN	1	115/115	227/227	Summer N-1 Thermal	Included
2022W3-GD-S1652	205912	AD1-020 TAP	204544	27LINCOLN	1	115	227	Summer Gen Deliv	Included
2022W3-N1-ST83	313904	6GOOSECRK	314006	6ASHBURA	1	230/230	345/345	Summer N-1 Thermal	Included

New Flowgates

None

Financial Information

Capital spend start date 10/2023

Construction start date 10/2027

Project Duration (In Months) 80

Additional Comments

Financial workbook has two versions. The redacted version is the public version. Also, the *.dxt files have been renamed as *.txt files in the zipped modeling files. Contact Larre Hozempa at lhozemp@firstenergycorp.com or 724.454.8617 with any follow-up questions.